

Application address The Oaks Main Street Botcheston Leicester Leicestershire LE9 9FF		Planning ref. 24/00091/FUL	
		Our ref. 2024/0091/04/F/R1	
Description Erection of a single storey detached garage, single storey stables and change of use of land for the keeping of horses (Sui Generis, 1.49 ha)		Consultation date 29/05/2024	
		Response date 12/06/2024	
Planning officer Joe Fleetwood		Reviewing officer Will Barber	
Application type Full		Extension requested ☐	
Refer to standing advice ☒	Conditions ☐	Further consultation required ☐	Concerns ☐

Consultation checklist

No.	Description	Check
1	Location plan	☒
2	Proposed layout plan	☒
3	Evidence that the site can be drained	☒
4	Topographic and ground investigation details	☒
5	The total impermeable area pre and post development	☒
6	All potential flood risk sources have been identified and assessed	☒
7	Existing and proposed peak discharge rates	☒
8	Consideration of sustainable drainage systems	☒
9	Attenuation volume calculations	☒
10	Consideration of the maintenance and management of all drainage elements	☒

LLFA Key Observations and Advice

Leicestershire County Council as Lead Local Flood Authority (LLFA) notes that most of the 1.6ha greenfield site is located within Flood Zone 1, being at low risk of fluvial flooding. The southernmost part of the site is located within Flood Zone 3, being at high risk of flooding from the Rothley Brook (Main River). There is a low risk of surface water flooding. The proposals seek to discharge at an undisclosed rate to a soakaway.

Revised drainage plans have been submitted. Leicestershire County Council as the LLFA advises the LPA that the proposed development is considered to be acceptable based on the surface

water design provided within the application. The development should be constructed in accordance with the details provided.

Advice to the Local Planning Authority

1. Standing Advice – National Planning Policy Framework

When determining planning applications, the local planning authority should ensure flood risk is not increased elsewhere and only consider development appropriate in areas at risk of flooding where informed by a site specific Flood Risk Assessment (FRA) confirming it will not put the users of the development at risk. Where an FRA is applicable this should be undertaken in accordance with the requirements of the National Planning Policy Framework and accompanying Planning Practice Guidance.

2. Standing Advice – Consent

Where there are any works proposed as part of an application which are likely to affect flows in an ordinary watercourse or ditch, the applicant will require consent under Section 23 of the Land Drainage Act 1991. This is in addition to any planning permission that may be granted. Guidance on this process and a sample application form can be found via the following website: <http://www.leicestershire.gov.uk/flood-risk-management>

Applicants are advised to refer to Leicestershire County Council's culverting policy contained within the Local Flood Risk Management Strategy Appendix document, available at the above link. No development should take place within 5 metres of any watercourse or ditch without first contacting the County Council for advice.

This consent does not consider local watercourse bylaws. It is the responsibility of the applicant to check if the local borough or district council has their own bylaws which the proposals will also need to consider.

3. Standing Advice – Maintenance

Note that it is the responsibility of the Local Planning Authority under the DEFRA/DCLG legislation (April 2015) to ensure that a system to facilitate the future maintenance of SuDS features can be managed and maintained in perpetuity before commencement of the works.

4. Standing Advice – Greenfield Development Runoff

For greenfield sites, the peak runoff rate from the development to any drain, sewer or surface water body for the 1 in 1 year rainfall event and the 1 in 100 year rainfall event should never exceed the peak greenfield runoff rate for the same event.

The runoff volume from the development in the 1 in 100 year, 6 hour rainfall event should not exceed the greenfield runoff volume for the same event. Where an increase in discharge volume is unavoidable, the proposals should discharge at QBar or provide alternative mitigation in line with CIRIA C753.

5. Standing Advice – Drainage and waste disposal

Where a drainage or waste disposal system is to be constructed or altered that is not proposed to be adopted by either the WASC (Water and Sewerage Company) or the County Council as highway authority then the system should be constructed in accordance with Part H of Building Regulations 2010.

6. Standing Advice – External surfaces

To prevent an increase in the discharge rate or volume due to development of external surfaces, permeable surface material should be utilised where possible, without an impermeable lining unless required to prevent mobilisation of contaminants or groundwater flooding.

Additional information and guidance is available here:

<https://www.leicestershire.gov.uk/environment-and-planning/flooding-and-drainage/>

Note: Response provided by the Lead Local Flood Authority under the delegated authority of the Director of Environment and Transport.