

From: public.access@hinckley-bosworth.gov.uk
Sent: 22 November 2023 12:44
To: Planning Application Comments
Subject: Consultee Comments for Planning Application 23/01021/FUL

Consultee comments

Dear Sir/Madam,

A consultee has commented on a Planning Application. A summary of the comments is provided below.

Comments were submitted at 22/11/2023 12:43 PM from Mr Peter Reid (peter.reid@hinckley-bosworth.gov.uk) on behalf of HBBC Drainage.

Application Summary

Reference:	23/01021/FUL
Address:	42 Station Road Earl Shilton Leicester Leicestershire LE9 7GA
Proposal:	Erection of four apartments
Case Officer:	David Spring

[Click for further information](#)

Comments Details

No objection subject to the following condition:

Comments:	Development shall not begin until surface water drainage details, incorporating sustainable drainage principles (SuDS) have been submitted to and approved by the Local Planning Authority, and the scheme shall subsequently be implemented in accordance with the approved details before the development is completed.
-----------	---

Kind regards