

From: public.access@hinckley-bosworth.gov.uk <public.access@hinckley-bosworth.gov.uk>
Sent: 12 June 2026 14:58:41 UTC+01:00
To: "PF - Planning" <planningapplications@hinckley-bosworth.gov.uk>
Subject: Consultee Comments for Planning Application 26/00515/ADV
Categories: Yasmin

Consultee comments

Dear Sir/Madam,

A consultee has commented on a Planning Application. A summary of the comments is provided below.

Comments were submitted at 12/06/2026 2:58 PM from Mr Giles Rawdon (giles.rawdon@hinckley-bosworth.gov.uk) on behalf of HBBC ES Pollution 2.

Application Summary

Reference:	26/00515/ADV
Address:	Consol 6 Rainbow Way Burbage Hinckley Leicestershire LE10 2FR
Proposal:	1 no. internally illuminated fascia sign
Case Officer:	Sophie Iliffe

[Click for further information](#)

Comments Details

Table 10.4 and 10.5 of the Institution of Lighting Professionals- Professional Lighting Guidance (PLG 05) 'Brightness of Illuminated Advertisements including Digital Displays' set out maximum luminance levels for illuminated signs.

The application states that the sign is 600cd/m2 which exceeds the recommended levels for a sign in an environmental zone E3 (300 cd/m2).

Comments:

I recommend that the applicant reduces the luminance to a maximum of 300 cd/m2 for use during the hours of darkness. Note 1 to the above table states that "The values in Table 10.4 apply to pre-curfew. The post-curfew levels shall generally be the display being off, unless [in zones E2 to E4 inclusive] the installation is still required to be operational, in which case the performance level shall be 50% of the pre-curfew level.

This may be controlled by condition:

In the hours of darkness the advertisement display luminance shall be no greater than the recommended maximum night time luminance value set out in Table 10.4 within the Institution of Lighting Professionals- Professional Lighting Guidance (PLG 05) 'Brightness of Illuminated Advertisements including Digital Displays' (or its equivalent in a replacement guide) in cd/m2. The environmental zone to be agreed with the Local Planning Authority.

Reason In the interests of amenity, public safety and in order to retain effective planning control.

In Daylight Hours the advertisement display luminance shall be controlled in order to reflect ambient light conditions (to ensure it is neither too bright or too dull), and shall at all times be no greater than the recommended maximum daytime luminance values set out in table 10.5 within the Institution of Lighting Professionals- Professional Lighting Guidance (PLG 05) 'Brightness of Illuminated Advertisements including Digital Displays' (or its equivalent in a replacement guide) in cd/m2.

Reason In the interests of amenity, public safety and in order to retain effective planning control.

Kind regards

This email and any files sent with it are confidential. If this email isn't intended for you, please notify the sender immediately and then permanently delete it. You must not read, print, store, disclose, copy or take any other action in respect of this email. We routinely monitor incoming and outgoing email messages to ensure they comply with Hinckley & Bosworth Borough Council's policy on the use of electronic communications. The contents of emails may have to be disclosed to a request under the Data Protection Act 2018, Freedom of Information Act 2000 and/or the Environmental Information Regulations 2004. The views expressed by the author may not necessarily reflect the views or policies of Hinckley & Bosworth Borough Council. Attachments to email messages may contain viruses that may damage your system. Whilst Hinckley & Bosworth Borough Council has taken every reasonable precaution to minimise this risk, we cannot accept any liability for any damage you suffer as a result. You are advised to carry out your own virus checks before opening any attachment. Save paper - only print this email if necessary. Visit us online: www.hinckley-bosworth.gov.uk Main office: Hinckley Hub, Rugby Road, Hinckley, Leics LE10 0FR