

PJS Consulting Engineers Limited

Unit 4 Winking Hill Farm
Kingston-on-Soar, Nottingham
Nottinghamshire NG11 ODP

Date 29/06/2023 13:54
File SW Model 17.05.23.mdx

Innovyze

Lutterworth Road
Burbage

Designed by matt.leask
Checked by

Network 2019.1

Page 1



Network Design Table for Surface Water Network

PN	Length (m)	Fall (m)	Slope (1:X)	I.Area (ha)	T.E. (mins)	Base Flow (l/s)	k (mm)	n	HYD SECT	DIA (mm)	Section Type	Auto Design
1.004	28.004	0.141	198.6	0.102	0.00	0.0	0.600		o	450	Pipe/Conduit	
1.005	26.776	0.690	38.8	0.188	0.00	0.0	0.600		o	450	Pipe/Conduit	
1.006	21.930	1.319	16.6	0.026	0.00	0.0	0.600		o	450	Pipe/Conduit	
1.007	52.729	1.750	30.1	0.259	0.00	0.0	0.600		o	600	Pipe/Conduit	
1.008	16.134	0.236	68.4	0.149	0.00	0.0	0.600		o	600	Pipe/Conduit	
3.000	30.855	1.060	29.1	0.055	5.00	0.0	0.600		o	225	Pipe/Conduit	
3.001	21.906	0.705	31.1	0.132	0.00	0.0	0.600		o	300	Pipe/Conduit	
3.002	29.084	1.746	16.7	0.056	0.00	0.0	0.600		o	300	Pipe/Conduit	
1.009	32.017	0.071	450.9	0.058	0.00	0.0	0.600		o	600	Pipe/Conduit	
1.010	11.920	0.025	476.8	0.024	0.00	0.0	0.600		o	675	Pipe/Conduit	
1.011	21.125	0.044	476.0	0.000	0.00	0.0	0.600		o	675	Pipe/Conduit	
4.000	24.119	0.450	53.6	0.186	5.00	0.0	0.050	v	-1	Pipe/Conduit		
4.001	3.063	0.030	102.1	0.000	0.00	0.0	0.050	v	-1	Pipe/Conduit		
4.002	18.973	0.290	65.4	0.000	0.00	0.0	0.050	v	-1	Pipe/Conduit		
4.003	30.004	1.700	17.6	0.025	0.00	0.0	0.050	v	-1	Pipe/Conduit		
4.004	51.681	1.190	43.4	0.072	0.00	0.0	0.050	v	-1	Pipe/Conduit		
4.005	10.410	1.451	7.2	0.000	0.00	0.0	0.050	v	-1	Pipe/Conduit		

Network Results Table

PN	Rain (mm/hr)	T.C. (mins)	US/IL (m)	E I.Area (ha)	E Base Flow (l/s)	Foul (l/s)	Add Flow (l/s)	Vel (m/s)	Cap (l/s)	Flow (l/s)
1.004	75.00	6.27	111.000	1.080	0.0	0.0	87.7	1.44	228.9	307.1
1.005	75.00	6.41	110.859	1.268	0.0	0.0	103.0	3.27	520.3	360.6
1.006	75.00	6.48	110.169	1.294	0.0	0.0	105.1	5.00	796.0	368.0
1.007	75.00	6.68	108.700	1.553	0.0	0.0	126.2	4.45	1257.5	441.6
1.008	75.00	6.77	106.950	1.702	0.0	0.0	138.3	2.95	833.6	484.0
3.000	75.00	5.21	110.600	0.055	0.0	0.0	4.5	2.43	96.8	15.6
3.001	75.00	5.34	109.465	0.187	0.0	0.0	15.2	2.83	200.1	53.2
3.002	75.00	5.47	108.760	0.243	0.0	0.0	19.7	3.87	273.6	69.1
1.009	75.00	7.24	106.714	2.003	0.0	0.0	162.7	1.14	322.4	569.6
1.010	75.00	7.40	106.568	2.027	0.0	0.0	164.7	1.19	427.1	576.4
1.011	75.00	7.70	106.543	2.027	0.0	0.0	164.7	1.19	427.5	576.4
4.000	75.00	5.27	111.610	0.186	0.0	0.0	15.1	1.48	3217.5	52.9
4.001	75.00	5.32	111.160	0.186	0.0	0.0	15.1	1.07	2331.2	52.9
4.002	75.00	5.55	111.130	0.186	0.0	0.0	15.1	1.34	2912.2	52.9
4.003	75.00	5.75	110.840	0.211	0.0	0.0	17.1	2.58	5606.9	60.0
4.004	75.00	6.27	109.140	0.283	0.0	0.0	23.0	1.65	3574.3	80.5
4.005	75.00	6.31	107.950	0.283	0.0	0.0	23.0	4.05	8794.2	80.5

©1982-2019 Innovyze

PJS Consulting Engineers Limited		Page 3
Unit 4 Winking Hill Farm Kingston-on-Soar, Nottingham Nottinghamshire NG11 0DP	Lutterworth Road Burbage	
Date 29/06/2023 13:54 File SW Model 17.05.23.mdx	Designed by matt.leask Checked by	
Innovyze	Network 2019.1	

Free Flowing Outfall Details for Surface Water Network

Outfall Pipe Number	Outfall Name	C. Level (m)	I. Level (m)	Min I. Level (m)	D,L (mm)	W (mm)
1.016	S37	107.300	106.000	0.000	0	0

Simulation Criteria for Surface Water Network

Volumetric Runoff Coeff	0.750	Additional Flow - % of Total Flow	0.000
Areal Reduction Factor	1.000	MADD Factor * 10m³/ha Storage	0.000
Hot Start (mins)	0	Inlet Coefficient	0.800
Hot Start Level (mm)	0	Flow per Person per Day (l/per/day)	0.000
Manhole Headloss Coeff (Global)	0.500	Run Time (mins)	60
Foul Sewage per hectare (l/s)	0.000	Output Interval (mins)	1

Number of Input Hydrographs	0	Number of Offline Controls	5	Number of Time/Area Diagrams	0
Number of Online Controls	3	Number of Storage Structures	2	Number of Real Time Controls	0

Synthetic Rainfall Details

Rainfall Model	FSR	Profile Type	Summer
Return Period (years)	100	Cv (Summer)	0.750
Region	England and Wales	Cv (Winter)	0.840
M5-60 (mm)	19.600	Storm Duration (mins)	30
Ratio R	0.402		

©1982-2019 Innovyze

PJS Consulting Engineers Limited		Page 4
Unit 4 Winking Hill Farm Kingston-on-Soar, Nottingham Nottinghamshire NG11 0DP	Lutterworth Road Burbage	
Date 29/06/2023 13:54 File SW Model 17.05.23.mdx	Designed by matt.leask Checked by	
Innovyze	Network 2019.1	

Online Controls for Surface Water Network

Orifice Manhole: S41, DS/PN: 4.003, Volume (m³): 39.2

Diameter (m) 0.150 Discharge Coefficient 0.600 Invert Level (m) 110.840

Orifice Manhole: S43, DS/PN: 4.005, Volume (m³): 110.2

Diameter (m) 0.150 Discharge Coefficient 0.600 Invert Level (m) 107.950

Hydro-Brake® Optimum Manhole: S35, DS/PN: 1.015, Volume (m³): 9.6

Unit Reference	MD-SHE-0201-2190-1400-2190
Design Head (m)	1.400
Design Flow (l/s)	21.9
Flush-Flo™	Calculated
Objective	Minimise upstream storage
Application	Surface
Sump Available	Yes
Diameter (mm)	201
Invert Level (m)	106.100
Minimum Outlet Pipe Diameter (mm)	225
Suggested Manhole Diameter (mm)	1500

Control Points	Head (m)	Flow (l/s)	Control Points	Head (m)	Flow (l/s)
Design Point (Calculated)	1.400	21.9	Kick-Flo®	0.936	18.1
Flush-Flo™	0.425	21.9	Mean Flow over Head Range	-	18.8

The hydrological calculations have been based on the Head/Discharge relationship for the Hydro-Brake® Optimum as specified. Should another type of control device other than a Hydro-Brake Optimum® be utilised then these storage routing calculations will be invalidated

Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)
0.100	6.9	1.200	20.4	3.000	31.5	7.000	47.5
0.200	19.0	1.400	21.9	3.500	34.0	7.500	49.1
0.300	21.5	1.600	23.3	4.000	36.2	8.000	50.7
0.400	21.9	1.800	24.7	4.500	38.3	8.500	52.2
0.500	21.8	2.000	26.0	5.000	40.3	9.000	53.6
0.600	21.5	2.200	27.2	5.500	42.2	9.500	55.1
0.800	20.3	2.400	28.3	6.000	44.1		
1.000	18.7	2.600	29.4	6.500	45.8		

PJS Consulting Engineers Limited		Page 5																																																								
Unit 4 Winking Hill Farm Kingston-on-Soar, Nottingham Nottinghamshire NG11 0DP	Lutterworth Road Burbage																																																									
Date 29/06/2023 13:54 File SW Model 17.05.23.mdx	Designed by matt.leask Checked by																																																									
Innovyze Network 2019.1																																																										
<u>Storage Structures for Surface Water Network</u> <u>Tank or Pond Manhole: S33, DS/PN: 1.013</u> Invert Level (m) 106.400 <table><tr><th>Depth (m)</th><th>Area (m²)</th><th>Depth (m)</th><th>Area (m²)</th></tr><tr><td>0.000</td><td>175.0</td><td>1.200</td><td>638.0</td></tr></table> <u>Tank or Pond Manhole: S35, DS/PN: 1.015</u> Invert Level (m) 106.100 <table><tr><th>Depth (m)</th><th>Area (m²)</th><th>Depth (m)</th><th>Area (m²)</th><th>Depth (m)</th><th>Area (m²)</th><th>Depth (m)</th><th>Area (m²)</th></tr><tr><td>0.000</td><td>791.8</td><td>0.500</td><td>992.5</td><td>1.000</td><td>1206.7</td><td>1.500</td><td>1434.5</td></tr><tr><td>0.100</td><td>830.9</td><td>0.600</td><td>1034.2</td><td>1.100</td><td>1251.2</td><td>1.600</td><td>1481.7</td></tr><tr><td>0.200</td><td>870.4</td><td>0.700</td><td>1076.5</td><td>1.200</td><td>1296.2</td><td>1.700</td><td>1529.3</td></tr><tr><td>0.300</td><td>910.6</td><td>0.800</td><td>1119.4</td><td>1.300</td><td>1341.7</td><td></td><td></td></tr><tr><td>0.400</td><td>951.3</td><td>0.900</td><td>1162.8</td><td>1.400</td><td>1387.8</td><td></td><td></td></tr></table>			Depth (m)	Area (m²)	Depth (m)	Area (m²)	0.000	175.0	1.200	638.0	Depth (m)	Area (m²)	Depth (m)	Area (m²)	Depth (m)	Area (m²)	Depth (m)	Area (m²)	0.000	791.8	0.500	992.5	1.000	1206.7	1.500	1434.5	0.100	830.9	0.600	1034.2	1.100	1251.2	1.600	1481.7	0.200	870.4	0.700	1076.5	1.200	1296.2	1.700	1529.3	0.300	910.6	0.800	1119.4	1.300	1341.7			0.400	951.3	0.900	1162.8	1.400	1387.8		
Depth (m)	Area (m²)	Depth (m)	Area (m²)																																																							
0.000	175.0	1.200	638.0																																																							
Depth (m)	Area (m²)	Depth (m)	Area (m²)	Depth (m)	Area (m²)	Depth (m)	Area (m²)																																																			
0.000	791.8	0.500	992.5	1.000	1206.7	1.500	1434.5																																																			
0.100	830.9	0.600	1034.2	1.100	1251.2	1.600	1481.7																																																			
0.200	870.4	0.700	1076.5	1.200	1296.2	1.700	1529.3																																																			
0.300	910.6	0.800	1119.4	1.300	1341.7																																																					
0.400	951.3	0.900	1162.8	1.400	1387.8																																																					
©1982-2019 Innovyze																																																										

PJS Consulting Engineers Limited

Unit 4 Winking Hill Farm

Kingston-on-Soar, Nottingham

Nottinghamshire NG11 0DP

Date 29/06/2023 13:54

File SW Model 17.05.23.mdx

Lutterworth Road

Burbage

Designed by matt.leask

Checked by

Innovyze

Network 2019.1

Page 6



Summary Wizard of 15 minute 1 year Summer I+0% for Surface Water Network

Simulation Criteria

Areal Reduction Factor 1.000

Hot Start (mins) 0

Hot Start Level (mm) 0

Manhole Headloss Coeff (Global) 0.500

Foul Sewage per hectare (l/s) 0.000

Additional Flow - % of Total Flow 0.000

MADD Factor * 10m³/ha Storage 0.000

Inlet Coeffiecient 0.800

Flow per Person per Day (l/per/day) 0.000

Number of Input Hydrographs 0

Number of Offline Controls 5

Number of Time/Area Diagrams 0

Number of Online Controls 3

Number of Storage Structures 2

Number of Real Time Controls 0

Synthetic Rainfall Details

Rainfall Model FSR

Region England and Wales Cv (Summer) 0.750

M5-60 (mm) 19.600

Cv (Winter) 0.840

Ratio R 0.401

Margin for Flood Risk Warning (mm) 300.0

Analysis Timestep 2.5 Second Increment (Extended)

DTS Status OFF

DVD Status OFF

Inertia Status OFF

Profile(s) Summer and Winter


Duration(s) (mins) 15, 30, 60, 120, 180, 240, 360, 480, 600, 720, 960, 1440

Return Period(s) (years) 1, 30, 100

Climate Change (%) 0, 0, 40

PN	US/MH Name	Storm Rank	Water	Surcharged	Flooded	Flow / Cap.	Overflow	Pipe	Status
			Level (m)	Depth (m)	Volume (m³)		(l/s)	Flow (l/s)	
1.000	S4	20	113.914	-0.161	0.000	0.18	13.7	OK	
1.001	S5	20	112.712	-0.163	0.000	0.17	15.2	OK	
1.002	S6	20	112.036	-0.109	0.000	0.52	18.7	OK	
1.003	S7	20	111.723	-0.292	0.000	0.11	32.1	OK	
2.000	S1	20	113.433	-0.242	0.000	0.27	60.9	OK	
2.001	S2	20	112.768	-0.247	0.000	0.25	75.6	OK	
2.002	S3	20	111.600	-0.305	0.000	0.22	85.4	OK	
1.004	S8	20	111.269	-0.181	0.000	0.66	128.6	OK	
1.005	S9	21	111.038	-0.271	0.000	0.34	147.9	OK	
1.006	S10	20	110.316	-0.303	0.000	0.23	149.9	OK	
1.007	S11	22	108.860	-0.440	0.000	0.16	176.0	OK	
1.008	S12	33	107.219	-0.331	0.000	0.39	189.7	OK	
3.000	S13	20	110.642	-0.183	0.000	0.08	7.1	OK	
3.001	S14	20	109.535	-0.230	0.000	0.12	21.7	OK	
3.002	S15	22	108.827	-0.233	0.000	0.11	27.7	OK	

©1982-2019 Innovyze

PJS Consulting Engineers Limited		Page 8
Unit 4 Winking Hill Farm Kingston-on-Soar, Nottingham Nottinghamshire NG11 0DP		
Lutterworth Road Burbage		
Date 29/06/2023 13:54 File SW Model 17.05.23.mdx		
Designed by matt.leask Checked by		
Innovyze		Network 2019.1

Summary Wizard of 30 minute 1 year Summer I+0% for Surface Water Network

Simulation Criteria

Areal Reduction Factor	1.000	Additional Flow - % of Total Flow	0.000
Hot Start (mins)	0	MADD Factor * 10m³/ha Storage	0.000
Hot Start Level (mm)	0	Inlet Coefficient	0.800
Manhole Headloss Coeff (Global)	0.500	Flow per Person per Day (1/per/day)	0.000
Foul Sewage per hectare (l/s)	0.000		

Number of Input Hydrographs 0 Number of Offline Controls 5 Number of Time/Area Diagrams 0
Number of Online Controls 3 Number of Storage Structures 2 Number of Real Time Controls 0

Synthetic Rainfall Details


Rainfall Model	FSR	Ratio R	0.401
Region	England and Wales	Cv (Summer)	0.750
M5-60 (mm)	19.600	Cv (Winter)	0.840

Margin for Flood Risk Warning (mm) 300.0
Analysis Timestep 2.5 Second Increment (Extended)
DTS Status OFF
DVD Status OFF
Inertia Status OFF

Profile(s) Summer and Winter
Duration(s) (mins) 15, 30, 60, 120, 180, 240, 360, 480, 600, 720, 960, 1440
Return Period(s) (years) 1, 30, 100
Climate Change (%) 0, 0, 40

PN	US/MH Name	Storm Rank	Water	Surcharged	Flooded	Pipe		Status
			Level (m)	Depth (m)	Volume (m³)	Flow / Overflow (l/s)	Flow (l/s)	
1.000	S4	21	113.910	-0.165	0.000	0.16	12.5	OK
1.001	S5	23	112.708	-0.167	0.000	0.15	13.8	OK
1.002	S6	23	112.029	-0.116	0.000	0.47	17.0	OK
1.003	S7	23	111.720	-0.295	0.000	0.10	29.8	OK
2.000	S1	21	113.425	-0.250	0.000	0.25	55.4	OK
2.001	S2	23	112.762	-0.253	0.000	0.23	69.7	OK
2.002	S3	23	111.593	-0.312	0.000	0.21	78.5	OK
1.004	S8	23	111.255	-0.195	0.000	0.61	118.0	OK
1.005	S9	23	111.031	-0.278	0.000	0.31	137.0	OK
1.006	S10	23	110.310	-0.309	0.000	0.22	139.6	OK
1.007	S11	24	108.854	-0.446	0.000	0.15	164.8	OK
1.008	S12	36	107.207	-0.343	0.000	0.37	178.7	OK
3.000	S13	21	110.639	-0.186	0.000	0.07	6.5	OK
3.001	S14	24	109.532	-0.233	0.000	0.11	20.0	OK
3.002	S15	25	108.824	-0.236	0.000	0.10	25.7	OK

©1982-2019 Innovyze

PJS Consulting Engineers Limited		Page 10
Unit 4 Winking Hill Farm Kingston-on-Soar, Nottingham Nottinghamshire NG11 0DP		
Lutterworth Road Burbage		
Date 29/06/2023 13:54 File SW Model 17.05.23.mdx		
Designed by matt.leask Checked by		
Innovyze		Network 2019.1

Summary Wizard of 60 minute 1 year Summer I+0% for Surface Water Network

Simulation Criteria

Areal Reduction Factor 1.000	Additional Flow - % of Total Flow 0.000
Hot Start (mins) 0	MADD Factor * 10m³/ha Storage 0.000
Hot Start Level (mm) 0	Inlet Coefficient 0.800
Manhole Headloss Coeff (Global) 0.500	Flow per Person per Day (l/per/day) 0.000
Foul Sewage per hectare (l/s) 0.000	

Number of Input Hydrographs 0	Number of Offline Controls 5	Number of Time/Area Diagrams 0
Number of Online Controls 3	Number of Storage Structures 2	Number of Real Time Controls 0

Synthetic Rainfall Details


Rainfall Model	FSR	Ratio R 0.401
Region England and Wales Cv (Summer)	0.750	
M5-60 (mm)	19.600	Cv (Winter) 0.840

Margin for Flood Risk Warning (mm)	300.0
Analysis Timestep 2.5 Second Increment (Extended)	
DTS Status	OFF
DVD Status	OFF
Inertia Status	OFF

Profile(s)	Summer and Winter
Duration(s) (mins)	15, 30, 60, 120, 180, 240, 360, 480, 600, 720, 960, 1440
Return Period(s) (years)	1, 30, 100
Climate Change (%)	0, 0, 40

PN	US/MH Name	Storm Rank	Water	Surcharged	Flooded	Pipe		Status
			Level (m)	Depth (m)	Volume (m³)	Flow / Overflow (l/s)	Flow (l/s)	
1.000	S4	28	113.902	-0.173	0.000	0.12	9.5	OK
1.001	S5	28	112.701	-0.174	0.000	0.12	10.5	OK
1.002	S6	29	112.014	-0.131	0.000	0.36	13.1	OK
1.003	S7	29	111.710	-0.305	0.000	0.08	23.4	OK
2.000	S1	28	113.408	-0.267	0.000	0.18	41.8	OK
2.001	S2	29	112.745	-0.270	0.000	0.18	53.2	OK
2.002	S3	29	111.574	-0.331	0.000	0.16	60.3	OK
1.004	S8	29	111.218	-0.232	0.000	0.47	92.0	OK
1.005	S9	29	111.009	-0.300	0.000	0.24	107.3	OK
1.006	S10	29	110.292	-0.327	0.000	0.17	109.3	OK
1.007	S11	30	108.836	-0.464	0.000	0.12	130.0	OK
1.008	S12	39	107.171	-0.379	0.000	0.29	141.7	OK
3.000	S13	28	110.633	-0.192	0.000	0.05	4.9	OK
3.001	S14	30	109.525	-0.240	0.000	0.09	15.7	OK
3.002	S15	30	108.817	-0.243	0.000	0.08	20.3	OK

©1982-2019 Innovyze

PJS Consulting Engineers Limited		Page 12
Unit 4 Winking Hill Farm Kingston-on-Soar, Nottingham Nottinghamshire NG11 0DP		
Lutterworth Road Burbage		
Date 29/06/2023 13:54 File SW Model 17.05.23.mdx		
Designed by matt.leask Checked by		
Innovyze		Network 2019.1

Summary Wizard of 120 minute 1 year Summer I+0% for Surface Water Network

Simulation Criteria

Areal Reduction Factor	1.000	Additional Flow - % of Total Flow	0.000
Hot Start (mins)	0	MADD Factor * 10m³/ha Storage	0.000
Hot Start Level (mm)	0	Inlet Coefficient	0.800
Manhole Headloss Coeff (Global)	0.500	Flow per Person per Day (l/per/day)	0.000
Foul Sewage per hectare (l/s)	0.000		

Number of Input Hydrographs 0 Number of Offline Controls 5 Number of Time/Area Diagrams 0
Number of Online Controls 3 Number of Storage Structures 2 Number of Real Time Controls 0

Synthetic Rainfall Details


Rainfall Model	FSR	Ratio R	0.401
Region	England and Wales	Cv (Summer)	0.750
M5-60 (mm)	19.600	Cv (Winter)	0.840

Margin for Flood Risk Warning (mm) 300.0
Analysis Timestep 2.5 Second Increment (Extended)
DTS Status OFF
DVD Status OFF
Inertia Status OFF

Profile(s) Summer and Winter
Duration(s) (mins) 15, 30, 60, 120, 180, 240, 360, 480, 600, 720, 960, 1440
Return Period(s) (years) 1, 30, 100
Climate Change (%) 0, 0, 40

PN	US/MH Name	Storm Rank	Water	Surcharged	Flooded	Pipe		Status
			Level (m)	Depth (m)	Volume (m³)	Flow / Overflow (l/s)	Flow (l/s)	
1.000	S4	38	113.893	-0.182	0.000	0.08	6.4	OK
1.001	S5	38	112.692	-0.183	0.000	0.08	7.1	OK
1.002	S6	38	111.996	-0.149	0.000	0.25	9.0	OK
1.003	S7	38	111.697	-0.318	0.000	0.06	16.3	OK
2.000	S1	38	113.388	-0.287	0.000	0.13	28.3	OK
2.001	S2	38	112.726	-0.289	0.000	0.12	36.3	OK
2.002	S3	38	111.553	-0.352	0.000	0.11	41.3	OK
1.004	S8	38	111.176	-0.274	0.000	0.33	63.4	OK
1.005	S9	38	110.982	-0.327	0.000	0.17	74.2	OK
1.006	S10	38	110.271	-0.348	0.000	0.12	75.7	OK
1.007	S11	38	108.814	-0.486	0.000	0.08	90.4	OK
1.008	S12	44	107.133	-0.417	0.000	0.20	98.8	OK
3.000	S13	38	110.628	-0.197	0.000	0.04	3.3	OK
3.001	S14	38	109.513	-0.252	0.000	0.06	10.9	OK
3.002	S15	38	108.806	-0.254	0.000	0.06	14.1	OK

©1982-2019 Innovyze

PJS Consulting Engineers Limited		Page 14
Unit 4 Winking Hill Farm Kingston-on-Soar, Nottingham Nottinghamshire NG11 0DP		
Lutterworth Road Burbage		
Date 29/06/2023 13:54 File SW Model 17.05.23.mdx		
Designed by matt.leask Checked by		
Innovyze		Network 2019.1

Summary Wizard of 180 minute 1 year Summer I+0% for Surface Water Network

Simulation Criteria

Areal Reduction Factor	1.000	Additional Flow - % of Total Flow	0.000
Hot Start (mins)	0	MADD Factor * 10m³/ha Storage	0.000
Hot Start Level (mm)	0	Inlet Coefficient	0.800
Manhole Headloss Coeff (Global)	0.500	Flow per Person per Day (l/per/day)	0.000
Foul Sewage per hectare (l/s)	0.000		

Number of Input Hydrographs 0 Number of Offline Controls 5 Number of Time/Area Diagrams 0
Number of Online Controls 3 Number of Storage Structures 2 Number of Real Time Controls 0

Synthetic Rainfall Details


Rainfall Model	FSR	Ratio R	0.401
Region	England and Wales	Cv (Summer)	0.750
M5-60 (mm)	19.600	Cv (Winter)	0.840

Margin for Flood Risk Warning (mm) 300.0
Analysis Timestep 2.5 Second Increment (Extended)
DTS Status OFF
DVD Status OFF
Inertia Status OFF

Profile(s) Summer and Winter
Duration(s) (mins) 15, 30, 60, 120, 180, 240, 360, 480, 600, 720, 960, 1440
Return Period(s) (years) 1, 30, 100
Climate Change (%) 0, 0, 40

PN	US/MH Name	Storm Rank	Water	Surcharged	Flooded	Pipe		Status
			Level (m)	Depth (m)	Volume (m³)	Flow / Overflow (l/s)	Flow (l/s)	
1.000	S4	43	113.887	-0.188	0.000	0.06	5.0	OK
1.001	S5	44	112.686	-0.189	0.000	0.06	5.6	OK
1.002	S6	44	111.987	-0.158	0.000	0.19	7.0	OK
1.003	S7	44	111.690	-0.325	0.000	0.04	12.7	OK
2.000	S1	43	113.378	-0.297	0.000	0.10	21.9	OK
2.001	S2	44	112.717	-0.298	0.000	0.09	28.3	OK
2.002	S3	44	111.543	-0.362	0.000	0.08	32.2	OK
1.004	S8	44	111.153	-0.297	0.000	0.25	49.5	OK
1.005	S9	44	110.967	-0.342	0.000	0.13	58.0	OK
1.006	S10	44	110.260	-0.359	0.000	0.09	59.1	OK
1.007	S11	44	108.798	-0.502	0.000	0.06	70.8	OK
1.008	S12	47	107.109	-0.441	0.000	0.16	77.4	OK
3.000	S13	43	110.625	-0.200	0.000	0.03	2.6	OK
3.001	S14	44	109.507	-0.258	0.000	0.05	8.5	OK
3.002	S15	44	108.800	-0.260	0.000	0.04	11.1	OK

©1982-2019 Innovyze

PJS Consulting Engineers Limited		Page 18
Unit 4 Winking Hill Farm Kingston-on-Soar, Nottingham Nottinghamshire NG11 0DP		
Lutterworth Road Burbage		
Date 29/06/2023 13:54 File SW Model 17.05.23.mdx		
Designed by matt.leask Checked by		
Innovyze		Network 2019.1

Summary Wizard of 360 minute 1 year Summer I+0% for Surface Water Network

Simulation Criteria

Areal Reduction Factor	1.000	Additional Flow - % of Total Flow	0.000
Hot Start (mins)	0	MADD Factor * 10m³/ha Storage	0.000
Hot Start Level (mm)	0	Inlet Coefficient	0.800
Manhole Headloss Coeff (Global)	0.500	Flow per Person per Day (l/per/day)	0.000
Foul Sewage per hectare (l/s)	0.000		

Number of Input Hydrographs	0	Number of Offline Controls	5	Number of Time/Area Diagrams	0
Number of Online Controls	3	Number of Storage Structures	2	Number of Real Time Controls	0

Synthetic Rainfall Details

Rainfall Model	FSR	Ratio R	0.401
Region	England and Wales	Cv (Summer)	0.750
M5-60 (mm)	19.600	Cv (Winter)	0.840

Margin for Flood Risk Warning (mm)	300.0
Analysis Timestep	2.5 Second Increment (Extended)
DTS Status	OFF
DVD Status	OFF
Inertia Status	OFF

Profile(s)	Summer and Winter
Duration(s) (mins)	15, 30, 60, 120, 180, 240, 360, 480, 600, 720, 960, 1440
Return Period(s) (years)	1, 30, 100
Climate Change (%)	0, 0, 40

PN	US/MH Name	Storm Rank	Water	Surcharged	Flooded	Pipe		Status
			Level (m)	Depth (m)	Volume (m³)	Flow / Overflow (l/s)	Flow (l/s)	
1.000	S4	55	113.879	-0.196	0.000	0.04	3.1	OK
1.001	S5	55	112.678	-0.197	0.000	0.04	3.5	OK
1.002	S6	55	111.972	-0.173	0.000	0.12	4.4	OK
1.003	S7	55	111.681	-0.334	0.000	0.03	8.1	OK
2.000	S1	55	113.360	-0.315	0.000	0.06	13.7	OK
2.001	S2	55	112.698	-0.317	0.000	0.06	17.8	OK
2.002	S3	55	111.521	-0.384	0.000	0.05	20.3	OK
1.004	S8	55	111.120	-0.330	0.000	0.16	31.3	OK
1.005	S9	55	110.946	-0.363	0.000	0.08	36.7	OK
1.006	S10	55	110.239	-0.380	0.000	0.06	37.4	OK
1.007	S11	55	108.777	-0.523	0.000	0.04	44.8	OK
1.008	S12	56	107.077	-0.473	0.000	0.10	49.1	OK
3.000	S13	55	110.619	-0.206	0.000	0.02	1.6	OK
3.001	S14	55	109.499	-0.266	0.000	0.03	5.4	OK
3.002	S15	55	108.793	-0.267	0.000	0.03	7.0	OK

©1982-2019 Innovyze

PJS Consulting Engineers Limited

Unit 4 Winking Hill Farm

Kingston-on-Soar, Nottingham

Nottinghamshire NG11 0DP

Date 29/06/2023 13:54

File SW Model 17.05.23.mdx

Lutterworth Road

Burbage

Designed by matt.leask

Checked by

Innovyze

Network 2019.1

Page 20



Summary Wizard of 480 minute 1 year Summer I+0% for Surface Water Network

Simulation Criteria

Areal Reduction Factor 1.000

Hot Start (mins) 0

Hot Start Level (mm) 0

Manhole Headloss Coeff (Global) 0.500

Foul Sewage per hectare (l/s) 0.000

Additional Flow - % of Total Flow 0.000

MADD Factor * 10m³/ha Storage 0.000

Inlet Coeffiecient 0.800

Flow per Person per Day (l/per/day) 0.000

Number of Input Hydrographs 0

Number of Offline Controls 5

Number of Time/Area Diagrams 0

Number of Online Controls 3

Number of Storage Structures 2

Number of Real Time Controls 0

Synthetic Rainfall Details

Rainfall Model FSR

Region England and Wales Cv (Summer) 0.750

M5-60 (mm) 19.600 Cv (Winter) 0.840

Ratio R 0.401

Analysis Timestep 2.5 Second Increment (Extended)

DTS Status OFF

DVD Status OFF

Inertia Status OFF

Profile(s) Summer and Winter

Duration(s) (mins) 15, 30, 60, 120, 180, 240, 360, 480, 600, 720, 960, 1440

Return Period(s) (years) 1, 30, 100

Climate Change (%) 0, 0, 40

Water

US/MH Storm

Level

Depth

Volume

Flow /

Overflow

Pipe

PN

Name

Rank

(m)

(m)

(m³)

Cap.

(l/s)

(l/s)

Status

1.000

S4

59

113.876

-0.199

0.000

0.03

2.5

OK

1.001

S5

59

112.676

-0.199

0.000

0.03

2.8

OK

1.002

S6

59

111.967

-0.178

0.000

0.10

3.6

OK

1.003

S7

59

111.678

-0.337

0.000

0.02

6.6

OK

2.000

S1

59

113.353

-0.322

0.000

0.05

11.1

OK

2.001

S2

59

112.692

-0.323

0.000

0.05

14.4

OK

2.002

S3

59

111.515

-0.390

0.000

0.04

16.5

OK

1.004

S8

59

111.107

-0.343

0.000

0.13

25.4

OK

1.005

S9

59

110.935

-0.374

0.000

0.07

29.9

OK

1.006

S10

59

110.231

-0.388

0.000

0.05

30.5

OK

1.007

S11

59

108.771

-0.529

0.000

0.03

36.6

OK

1.008

S12

59

107.065

-0.485

0.000

0.08

40.1

OK

3.000

S13

59

110.615

-0.210

0.000

0.01

1.3

OK

3.001

S14

59

109.497

-0.268

0.000

0.03

4.4

OK

3.002

S15

59

108.791

-0.269


0.000

0.02

5.7

OK

©1982-2019 Innovyze

PJS Consulting Engineers Limited		Page 22
Unit 4 Winking Hill Farm Kingston-on-Soar, Nottingham Nottinghamshire NG11 0DP		
Lutterworth Road Burbage		
Date 29/06/2023 13:54 File SW Model 17.05.23.mdx		
Designed by matt.leask Checked by		
Innovyze		Network 2019.1

Summary Wizard of 600 minute 1 year Summer I+0% for Surface Water Network

Simulation Criteria

Areal Reduction Factor	1.000	Additional Flow - % of Total Flow	0.000
Hot Start (mins)	0	MADD Factor * 10m³/ha Storage	0.000
Hot Start Level (mm)	0	Inlet Coefficient	0.800
Manhole Headloss Coeff (Global)	0.500	Flow per Person per Day (l/per/day)	0.000
Foul Sewage per hectare (l/s)	0.000		

Number of Input Hydrographs	0	Number of Offline Controls	5	Number of Time/Area Diagrams	0
Number of Online Controls	3	Number of Storage Structures	2	Number of Real Time Controls	0

Synthetic Rainfall Details


Rainfall Model	FSR	Ratio R	0.401
Region	England and Wales	Cv (Summer)	0.750
M5-60 (mm)	19.600	Cv (Winter)	0.840

Margin for Flood Risk Warning (mm)	300.0
Analysis Timestep	2.5 Second Increment (Extended)
DTS Status	OFF
DVD Status	OFF
Inertia Status	OFF

Profile(s)	Summer and Winter
Duration(s) (mins)	15, 30, 60, 120, 180, 240, 360, 480, 600, 720, 960, 1440
Return Period(s) (years)	1, 30, 100
Climate Change (%)	0, 0, 40

PN	US/MH Name	Storm Rank	Water	Surcharged	Flooded	Pipe		Status
			Level (m)	Depth (m)	Volume (m³)	Flow / Overflow (l/s)	Flow (l/s)	
1.000	S4	63	113.875	-0.200	0.000	0.03	2.1	OK
1.001	S5	63	112.674	-0.201	0.000	0.03	2.4	OK
1.002	S6	63	111.964	-0.181	0.000	0.08	3.0	OK
1.003	S7	63	111.674	-0.341	0.000	0.02	5.6	OK
2.000	S1	63	113.349	-0.326	0.000	0.04	9.5	OK
2.001	S2	63	112.688	-0.327	0.000	0.04	12.3	OK
2.002	S3	63	111.510	-0.395	0.000	0.04	14.0	OK
1.004	S8	63	111.099	-0.351	0.000	0.11	21.6	OK
1.005	S9	63	110.928	-0.381	0.000	0.06	25.4	OK
1.006	S10	63	110.227	-0.392	0.000	0.04	25.9	OK
1.007	S11	63	108.766	-0.534	0.000	0.03	31.1	OK
1.008	S12	63	107.054	-0.496	0.000	0.07	34.1	OK
3.000	S13	63	110.613	-0.212	0.000	0.01	1.1	OK
3.001	S14	63	109.495	-0.270	0.000	0.02	3.7	OK
3.002	S15	63	108.788	-0.272	0.000	0.02	4.9	OK

©1982-2019 Innovyze

PJS Consulting Engineers Limited		Page 24
Unit 4 Winking Hill Farm Kingston-on-Soar, Nottingham Nottinghamshire NG11 0DP		
Lutterworth Road Burbage		
Date 29/06/2023 13:54 File SW Model 17.05.23.mdx		
Designed by matt.leask Checked by		
Innovyze		Network 2019.1

Summary Wizard of 720 minute 1 year Summer I+0% for Surface Water Network

Simulation Criteria

Areal Reduction Factor	1.000	Additional Flow - % of Total Flow	0.000
Hot Start (mins)	0	MADD Factor * 10m³/ha Storage	0.000
Hot Start Level (mm)	0	Inlet Coefficient	0.800
Manhole Headloss Coeff (Global)	0.500	Flow per Person per Day (l/per/day)	0.000
Foul Sewage per hectare (l/s)	0.000		

Number of Input Hydrographs 0 Number of Offline Controls 5 Number of Time/Area Diagrams 0
Number of Online Controls 3 Number of Storage Structures 2 Number of Real Time Controls 0

Synthetic Rainfall Details

Rainfall Model	FSR	Ratio R	0.401
Region	England and Wales	Cv (Summer)	0.750
M5-60 (mm)	19.600	Cv (Winter)	0.840

Margin for Flood Risk Warning (mm) 300.0
Analysis Timestep 2.5 Second Increment (Extended)
DTS Status OFF
DVD Status OFF
Inertia Status OFF

Profile(s) Summer and Winter
Duration(s) (mins) 15, 30, 60, 120, 180, 240, 360, 480, 600, 720, 960, 1440
Return Period(s) (years) 1, 30, 100
Climate Change (%) 0, 0, 40

PN	US/MH Name	Storm Rank	Water	Surcharged	Flooded	Pipe		Status
			Level (m)	Depth (m)	Volume (m³)	Flow / Overflow (l/s)	Flow (l/s)	
1.000	S4	64	113.874	-0.201	0.000	0.02	1.9	OK
1.001	S5	64	112.673	-0.202	0.000	0.02	2.1	OK
1.002	S6	64	111.960	-0.185	0.000	0.07	2.7	OK
1.003	S7	64	111.669	-0.346	0.000	0.02	4.9	OK
2.000	S1	64	113.346	-0.329	0.000	0.04	8.3	OK
2.001	S2	64	112.685	-0.330	0.000	0.04	10.7	OK
2.002	S3	64	111.507	-0.398	0.000	0.03	12.3	OK
1.004	S8	64	111.094	-0.356	0.000	0.10	18.9	OK
1.005	S9	64	110.924	-0.385	0.000	0.05	22.2	OK
1.006	S10	64	110.223	-0.396	0.000	0.04	22.7	OK
1.007	S11	64	108.763	-0.537	0.000	0.02	27.2	OK
1.008	S12	64	107.046	-0.504	0.000	0.06	29.8	OK
3.000	S13	64	110.611	-0.214	0.000	0.01	1.0	OK
3.001	S14	64	109.491	-0.274	0.000	0.02	3.3	OK
3.002	S15	64	108.784	-0.276	0.000	0.02	4.3	OK

©1982-2019 Innovyze

PJS Consulting Engineers Limited

Unit 4 Winking Hill Farm
Kingston-on-Soar, Nottingham
Nottinghamshire NG11 0DP

Date 29/06/2023 13:54
File SW Model 17.05.23.mdx

Innovyze

Lutterworth Road
Burbage

Designed by matt.leask
Checked by

Network 2019.1

Page 26



Summary Wizard of 960 minute 1 year Summer I+0% for Surface Water Network

Simulation Criteria

Areal Reduction Factor 1.000

Hot Start (mins) 0

Hot Start Level (mm) 0

Manhole Headloss Coeff (Global) 0.500

Foul Sewage per hectare (l/s) 0.000

Additional Flow - % of Total Flow 0.000

MADD Factor * 10m³/ha Storage 0.000

Inlet Coeffiecient 0.800

Flow per Person per Day (l/per/day) 0.000

Number of Input Hydrographs 0

Number of Offline Controls 5

Number of Time/Area Diagrams 0

Number of Online Controls 3

Number of Storage Structures 2

Number of Real Time Controls 0

Synthetic Rainfall Details

Rainfall Model FSR

Region England and Wales Cv (Summer) 0.750

M5-60 (mm) 19.600 Cv (Winter) 0.840

Ratio R 0.401

Margin for Flood Risk Warning (mm) 300.0

Analysis Timestep 2.5 Second Increment (Extended)

DTS Status OFF

DVD Status OFF

Inertia Status OFF

Profile(s) Summer and Winter

Duration(s) (mins) 15, 30, 60, 120, 180, 240, 360, 480, 600, 720, 960, 1440

Return Period(s) (years) 1, 30, 100

Climate Change (%) 0, 0, 40

PN	US/MH Name	Storm Rank	Water	Surcharged	Flooded	Flow / Cap.	Overflow	Pipe	Status
			Level (m)	Depth (m)	Volume (m³)		(l/s)	Flow (l/s)	
1.000	S4	68	113.871	-0.204	0.000	0.02	1.5	OK	
1.001	S5	68	112.670	-0.205	0.000	0.02	1.7	OK	
1.002	S6	68	111.955	-0.190	0.000	0.06	2.2	OK	
1.003	S7	68	111.664	-0.351	0.000	0.01	4.0	OK	
2.000	S1	68	113.342	-0.333	0.000	0.03	6.7	OK	
2.001	S2	68	112.682	-0.333	0.000	0.03	8.7	OK	
2.002	S3	68	111.503	-0.402	0.000	0.03	9.9	OK	
1.004	S8	68	111.083	-0.367	0.000	0.08	15.3	OK	
1.005	S9	68	110.917	-0.392	0.000	0.04	18.0	OK	
1.006	S10	68	110.219	-0.400	0.000	0.03	18.4	OK	
1.007	S11	68	108.757	-0.543	0.000	0.02	22.1	OK	
1.008	S12	68	107.035	-0.515	0.000	0.05	24.2	OK	
3.000	S13	68	110.609	-0.216	0.000	0.01	0.8	OK	
3.001	S14	68	109.486	-0.279	0.000	0.02	2.7	OK	
3.002	S15	68	108.780	-0.280	0.000	0.01	3.5	OK	

©1982-2019 Innovyze

PJS Consulting Engineers Limited

Unit 4 Winking Hill Farm

Kingston-on-Soar, Nottingham

Nottinghamshire NG11 0DP

Date 29/06/2023 13:54

File SW Model 17.05.23.mdx

Lutterworth Road

Burbage

Designed by matt.leask

Checked by

Innovyze

Network 2019.1

Page 28



Summary Wizard of 1440 minute 1 year Summer I+0% for Surface Water Network

Simulation Criteria

Areal Reduction Factor 1.000

Hot Start (mins) 0

Hot Start Level (mm) 0

Manhole Headloss Coeff (Global) 0.500

Foul Sewage per hectare (l/s) 0.000

Additional Flow - % of Total Flow 0.000

MADD Factor * 10m³/ha Storage 0.000

Inlet Coeffiecient 0.800

Flow per Person per Day (l/per/day) 0.000

Number of Input Hydrographs 0

Number of Offline Controls 5

Number of Time/Area Diagrams 0

Number of Online Controls 3

Number of Storage Structures 2

Number of Real Time Controls 0

Synthetic Rainfall Details

Rainfall Model FSR

Region England and Wales Cv (Summer) 0.750

M5-60 (mm) 19.600 Cv (Winter) 0.840

Ratio R 0.401

Margin for Flood Risk Warning (mm) 300.0

Analysis Timestep 2.5 Second Increment (Extended)

DTS Status OFF

DVD Status OFF

Inertia Status OFF

Profile(s) Summer and Winter


Duration(s) (mins) 15, 30, 60, 120, 180, 240, 360, 480, 600, 720, 960, 1440

Return Period(s) (years) 1, 30, 100

Climate Change (%) 0, 0, 40

PN	US/MH Name	Storm Rank	Water	Surcharged	Flooded	Flow / Cap.	Overflow	Pipe	Status
			Level (m)	Depth (m)	Volume (m³)		(l/s)	Flow (l/s)	
1.000	S4	70	113.866	-0.209	0.000	0.01	1.1	OK	
1.001	S5	70	112.665	-0.210	0.000	0.01	1.3	OK	
1.002	S6	70	111.950	-0.195	0.000	0.04	1.6	OK	
1.003	S7	70	111.658	-0.357	0.000	0.01	2.9	OK	
2.000	S1	70	113.338	-0.337	0.000	0.02	5.0	OK	
2.001	S2	70	112.678	-0.337	0.000	0.02	6.5	OK	
2.002	S3	70	111.496	-0.409	0.000	0.02	7.4	OK	
1.004	S8	70	111.070	-0.380	0.000	0.06	11.4	OK	
1.005	S9	70	110.910	-0.399	0.000	0.03	13.4	OK	
1.006	S10	70	110.214	-0.405	0.000	0.02	13.7	OK	
1.007	S11	70	108.742	-0.558	0.000	0.01	16.4	OK	
1.008	S12	70	107.024	-0.526	0.000	0.04	18.0	OK	
3.000	S13	70	110.607	-0.218	0.000	0.01	0.6	OK	
3.001	S14	70	109.481	-0.284	0.000	0.01	2.0	OK	
3.002	S15	70	108.775	-0.285	0.000	0.01	2.6	OK	

©1982-2019 Innovyze

PJS Consulting Engineers Limited		Page 30
Unit 4 Winking Hill Farm Kingston-on-Soar, Nottingham Nottinghamshire NG11 0DP		
Lutterworth Road Burbage		
Date 29/06/2023 13:54 File SW Model 17.05.23.mdx		
Designed by matt.leask Checked by		
Innovyze		Network 2019.1

Summary Wizard of 15 minute 30 year Summer I+0% for Surface Water Network

Simulation Criteria

Areal Reduction Factor	1.000	Additional Flow - % of Total Flow	0.000
Hot Start (mins)	0	MADD Factor * 10m³/ha Storage	0.000
Hot Start Level (mm)	0	Inlet Coefficient	0.800
Manhole Headloss Coeff (Global)	0.500	Flow per Person per Day (l/per/day)	0.000
Foul Sewage per hectare (l/s)	0.000		

Number of Input Hydrographs	0	Number of Offline Controls	5	Number of Time/Area Diagrams	0
Number of Online Controls	3	Number of Storage Structures	2	Number of Real Time Controls	0

Synthetic Rainfall Details

Rainfall Model	FSR	Ratio R	0.401
Region	England and Wales	Cv (Summer)	0.750
M5-60 (mm)	19.600	Cv (Winter)	0.840


Margin for Flood Risk Warning (mm)	300.0
Analysis Timestep	2.5 Second Increment (Extended)
DTS Status	OFF
DVD Status	OFF
Inertia Status	OFF

Profile(s)	Summer and Winter
Duration(s) (mins)	15, 30, 60, 120, 180, 240, 360, 480, 600, 720, 960, 1440
Return Period(s) (years)	1, 30, 100
Climate Change (%)	0, 0, 40

PN	US/MH Name	Storm Rank	Water Level (m)	Surcharged Depth (m)	Flooded Volume (m³)	Flow / Overflow Cap.	Pipe Flow (l/s)	Status
1.000	S4	7	113.955	-0.120	0.000	0.44	33.7	OK
1.001	S5	7	112.752	-0.123	0.000	0.42	38.0	OK
1.002	S6	7	112.246	0.101	0.000	1.35	48.9	SURCHARGED
1.003	S7	7	111.789	-0.226	0.000	0.31	91.1	OK
2.000	S1	7	113.526	-0.149	0.000	0.66	149.4	OK
2.001	S2	7	112.865	-0.150	0.000	0.65	197.8	OK
2.002	S3	7	111.911	0.006	0.000	0.59	224.8	SURCHARGED
1.004	S8	7	111.746	0.296	0.000	1.78	346.6	SURCHARGED
1.005	S9	7	111.200	-0.109	0.000	0.92	403.9	OK
1.006	S10	7	110.431	-0.188	0.000	0.63	411.0	OK
1.007	S11	7	108.982	-0.318	0.000	0.44	488.6	OK
1.008	S12	8	108.211	0.661	0.000	1.04	504.2	SURCHARGED
3.000	S13	7	110.667	-0.158	0.000	0.19	17.6	OK
3.001	S14	7	109.591	-0.174	0.000	0.37	64.7	OK
3.002	S15	7	108.881	-0.179	0.000	0.34	84.7	OK

©1982-2019 Innovyze

PJS Consulting Engineers Limited							Page 32		
Unit 4 Winking Hill Farm Kingston-on-Soar, Nottingham Nottinghamshire NG11 0DP				Lutterworth Road Burbage					
Date 29/06/2023 13:54				Designed by matt.leask					
File SW Model 17.05.23.mdx				Checked by					
Innovyze				Network 2019.1					
<u>Summary Wizard of 30 minute 30 year Summer I+0% for Surface Water Network</u>									
<u>Simulation Criteria</u>									
Areal Reduction Factor		1.000		Additional Flow - % of Total Flow		0.000			
Hot Start (mins)		0		MADD Factor * 10m³/ha Storage		0.000			
Hot Start Level (mm)		0		Inlet Coefficient		0.800			
Manhole Headloss Coeff (Global)		0.500		Flow per Person per Day (l/per/day)		0.000			
Foul Sewage per hectare (l/s)		0.000							
Number of Input Hydrographs		0		Number of Offline Controls		5		Number of Time/Area Diagrams	0
Number of Online Controls		3		Number of Storage Structures		2		Number of Real Time Controls	0
<u>Synthetic Rainfall Details</u>									
Rainfall Model		FSR		Ratio R		0.401			
Region		England and Wales		Cv (Summer)		0.750			
M5-60 (mm)		19.600		Cv (Winter)		0.840			
Margin for Flood Risk Warning (mm)						300.0			
Analysis Timestep		2.5		Second Increment (Extended)					
DTS Status						OFF			
DVD Status						OFF			
Inertia Status						OFF			
Profile(s)						Summer and Winter			
Duration(s) (mins)		15, 30, 60, 120, 180, 240, 360, 480, 600, 720, 960, 1440							
Return Period(s) (years)						1, 30, 100			
Climate Change (%)						0, 0, 40			

PJS Consulting Engineers Limited		Page 34
Unit 4 Winking Hill Farm Kingston-on-Soar, Nottingham Nottinghamshire NG11 0DP		
Lutterworth Road Burbage		
Date 29/06/2023 13:54 File SW Model 17.05.23.mdx		
Designed by matt.leask Checked by		
Innovyze	Network 2019.1	

Summary Wizard of 60 minute 30 year Summer I+0% for Surface Water Network

Simulation Criteria

Areal Reduction Factor	1.000	Additional Flow - % of Total Flow	0.000
Hot Start (mins)	0	MADD Factor * 10m³/ha Storage	0.000
Hot Start Level (mm)	0	Inlet Coefficient	0.800
Manhole Headloss Coeff (Global)	0.500	Flow per Person per Day (l/per/day)	0.000
Foul Sewage per hectare (l/s)	0.000		

Number of Input Hydrographs	0	Number of Offline Controls	5	Number of Time/Area Diagrams	0
Number of Online Controls	3	Number of Storage Structures	2	Number of Real Time Controls	0

Synthetic Rainfall Details


Rainfall Model	FSR	Ratio R	0.401
Region	England and Wales	Cv (Summer)	0.750
M5-60 (mm)	19.600	Cv (Winter)	0.840

Margin for Flood Risk Warning (mm)	300.0
Analysis Timestep	2.5 Second Increment (Extended)
DTS Status	OFF
DVD Status	OFF
Inertia Status	OFF

Profile(s)	Summer and Winter
Duration(s) (mins)	15, 30, 60, 120, 180, 240, 360, 480, 600, 720, 960, 1440
Return Period(s) (years)	1, 30, 100
Climate Change (%)	0, 0, 40

PN	US/MH Name	Storm Rank	Water	Surcharged	Flooded	Flow / Cap.	Overflow	Pipe	Status
			Level (m)	Depth (m)	Volume (m³)		(l/s)	Flow (l/s)	
1.000	S4	12	113.933	-0.142	0.000	0.29	22.8		OK
1.001	S5	12	112.731	-0.144	0.000	0.28	25.6		OK
1.002	S6	12	112.087	-0.058	0.000	0.90	32.5		OK
1.003	S7	12	111.755	-0.260	0.000	0.20	59.9		OK
2.000	S1	12	113.475	-0.200	0.000	0.45	100.7		OK
2.001	S2	12	112.813	-0.202	0.000	0.43	131.0		OK
2.002	S3	12	111.652	-0.253	0.000	0.39	149.9		OK
1.004	S8	12	111.485	0.035	0.000	1.18	230.1	SURCHARGED	
1.005	S9	12	111.115	-0.194	0.000	0.61	269.0		OK
1.006	S10	12	110.374	-0.245	0.000	0.42	274.3		OK
1.007	S11	12	108.924	-0.376	0.000	0.29	326.7		OK
1.008	S12	12	107.578	0.028	0.000	0.73	356.2	SURCHARGED	
3.000	S13	12	110.654	-0.171	0.000	0.13	11.7		OK
3.001	S14	12	109.563	-0.202	0.000	0.23	40.7		OK
3.002	S15	12	108.854	-0.206	0.000	0.21	52.8		OK

©1982-2019 Innovyze

PJS Consulting Engineers Limited		Page 36
Unit 4 Winking Hill Farm Kingston-on-Soar, Nottingham Nottinghamshire NG11 ODP		
Lutterworth Road Burbage		
Date 29/06/2023 13:54 File SW Model 17.05.23.mdx		
Designed by matt.leask Checked by		
Innovyze		Network 2019.1

Summary Wizard of 120 minute 30 year Summer I+0% for Surface Water Network

Simulation Criteria

Areal Reduction Factor	1.000	Additional Flow - % of Total Flow	0.000
Hot Start (mins)	0	MADD Factor * 10m³/ha Storage	0.000
Hot Start Level (mm)	0	Inlet Coefficient	0.800
Manhole Headloss Coeff (Global)	0.500	Flow per Person per Day (l/per/day)	0.000
Foul Sewage per hectare (l/s)	0.000		

Number of Input Hydrographs 0 Number of Offline Controls 5 Number of Time/Area Diagrams 0
Number of Online Controls 3 Number of Storage Structures 2 Number of Real Time Controls 0

Synthetic Rainfall Details

Rainfall Model	FSR	Ratio R	0.401
Region	England and Wales	Cv (Summer)	0.750
M5-60 (mm)	19.600	Cv (Winter)	0.840

Margin for Flood Risk Warning (mm) 300.0
Analysis Timestep 2.5 Second Increment (Extended)
DTS Status OFF
DVD Status OFF
Inertia Status OFF

Profile(s) Summer and Winter
Duration(s) (mins) 15, 30, 60, 120, 180, 240, 360, 480, 600, 720, 960, 1440
Return Period(s) (years) 1, 30, 100
Climate Change (%) 0, 0, 40

PN	US/MH Name	Storm Rank	Water	Surcharged	Flooded	Pipe		Status
			Level (m)	Depth (m)	Volume (m³)	Flow / Overflow (l/s)	Flow (l/s)	
1.000	S4	18	113.917	-0.158	0.000	0.19	15.1	OK
1.001	S5	18	112.715	-0.160	0.000	0.18	16.9	OK
1.002	S6	18	112.045	-0.100	0.000	0.59	21.4	OK
1.003	S7	18	111.731	-0.284	0.000	0.13	39.4	OK
2.000	S1	18	113.438	-0.237	0.000	0.29	66.5	OK
2.001	S2	18	112.776	-0.239	0.000	0.29	86.4	OK
2.002	S3	18	111.610	-0.295	0.000	0.26	98.7	OK
1.004	S8	18	111.301	-0.149	0.000	0.78	152.2	OK
1.005	S9	18	111.058	-0.251	0.000	0.41	178.4	OK
1.006	S10	18	110.331	-0.288	0.000	0.28	181.7	OK
1.007	S11	18	108.880	-0.420	0.000	0.20	217.9	OK
1.008	S12	24	107.367	-0.183	0.000	0.49	238.1	OK
3.000	S13	18	110.644	-0.181	0.000	0.09	7.8	OK
3.001	S14	18	109.543	-0.222	0.000	0.15	26.6	OK
3.002	S15	18	108.834	-0.226	0.000	0.14	34.5	OK

©1982-2019 Innovyze

PJS Consulting Engineers Limited

Unit 4 Winking Hill Farm

Kingston-on-Soar, Nottingham

Nottinghamshire NG11 0DP

Date 29/06/2023 13:54

File SW Model 17.05.23.mdx

Lutterworth Road

Burbage

Designed by matt.leask

Checked by

Innovyze

Network 2019.1

Page 38



Summary Wizard of 180 minute 30 year Summer I+0% for Surface Water Network

Simulation Criteria

Areal Reduction Factor 1.000

Hot Start (mins) 0

Hot Start Level (mm) 0

Manhole Headloss Coeff (Global) 0.500

Foul Sewage per hectare (l/s) 0.000

Additional Flow - % of Total Flow 0.000

MADD Factor * 10m³/ha Storage 0.000

Inlet Coeffiecient 0.800

Flow per Person per Day (l/per/day) 0.000

Number of Input Hydrographs 0

Number of Offline Controls 5

Number of Time/Area Diagrams 0

Number of Online Controls 3

Number of Storage Structures 2

Number of Real Time Controls 0

Synthetic Rainfall Details

Rainfall Model FSR

Region England and Wales Cv (Summer) 0.750

M5-60 (mm) 19.600 Cv (Winter) 0.840

Ratio R 0.401

Analysis Timestep 2.5 Second Increment (Extended)

DTS Status OFF

DVD Status OFF

Inertia Status OFF

Margin for Flood Risk Warning (mm) 300.0

Profile(s) Summer and Winter

Duration(s) (mins) 15, 30, 60, 120, 180, 240, 360, 480, 600, 720, 960, 1440

Return Period(s) (years) 1, 30, 100

Climate Change (%) 0, 0, 40

PN

US/MH Name

Storm Rank

Water Level (m)

Surcharged Depth (m)

Flooded Volume (m³)

Flow / Cap.

Overflow (l/s)

Pipe Flow (l/s)

Status

1.000

S4

24

113.907

-0.168

0.000

0.15

11.5

OK

1.001

S5

24

112.706

-0.169

0.000

0.14

12.9

OK

1.002

S6

24

112.026

-0.119

0.000

0.45

16.3

OK

1.003

S7

24

111.720

-0.295

0.000

0.10

29.9

OK

2.000

S1

24

113.420

-0.255

0.000

0.22

50.6

OK

2.001

S2

24

112.758

-0.257

0.000

0.22

65.6

OK

2.002

S3

24

111.590

-0.315

0.000

0.20

75.0

OK

1.004

S8

24

111.250

-0.200

0.000

0.59

115.7

OK

1.005

S9

24

111.030

-0.279

0.000

0.31

135.6

OK

1.006

S10

24

110.310

-0.309

0.000

0.21

138.2

OK

1.007

S11

23

108.854

-0.446

0.000

0.15

165.7

OK

1.008

S12

35

107.217

-0.333

0.000

0.37

181.1

OK

3.000

S13

24

110.637

-0.188

0.000

0.07

5.9

OK

3.001

S14

23

109.532

-0.233

0.000

0.11

20.2

OK

3.002

S15

23

108.825

-0.235


0.000

0.11

26.2

OK

©1982-2019 Innovyze

PJS Consulting Engineers Limited		Page 40
Unit 4 Winking Hill Farm Kingston-on-Soar, Nottingham Nottinghamshire NG11 0DP		
Lutterworth Road Burbage		
Date 29/06/2023 13:54 File SW Model 17.05.23.mdx		
Designed by matt.leask Checked by		
Innovyze	Network 2019.1	

Summary Wizard of 240 minute 30 year Summer I+0% for Surface Water Network

Simulation Criteria

Areal Reduction Factor 1.000	Additional Flow - % of Total Flow 0.000
Hot Start (mins) 0	MADD Factor * 10m³/ha Storage 0.000
Hot Start Level (mm) 0	Inlet Coefficient 0.800
Manhole Headloss Coeff (Global) 0.500	Flow per Person per Day (l/per/day) 0.000
Foul Sewage per hectare (l/s) 0.000	

Number of Input Hydrographs 0	Number of Offline Controls 5	Number of Time/Area Diagrams 0
Number of Online Controls 3	Number of Storage Structures 2	Number of Real Time Controls 0

Synthetic Rainfall Details

Rainfall Model	FSR	Ratio R 0.401
Region England and Wales Cv (Summer)	0.750	
M5-60 (mm)	19.600	Cv (Winter) 0.840

Margin for Flood Risk Warning (mm)	300.0
Analysis Timestep 2.5 Second Increment (Extended)	
DTS Status	OFF
DVD Status	OFF
Inertia Status	OFF

Profile(s)	Summer and Winter
Duration(s) (mins)	15, 30, 60, 120, 180, 240, 360, 480, 600, 720, 960, 1440
Return Period(s) (years)	1, 30, 100
Climate Change (%)	0, 0, 40

PN	US/MH Name	Storm Rank	Water	Surcharged	Flooded	Pipe		Status
			Level (m)	Depth (m)	Volume (m³)	Flow / Overflow (l/s)	Flow (l/s)	
1.000	S4	29	113.902	-0.173	0.000	0.12	9.3	OK
1.001	S5	29	112.700	-0.175	0.000	0.11	10.5	OK
1.002	S6	28	112.014	-0.131	0.000	0.37	13.2	OK
1.003	S7	28	111.712	-0.303	0.000	0.08	24.3	OK
2.000	S1	29	113.407	-0.268	0.000	0.18	41.1	OK
2.001	S2	28	112.746	-0.269	0.000	0.18	53.3	OK
2.002	S3	28	111.575	-0.330	0.000	0.16	60.9	OK
1.004	S8	28	111.220	-0.230	0.000	0.48	94.0	OK
1.005	S9	28	111.011	-0.298	0.000	0.25	110.2	OK
1.006	S10	28	110.295	-0.324	0.000	0.17	112.4	OK
1.007	S11	28	108.839	-0.461	0.000	0.12	134.8	OK
1.008	S12	38	107.176	-0.374	0.000	0.30	147.5	OK
3.000	S13	29	110.633	-0.192	0.000	0.05	4.8	OK
3.001	S14	28	109.526	-0.239	0.000	0.09	16.4	OK
3.002	S15	28	108.819	-0.241	0.000	0.09	21.2	OK

©1982-2019 Innovyze

PJS Consulting Engineers Limited		Page 42
Unit 4 Winking Hill Farm Kingston-on-Soar, Nottingham Nottinghamshire NG11 0DP	Lutterworth Road Burbage	
Date 29/06/2023 13:54 File SW Model 17.05.23.mdx	Designed by matt.leask Checked by	
Innovyze Network 2019.1		

Summary Wizard of 360 minute 30 year Summer I+0% for Surface Water Network

Simulation Criteria

Areal Reduction Factor 1.000 Additional Flow - % of Total Flow 0.000
 Hot Start (mins) 0 MADD Factor * 10m³/ha Storage 0.000
 Hot Start Level (mm) 0 Inlet Coefficient 0.800
 Manhole Headloss Coeff (Global) 0.500 Flow per Person per Day (l/per/day) 0.000
 Foul Sewage per hectare (l/s) 0.000

Number of Input Hydrographs 0 Number of Offline Controls 5 Number of Time/Area Diagrams 0
 Number of Online Controls 3 Number of Storage Structures 2 Number of Real Time Controls 0

Synthetic Rainfall Details


Rainfall Model FSR Ratio R 0.401
 Region England and Wales Cv (Summer) 0.750
 M5-60 (mm) 19.600 Cv (Winter) 0.840

Margin for Flood Risk Warning (mm) 300.0
 Analysis Timestep 2.5 Second Increment (Extended)
 DTS Status OFF
 DVD Status OFF
 Inertia Status OFF

Profile(s) Summer and Winter
 Duration(s) (mins) 15, 30, 60, 120, 180, 240, 360, 480, 600, 720, 960, 1440
 Return Period(s) (years) 1, 30, 100
 Climate Change (%) 0, 0, 40

PN	US/MH Name	Storm Rank	Water Level (m)	Surcharged Depth (m)	Flooded Volume (m³)	Pipe		Status
						Flow / Cap. (l/s)	Overflow (l/s)	
1.000	S4	36	113.895	-0.180	0.000	0.09	6.9	OK
1.001	S5	36	112.694	-0.181	0.000	0.08	7.7	OK
1.002	S6	36	111.999	-0.146	0.000	0.27	9.8	OK
1.003	S7	36	111.700	-0.315	0.000	0.06	17.9	OK
2.000	S1	36	113.391	-0.284	0.000	0.13	30.4	OK
2.001	S2	36	112.729	-0.286	0.000	0.13	39.4	OK
2.002	S3	36	111.557	-0.348	0.000	0.12	45.0	OK
1.004	S8	36	111.185	-0.265	0.000	0.36	69.4	OK
1.005	S9	36	110.989	-0.320	0.000	0.19	81.5	OK
1.006	S10	36	110.276	-0.343	0.000	0.13	83.1	OK
1.007	S11	36	108.821	-0.479	0.000	0.09	99.7	OK
1.008	S12	42	107.142	-0.408	0.000	0.22	109.2	OK
3.000	S13	36	110.628	-0.197	0.000	0.04	3.5	OK
3.001	S14	36	109.516	-0.249	0.000	0.07	12.0	OK
3.002	S15	36	108.809	-0.251	0.000	0.06	15.6	OK

©1982-2019 Innovyze

PJS Consulting Engineers Limited		Page 44
Unit 4 Winking Hill Farm Kingston-on-Soar, Nottingham Nottinghamshire NG11 0DP		
Lutterworth Road Burbage		
Date 29/06/2023 13:54 File SW Model 17.05.23.mdx		
Designed by matt.leask Checked by		
Innovyze		Network 2019.1

Summary Wizard of 480 minute 30 year Summer I+0% for Surface Water Network

Simulation Criteria

Areal Reduction Factor	1.000	Additional Flow - % of Total Flow	0.000
Hot Start (mins)	0	MADD Factor * 10m³/ha Storage	0.000
Hot Start Level (mm)	0	Inlet Coefficient	0.800
Manhole Headloss Coeff (Global)	0.500	Flow per Person per Day (l/per/day)	0.000
Foul Sewage per hectare (l/s)	0.000		

Number of Input Hydrographs 0 Number of Offline Controls 5 Number of Time/Area Diagrams 0
Number of Online Controls 3 Number of Storage Structures 2 Number of Real Time Controls 0

Synthetic Rainfall Details


Rainfall Model	FSR	Ratio R	0.401
Region	England and Wales	Cv (Summer)	0.750
M5-60 (mm)	19.600	Cv (Winter)	0.840

Margin for Flood Risk Warning (mm) 300.0
Analysis Timestep 2.5 Second Increment (Extended)
DTS Status OFF
DVD Status OFF
Inertia Status OFF

Profile(s) Summer and Winter
Duration(s) (mins) 15, 30, 60, 120, 180, 240, 360, 480, 600, 720, 960, 1440
Return Period(s) (years) 1, 30, 100
Climate Change (%) 0, 0, 40

PN	US/MH Name	Storm Rank	Water	Surcharged	Flooded	Pipe		Status
			Level (m)	Depth (m)	Volume (m³)	Flow / Overflow (l/s)	Flow (l/s)	
1.000	S4	41	113.889	-0.186	0.000	0.07	5.5	OK
1.001	S5	41	112.688	-0.187	0.000	0.07	6.2	OK
1.002	S6	41	111.991	-0.154	0.000	0.22	7.8	OK
1.003	S7	41	111.693	-0.322	0.000	0.05	14.4	OK
2.000	S1	41	113.382	-0.293	0.000	0.11	24.3	OK
2.001	S2	41	112.720	-0.295	0.000	0.10	31.5	OK
2.002	S3	41	111.548	-0.357	0.000	0.09	36.0	OK
1.004	S8	41	111.163	-0.287	0.000	0.29	55.6	OK
1.005	S9	41	110.974	-0.335	0.000	0.15	65.3	OK
1.006	S10	41	110.265	-0.354	0.000	0.10	66.6	OK
1.007	S11	41	108.805	-0.495	0.000	0.07	79.9	OK
1.008	S12	45	107.121	-0.429	0.000	0.18	87.6	OK
3.000	S13	41	110.626	-0.199	0.000	0.03	2.8	OK
3.001	S14	41	109.510	-0.255	0.000	0.05	9.6	OK
3.002	S15	41	108.803	-0.257	0.000	0.05	12.5	OK

©1982-2019 Innovyze

PJS Consulting Engineers Limited		Page 46
Unit 4 Winking Hill Farm Kingston-on-Soar, Nottingham Nottinghamshire NG11 0DP		
Lutterworth Road Burbage		
Date 29/06/2023 13:54 File SW Model 17.05.23.mdx		
Designed by matt.leask Checked by		
Innovyze		Network 2019.1

Summary Wizard of 600 minute 30 year Summer I+0% for Surface Water Network

Simulation Criteria

Areal Reduction Factor 1.000	Additional Flow - % of Total Flow 0.000
Hot Start (mins) 0	MADD Factor * 10m³/ha Storage 0.000
Hot Start Level (mm) 0	Inlet Coefficient 0.800
Manhole Headloss Coeff (Global) 0.500	Flow per Person per Day (l/per/day) 0.000
Foul Sewage per hectare (l/s) 0.000	

Number of Input Hydrographs 0 Number of Offline Controls 5 Number of Time/Area Diagrams 0
Number of Online Controls 3 Number of Storage Structures 2 Number of Real Time Controls 0

Synthetic Rainfall Details

Rainfall Model	FSR	Ratio R 0.401
Region England and Wales Cv (Summer)	0.750	
M5-60 (mm)	19.600	Cv (Winter) 0.840

Margin for Flood Risk Warning (mm) 300.0

Analysis Timestep 2.5 Second Increment (Extended)

DTS Status OFF
DVD Status OFF
Inertia Status OFF

Profile(s) Summer and Winter


Duration(s) (mins) 15, 30, 60, 120, 180, 240, 360, 480, 600, 720, 960, 1440

Return Period(s) (years) 1, 30, 100

Climate Change (%) 0, 0, 40

PN	US/MH Name	Storm Rank	Water	Surcharged	Flooded	Pipe		Status
			Level (m)	Depth (m)	Volume (m³)	Flow / Overflow (l/s)	Flow (l/s)	
1.000	S4	46	113.885	-0.190	0.000	0.06	4.6	OK
1.001	S5	46	112.684	-0.191	0.000	0.06	5.2	OK
1.002	S6	46	111.984	-0.161	0.000	0.18	6.6	OK
1.003	S7	46	111.689	-0.326	0.000	0.04	12.1	OK
2.000	S1	46	113.376	-0.299	0.000	0.09	20.4	OK
2.001	S2	46	112.715	-0.300	0.000	0.09	26.5	OK
2.002	S3	46	111.539	-0.366	0.000	0.08	30.2	OK
1.004	S8	46	111.149	-0.301	0.000	0.24	46.7	OK
1.005	S9	46	110.964	-0.345	0.000	0.12	54.9	OK
1.006	S10	46	110.258	-0.361	0.000	0.09	56.0	OK
1.007	S11	46	108.795	-0.505	0.000	0.06	67.2	OK
1.008	S12	49	107.105	-0.445	0.000	0.15	73.6	OK
3.000	S13	46	110.624	-0.201	0.000	0.03	2.4	OK
3.001	S14	46	109.506	-0.259	0.000	0.05	8.1	OK
3.002	S15	46	108.799	-0.261	0.000	0.04	10.5	OK

©1982-2019 Innovyze

PJS Consulting Engineers Limited		Page 48
Unit 4 Winking Hill Farm Kingston-on-Soar, Nottingham Nottinghamshire NG11 0DP		
Lutterworth Road Burbage		
Date 29/06/2023 13:54 File SW Model 17.05.23.mdx		
Designed by matt.leask Checked by		
Innovyze		Network 2019.1

Summary Wizard of 720 minute 30 year Summer I+0% for Surface Water Network

Simulation Criteria

Areal Reduction Factor	1.000	Additional Flow - % of Total Flow	0.000
Hot Start (mins)	0	MADD Factor * 10m³/ha Storage	0.000
Hot Start Level (mm)	0	Inlet Coefficient	0.800
Manhole Headloss Coeff (Global)	0.500	Flow per Person per Day (l/per/day)	0.000
Foul Sewage per hectare (l/s)	0.000		

Number of Input Hydrographs 0 Number of Offline Controls 5 Number of Time/Area Diagrams 0
Number of Online Controls 3 Number of Storage Structures 2 Number of Real Time Controls 0

Synthetic Rainfall Details

Rainfall Model	FSR	Ratio R	0.401
Region	England and Wales	Cv (Summer)	0.750
M5-60 (mm)	19.600	Cv (Winter)	0.840

Margin for Flood Risk Warning (mm) 300.0
Analysis Timestep 2.5 Second Increment (Extended)
DTS Status OFF
DVD Status OFF
Inertia Status OFF

Profile(s) Summer and Winter
Duration(s) (mins) 15, 30, 60, 120, 180, 240, 360, 480, 600, 720, 960, 1440
Return Period(s) (years) 1, 30, 100
Climate Change (%) 0, 0, 40

PN	US/MH Name	Storm Rank	Water	Surcharged	Flooded	Pipe		Status
			Level (m)	Depth (m)	Volume (m³)	Flow / Overflow (l/s)	Flow (l/s)	
1.000	S4	50	113.883	-0.192	0.000	0.05	4.0	OK
1.001	S5	50	112.682	-0.193	0.000	0.05	4.5	OK
1.002	S6	50	111.979	-0.166	0.000	0.16	5.7	OK
1.003	S7	50	111.686	-0.329	0.000	0.04	10.5	OK
2.000	S1	50	113.369	-0.306	0.000	0.08	17.7	OK
2.001	S2	50	112.708	-0.307	0.000	0.08	23.0	OK
2.002	S3	50	111.532	-0.373	0.000	0.07	26.2	OK
1.004	S8	50	111.138	-0.312	0.000	0.21	40.5	OK
1.005	S9	50	110.957	-0.352	0.000	0.11	47.6	OK
1.006	S10	50	110.250	-0.369	0.000	0.08	48.6	OK
1.007	S11	50	108.788	-0.512	0.000	0.05	58.3	OK
1.008	S12	51	107.094	-0.456	0.000	0.13	63.9	OK
3.000	S13	50	110.623	-0.202	0.000	0.02	2.1	OK
3.001	S14	50	109.503	-0.262	0.000	0.04	7.0	OK
3.002	S15	50	108.797	-0.263	0.000	0.04	9.1	OK

PJS Consulting Engineers Limited

Unit 4 Winking Hill Farm
Kingston-on-Soar, Nottingham
Nottinghamshire NG11 0DP

Date 29/06/2023 13:54
File SW Model 17.05.23.mdx

Innovyze

Lutterworth Road
Burbage

Designed by matt.leask
Checked by

Network 2019.1

Page 50



Summary Wizard of 960 minute 30 year Summer I+0% for Surface Water Network

Simulation Criteria

Areal Reduction Factor 1.000

Hot Start (mins) 0

Hot Start Level (mm) 0

Manhole Headloss Coeff (Global) 0.500

Foul Sewage per hectare (l/s) 0.000

Additional Flow - % of Total Flow 0.000

MADD Factor * 10m³/ha Storage 0.000

Inlet Coeffiecient 0.800

Flow per Person per Day (l/per/day) 0.000

Number of Input Hydrographs 0

Number of Offline Controls 5

Number of Online Controls 3

Number of Time/Area Diagrams 0

Number of Storage Structures 2

Number of Real Time Controls 0

Synthetic Rainfall Details

Rainfall Model FSR

Region England and Wales Cv (Summer) 0.750

M5-60 (mm) 19.600 Cv (Winter) 0.840

Ratio R 0.401

Analysis Timestep 2.5 Second Increment (Extended)

DTS Status OFF

DVD Status OFF

Inertia Status OFF

Profile(s) Summer and Winter

Duration(s) (mins) 15, 30, 60, 120, 180, 240, 360, 480, 600, 720, 960, 1440

Return Period(s) (years) 1, 30, 100

Climate Change (%) 0, 0, 40

Water

US/MH Storm

Level

Depth

Volume

Flow /

Overflow

Pipe

PN

Name

Rank

(m)

(m)

(m³)

Cap.

(l/s)

(l/s)

Status

Surcharged

Flooded

Flow

Flow

1.000

S4

54

113.879

-0.196

0.000

0.04

3.2

OK

1.001

S5

54

112.679

-0.196

0.000

0.04

3.6

OK

1.002

S6

54

111.973

-0.172

0.000

0.13

4.6

OK

1.003

S7

54

111.682

-0.333

0.000

0.03

8.4

OK

2.000

S1

54

113.361

-0.314

0.000

0.06

14.1

OK

2.001

S2

54

112.700

-0.315

0.000

0.06

18.3

OK

2.002

S3

54

111.523

-0.382

0.000

0.06

21.0

OK

1.004

S8

54

111.122

-0.328

0.000

0.17

32.4

OK

1.005

S9

54

110.948

-0.361

0.000

0.09

38.0

OK

1.006

S10

54

110.240

-0.379

0.000

0.06

38.8

OK

1.007

S11

54

108.779

-0.521

0.000

0.04

46.5

OK

1.008

S12

55

107.079

-0.471

0.000

0.10

51.0

OK

3.000

S13

54

110.619

-0.206

0.000

0.02

1.6

OK

3.001

S14

54

109.500

-0.265

0.000

0.03

5.6

OK

3.002

S15

54

108.794

-0.266


0.000

0.03

7.3

OK

©1982-2019 Innovyze

PJS Consulting Engineers Limited		Page 52
Unit 4 Winking Hill Farm Kingston-on-Soar, Nottingham Nottinghamshire NG11 0DP		
Lutterworth Road Burbage		
Date 29/06/2023 13:54 File SW Model 17.05.23.mdx		
Designed by matt.leask Checked by		
Innovyze		Network 2019.1

Summary Wizard of 1440 minute 30 year Summer I+0% for Surface Water Network

Simulation Criteria

Areal Reduction Factor	1.000	Additional Flow - % of Total Flow	0.000
Hot Start (mins)	0	MADD Factor * 10m³/ha Storage	0.000
Hot Start Level (mm)	0	Inlet Coefficient	0.800
Manhole Headloss Coeff (Global)	0.500	Flow per Person per Day (l/per/day)	0.000
Foul Sewage per hectare (l/s)	0.000		

Number of Input Hydrographs 0 Number of Offline Controls 5 Number of Time/Area Diagrams 0
Number of Online Controls 3 Number of Storage Structures 2 Number of Real Time Controls 0

Synthetic Rainfall Details

Rainfall Model	FSR	Ratio R	0.401
Region	England and Wales	Cv (Summer)	0.750
M5-60 (mm)	19.600	Cv (Winter)	0.840

Margin for Flood Risk Warning (mm) 300.0
Analysis Timestep 2.5 Second Increment (Extended)
DTS Status OFF
DVD Status OFF
Inertia Status OFF

Profile(s) Summer and Winter
Duration(s) (mins) 15, 30, 60, 120, 180, 240, 360, 480, 600, 720, 960, 1440
Return Period(s) (years) 1, 30, 100
Climate Change (%) 0, 0, 40

PN	US/MH Name	Storm Rank	Water	Surcharged	Flooded	Pipe		Status
			Level (m)	Depth (m)	Volume (m³)	Flow / Overflow (l/s)	Flow (l/s)	
1.000	S4	60	113.876	-0.199	0.000	0.03	2.3	OK
1.001	S5	60	112.675	-0.200	0.000	0.03	2.6	OK
1.002	S6	60	111.966	-0.179	0.000	0.09	3.3	OK
1.003	S7	60	111.677	-0.338	0.000	0.02	6.1	OK
2.000	S1	60	113.351	-0.324	0.000	0.05	10.3	OK
2.001	S2	60	112.690	-0.325	0.000	0.04	13.3	OK
2.002	S3	60	111.513	-0.392	0.000	0.04	15.2	OK
1.004	S8	60	111.103	-0.347	0.000	0.12	23.5	OK
1.005	S9	60	110.932	-0.377	0.000	0.06	27.6	OK
1.006	S10	60	110.229	-0.390	0.000	0.04	28.2	OK
1.007	S11	60	108.768	-0.532	0.000	0.03	33.9	OK
1.008	S12	60	107.059	-0.491	0.000	0.08	37.1	OK
3.000	S13	60	110.614	-0.211	0.000	0.01	1.2	OK
3.001	S14	60	109.496	-0.269	0.000	0.02	4.1	OK
3.002	S15	60	108.790	-0.270	0.000	0.02	5.3	OK

©1982-2019 Innovyze

PJS Consulting Engineers Limited		Page 57
Unit 4 Winking Hill Farm Kingston-on-Soar, Nottingham Nottinghamshire NG11 0DP	Lutterworth Road Burbage	
Date 29/06/2023 13:54 File SW Model 17.05.23.mdx	Designed by matt.leask Checked by	
Innovyze	Network 2019.1	

Summary Wizard of 30 minute 100 year Summer I+40% for Surface Water Network


PN	US/MH Name	Storm Rank	Water Level (m)	Surcharged Depth (m)	Flooded Volume (m³)	Flow / Cap.	Overflow (l/s)	Pipe Flow (l/s)	Status
1.009	S16	4	109.084	1.770	0.000	3.06		812.8	SURCHARGED
1.010	S17	3	108.464	1.221	0.000	3.80		816.7	SURCHARGED
1.011	S18	3	108.078	0.860	0.000	2.73		812.4	SURCHARGED
4.000	S38	3	111.727	-0.583	0.000	0.03		98.0	OK
4.001	S39	3	111.313	-0.547	0.000	0.05	10.5	89.0	OK
4.002	S40	3	111.310	-0.520	0.000	0.03	13.3	78.1	OK
4.003	S41	3	111.306	-0.234	0.000	0.01	29.3	29.3	FLOOD RISK
4.004	S42	3	109.227	-0.613	0.000	0.02	4.4	60.6	OK
4.005	S43	3	108.306	-0.344	0.000	0.00	24.8	24.8	OK
1.012	S32	3	107.728	0.554	0.000	1.52		852.6	FLOOD RISK
5.000	S22	3	112.381	0.386	0.000	0.96		63.5	SURCHARGED
5.001	S23	3	111.662	0.427	0.000	1.91		68.5	SURCHARGED
5.002	S24	3	111.473	0.303	0.000	1.73		170.2	SURCHARGED
5.003	S25	3	110.840	-0.175	0.000	0.55		188.9	OK
5.004	S26	3	110.005	0.180	0.000	0.50		242.7	SURCHARGED
5.005	S27	3	109.438	2.318	0.000	2.47		265.2	FLOOD RISK
5.006	S28	3	109.005	1.943	0.000	3.24		274.2	SURCHARGED
5.007	S29	4	108.522	1.503	0.000	2.13		280.3	SURCHARGED
5.008	S30	4	108.278	1.314	0.000	2.13		297.0	SURCHARGED
5.009	S31	3	107.923	1.040	0.000	2.31		337.0	SURCHARGED
1.013	S33	4	107.441	0.462	0.000	2.07		708.7	SURCHARGED
1.014	S34	22	107.128	0.199	0.000	1.65		708.4	SURCHARGED
1.015	S35	22	106.927	0.152	0.000	0.05		21.9	SURCHARGED
1.016	S36	42	106.188	-0.087	0.000	0.69		21.9	OK

PJS Consulting Engineers Limited				Page 58																						
Unit 4 Winking Hill Farm Kingston-on-Soar, Nottingham Nottinghamshire NG11 0DP				Lutterworth Road Burbage																						
Date 29/06/2023 13:54				Designed by matt.leask																						
File SW Model 17.05.23.mdx				Checked by																						
Innovyze				Network 2019.1																						
<u>Summary Wizard of 60 minute 100 year Summer I+40% for Surface Water Network</u>																										
<u>Simulation Criteria</u>																										
Areal Reduction Factor		1.000		Additional Flow - % of Total Flow		0.000																				
Hot Start (mins)		0		MADD Factor * 10m³/ha Storage		0.000																				
Hot Start Level (mm)		0		Inlet Coefficient		0.800																				
Manhole Headloss Coeff (Global)		0.500		Flow per Person per Day (l/per/day)		0.000																				
Foul Sewage per hectare (l/s)		0.000																								
Number of Input Hydrographs		0		Number of Offline Controls		5		Number of Time/Area Diagrams		0																
Number of Online Controls		3		Number of Storage Structures		2		Number of Real Time Controls		0																
<u>Synthetic Rainfall Details</u>																										
Rainfall Model		FSR		Ratio R		0.401																				
Region		England and Wales		Cv (Summer)		0.750																				
M5-60 (mm)		19.600		Cv (Winter)		0.840																				
Margin for Flood Risk Warning (mm)								300.0																		
Analysis Timestep		2.5		Second Increment (Extended)																						
DTS Status								OFF																		
DVD Status								OFF																		
Inertia Status								OFF																		
Profile(s)								Summer and Winter																		
Duration(s) (mins)		15, 30, 60, 120, 180, 240, 360, 480, 600, 720, 960, 1440																								
Return Period(s) (years)								1, 30, 100																		
Climate Change (%)								0, 0, 40																		
<table><tr><th rowspan="2">PN</th><th rowspan="2">US/MH Name</th><th rowspan="2">Storm Rank</th><th>Water</th><th>Surcharged</th><th>Flooded</th><th colspan="2">Pipe</th><th rowspan="2">Status</th><th rowspan="2"></th></tr><tr><th>Level (m)</th><th>Depth (m)</th><th>Volume (m³)</th><th>Flow / Cap.</th><th>Overflow (l/s)</th></tr></table>												PN	US/MH Name	Storm Rank	Water	Surcharged	Flooded	Pipe		Status		Level (m)	Depth (m)	Volume (m³)	Flow / Cap.	Overflow (l/s)
PN	US/MH Name	Storm Rank	Water	Surcharged	Flooded	Pipe		Status																		
			Level (m)	Depth (m)	Volume (m³)	Flow / Cap.	Overflow (l/s)																			
1.000	S4	5	113.968	-0.107	0.000	0.54	42.0	OK																		
1.001	S5	5	112.765	-0.110	0.000	0.52	47.1	OK																		
1.002	S6	5	112.385	0.240	0.000	1.62	58.4	SURCHARGED																		
1.003	S7	5	112.073	0.058	0.000	0.36	105.6	SURCHARGED																		
2.000	S1	5	113.559	-0.116	0.000	0.82	185.4	OK																		
2.001	S2	5	112.908	-0.107	0.000	0.79	240.1	OK																		
2.002	S3	5	112.238	0.333	0.000	0.70	266.6	SURCHARGED																		
1.004	S8	5	112.017	0.567	0.000	2.08	405.8	SURCHARGED																		
1.005	S9	5	111.404	0.095	0.000	1.08	473.5	SURCHARGED																		
1.006	S10	5	110.461	-0.158	0.000	0.75	482.7	OK																		
1.007	S11	5	109.427	0.127	0.000	0.51	561.2	SURCHARGED																		
1.008	S12	5	108.997	1.447	0.000	1.23	599.4	SURCHARGED																		
3.000	S13	5	110.674	-0.151	0.000	0.24	21.6	OK																		
3.001	S14	5	109.602	-0.163	0.000	0.43	74.8	OK																		
3.002	S15	5	108.891	-0.169	0.000	0.39	97.1	OK																		

©1982-2019 Innovyze

Summary Wizard of 60 minute 100 year Summer I+40% for Surface Water Network

			Water	Surcharged	Flooded	Pipe			
	US/MH	Storm	Level	Depth	Volume	Flow /	Overflow	Flow	
PN	Name	Rank	(m)	(m)	(m³)	Cap.	(l/s)	(l/s)	Status
1.009	S16	5	108.645	1.331	0.000	2.62		697.0	SURCHARGED
1.010	S17	5	108.182	0.939	0.000	3.26		702.3	SURCHARGED
1.011	S18	5	107.897	0.679	0.000	2.34		696.8	SURCHARGED
4.000	S38	5	111.710	-0.600	0.000	0.02		73.1	OK
4.001	S39	5	111.276	-0.584	0.000	0.04	6.7	66.3	OK
4.002	S40	5	111.257	-0.573	0.000	0.02	7.8	59.8	OK
4.003	S41	5	111.244	-0.296	0.000	0.01	26.9	26.9	FLOOD RISK
4.004	S42	5	109.219	-0.621	0.000	0.01	3.5	49.2	OK
4.005	S43	5	108.257	-0.393	0.000	0.00	22.6	22.6	OK
1.012	S32	5	107.634	0.460	0.000	1.32		738.5	FLOOD RISK
5.000	S22	5	111.916	-0.079	0.000	0.75		49.4	OK
5.001	S23	5	111.400	0.165	0.000	1.40		50.4	SURCHARGED
5.002	S24	5	111.278	0.108	0.000	1.33		131.4	SURCHARGED
5.003	S25	5	110.811	-0.204	0.000	0.43		145.2	OK
5.004	S26	5	109.614	-0.211	0.000	0.40		191.6	OK
5.005	S27	5	108.691	1.571	0.000	2.00		214.7	SURCHARGED
5.006	S28	5	108.409	1.347	0.000	2.66		225.1	SURCHARGED
5.007	S29	5	108.105	1.086	0.000	1.75		229.4	SURCHARGED
5.008	S30	5	107.952	0.988	0.000	1.75		243.7	SURCHARGED
5.009	S31	5	107.716	0.833	0.000	1.92		279.9	SURCHARGED
1.013	S33	9	107.390	0.411	0.000	1.98		679.2	SURCHARGED
1.014	S34	23	107.103	0.174	0.000	1.58		679.0	SURCHARGED
1.015	S35	20	107.073	0.298	0.000	0.05		21.9	SURCHARGED
1.016	S36	43	106.188	-0.087	0.000	0.69		21.9	OK

PJS Consulting Engineers Limited		Page 60
Unit 4 Winking Hill Farm Kingston-on-Soar, Nottingham Nottinghamshire NG11 ODP		
Lutterworth Road Burbage		
Date 29/06/2023 13:54 File SW Model 17.05.23.mdx		
Designed by matt.leask Checked by		
Innovyze		Network 2019.1

Summary Wizard of 120 minute 100 year Summer I+40% for Surface Water Network

Simulation Criteria

Areal Reduction Factor 1.000	Additional Flow - % of Total Flow 0.000
Hot Start (mins) 0	MADD Factor * 10m³/ha Storage 0.000
Hot Start Level (mm) 0	Inlet Coefficient 0.800
Manhole Headloss Coeff (Global) 0.500	Flow per Person per Day (l/per/day) 0.000
Foul Sewage per hectare (l/s) 0.000	

Number of Input Hydrographs 0 Number of Offline Controls 5 Number of Time/Area Diagrams 0
Number of Online Controls 3 Number of Storage Structures 2 Number of Real Time Controls 0

Synthetic Rainfall Details


Rainfall Model	FSR	Ratio R 0.401
Region England and Wales Cv (Summer)	0.750	
M5-60 (mm)	19.600 Cv (Winter)	0.840

Margin for Flood Risk Warning (mm) 300.0
Analysis Timestep 2.5 Second Increment (Extended)
DTS Status OFF
DVD Status OFF
Inertia Status OFF

Profile(s) Summer and Winter
Duration(s) (mins) 15, 30, 60, 120, 180, 240, 360, 480, 600, 720, 960, 1440
Return Period(s) (years) 1, 30, 100
Climate Change (%) 0, 0, 40

PN	US/MH Name	Storm Rank	Water Level (m)	Surcharged Depth (m)	Flooded Volume (m³)	Flow / Cap.	Overflow (l/s)	Pipe Flow (l/s)	Status
1.000	S4	11	113.943	-0.132	0.000	0.36		27.7	OK
1.001	S5	11	112.740	-0.135	0.000	0.34		31.1	OK
1.002	S6	11	112.158	0.013	0.000	1.09		39.3	SURCHARGED
1.003	S7	11	111.766	-0.249	0.000	0.25		72.4	OK
2.000	S1	11	113.497	-0.178	0.000	0.54		122.4	OK
2.001	S2	11	112.834	-0.181	0.000	0.53		158.9	OK
2.002	S3	11	111.682	-0.223	0.000	0.48		181.4	OK
1.004	S8	11	111.578	0.128	0.000	1.43		278.8	SURCHARGED
1.005	S9	11	111.150	-0.159	0.000	0.74		326.8	OK
1.006	S10	11	110.399	-0.220	0.000	0.52		333.9	OK
1.007	S11	10	108.949	-0.351	0.000	0.36		398.8	OK
1.008	S12	9	108.008	0.458	0.000	0.88		426.1	SURCHARGED
3.000	S13	11	110.659	-0.166	0.000	0.16		14.3	OK
3.001	S14	11	109.573	-0.192	0.000	0.28		48.9	OK
3.002	S15	11	108.863	-0.197	0.000	0.26		63.6	OK

©1982-2019 Innovyze

PJS Consulting Engineers Limited		Page 62
Unit 4 Winking Hill Farm Kingston-on-Soar, Nottingham Nottinghamshire NG11 ODP		
Lutterworth Road Burbage		
Date 29/06/2023 13:54 File SW Model 17.05.23.mdx		
Designed by matt.leask		
Checked by		
Innovyze		Network 2019.1

Summary Wizard of 180 minute 100 year Summer I+40% for Surface Water Network

Simulation Criteria

Areal Reduction Factor 1.000	Additional Flow - % of Total Flow 0.000
Hot Start (mins) 0	MADD Factor * 10m³/ha Storage 0.000
Hot Start Level (mm) 0	Inlet Coefficient 0.800
Manhole Headloss Coeff (Global) 0.500	Flow per Person per Day (l/per/day) 0.000
Foul Sewage per hectare (l/s) 0.000	

Number of Input Hydrographs 0 Number of Offline Controls 5 Number of Time/Area Diagrams 0
 Number of Online Controls 3 Number of Storage Structures 2 Number of Real Time Controls 0

Synthetic Rainfall Details

Rainfall Model	FSR	Ratio R 0.401
Region England and Wales Cv (Summer)	0.750	
M5-60 (mm)	19.600 Cv (Winter)	0.840

Margin for Flood Risk Warning (mm) 300.0
 Analysis Timestep 2.5 Second Increment (Extended)
 DTS Status OFF
 DVD Status OFF
 Inertia Status OFF

Profile(s) Summer and Winter
 Duration(s) (mins) 15, 30, 60, 120, 180, 240, 360, 480, 600, 720, 960, 1440
 Return Period(s) (years) 1, 30, 100
 Climate Change (%) 0, 0, 40

PN	US/MH Name	Storm Rank	Water Level (m)	Surcharged Depth (m)	Flooded Volume (m³)	Flow / Cap.	Overflow (l/s)	Pipe Flow (l/s)	Status
1.000	S4	13	113.929	-0.146	0.000	0.27		21.0	OK
1.001	S5	13	112.727	-0.148	0.000	0.26		23.6	OK
1.002	S6	13	112.077	-0.068	0.000	0.83		29.9	OK
1.003	S7	13	111.749	-0.266	0.000	0.19		54.9	OK
2.000	S1	13	113.467	-0.208	0.000	0.41		92.8	OK
2.001	S2	13	112.804	-0.211	0.000	0.40		120.4	OK
2.002	S3	13	111.642	-0.263	0.000	0.36		137.6	OK
1.004	S8	13	111.454	0.004	0.000	1.09		212.1	SURCHARGED
1.005	S9	13	111.102	-0.207	0.000	0.56		248.7	OK
1.006	S10	13	110.364	-0.255	0.000	0.39		253.5	OK
1.007	S11	13	108.914	-0.386	0.000	0.27		303.5	OK
1.008	S12	14	107.498	-0.052	0.000	0.68		332.5	OK
3.000	S13	13	110.651	-0.174	0.000	0.12		10.8	OK
3.001	S14	13	109.558	-0.207	0.000	0.21		37.0	OK
3.002	S15	13	108.850	-0.210	0.000	0.19		48.0	OK

©1982-2019 Innovyze

PJS Consulting Engineers Limited

Unit 4 Winking Hill Farm
Kingston-on-Soar, Nottingham
Nottinghamshire NG11 0DP

Date 29/06/2023 13:54
File SW Model 17.05.23.mdx

Innovyze

Lutterworth Road
Burbage

Designed by matt.leask
Checked by

Network 2019.1

Page 64



Summary Wizard of 240 minute 100 year Summer I+40% for Surface Water Network

Simulation Criteria

Areal Reduction Factor 1.000

Hot Start (mins) 0

Hot Start Level (mm) 0

Manhole Headloss Coeff (Global) 0.500

Foul Sewage per hectare (l/s) 0.000

Additional Flow - % of Total Flow 0.000

MADD Factor * 10m³/ha Storage 0.000

Inlet Coeffiecient 0.800

Flow per Person per Day (l/per/day) 0.000

Number of Input Hydrographs 0

Number of Offline Controls 5

Number of Time/Area Diagrams 0

Number of Online Controls 3

Number of Storage Structures 2

Number of Real Time Controls 0

Synthetic Rainfall Details

Rainfall Model FSR

Region England and Wales Cv (Summer) 0.750

M5-60 (mm) 19.600

Cv (Winter) 0.840

Ratio R 0.401

Margin for Flood Risk Warning (mm) 300.0

Analysis Timestep 2.5 Second Increment (Extended)

DTS Status OFF

DVD Status OFF

Inertia Status OFF

Profile(s) Summer and Winter

Duration(s) (mins) 15, 30, 60, 120, 180, 240, 360, 480, 600, 720, 960, 1440

Return Period(s) (years) 1, 30, 100

Climate Change (%) 0, 0, 40

			Water	Surcharged	Flooded		Pipe	
	US/MH	Storm	Level	Depth	Volume	Flow /	Overflow	Flow
PN	Name	Rank	(m)	(m)	(m³)	Cap.	(l/s)	(l/s)
Status								
1.000	S4	16	113.921	-0.154	0.000	0.22	17.1	OK
1.001	S5	16	112.719	-0.156	0.000	0.21	19.1	OK
1.002	S6	16	112.055	-0.090	0.000	0.67	24.2	OK
1.003	S7	16	111.737	-0.278	0.000	0.15	44.4	OK
2.000	S1	16	113.449	-0.226	0.000	0.33	75.2	OK
2.001	S2	16	112.786	-0.229	0.000	0.32	97.6	OK
2.002	S3	16	111.621	-0.284	0.000	0.29	111.4	OK
1.004	S8	16	111.328	-0.122	0.000	0.88	171.9	OK
1.005	S9	16	111.073	-0.236	0.000	0.46	201.5	OK
1.006	S10	16	110.343	-0.276	0.000	0.32	205.5	OK
1.007	S11	16	108.891	-0.409	0.000	0.22	246.4	OK
1.008	S12	21	107.406	-0.144	0.000	0.55	269.8	OK
3.000	S13	16	110.647	-0.178	0.000	0.10	8.8	OK
3.001	S14	16	109.548	-0.217	0.000	0.17	29.9	OK
3.002	S15	16	108.839	-0.221	0.000	0.16	38.8	OK

©1982-2019 Innovyze

PJS Consulting Engineers Limited

Unit 4 Winking Hill Farm
Kingston-on-Soar, Nottingham
Nottinghamshire NG11 0DP

Date 29/06/2023 13:54
File SW Model 17.05.23.mdx

Innovyze

Lutterworth Road
Burbage

Designed by matt.leask
Checked by

Network 2019.1

Page 66



Summary Wizard of 360 minute 100 year Summer I+40% for Surface Water Network

Simulation Criteria

Areal Reduction Factor 1.000

Hot Start (mins) 0

Hot Start Level (mm) 0

Manhole Headloss Coeff (Global) 0.500

Foul Sewage per hectare (l/s) 0.000

Additional Flow - % of Total Flow 0.000

MADD Factor * 10m³/ha Storage 0.000

Inlet Coeffiecient 0.800

Flow per Person per Day (l/per/day) 0.000

Number of Input Hydrographs 0

Number of Offline Controls 5

Number of Time/Area Diagrams 0

Number of Online Controls 3

Number of Storage Structures 2

Number of Real Time Controls 0

Synthetic Rainfall Details

Rainfall Model FSR

Region England and Wales Cv (Summer) 0.750

M5-60 (mm) 19.600

Cv (Winter) 0.840

Margin for Flood Risk Warning (mm) 300.0

Analysis Timestep 2.5 Second Increment (Extended)

DTS Status OFF

DVD Status OFF

Inertia Status OFF

Profile(s) Summer and Winter

Duration(s) (mins) 15, 30, 60, 120, 180, 240, 360, 480, 600, 720, 960, 1440

Return Period(s) (years) 1, 30, 100

Climate Change (%) 0, 0, 40

			Water	Surcharged	Flooded		Pipe	
	US/MH	Storm	Level	Depth	Volume	Flow /	Overflow	Pipe
PN	Name	Rank	(m)	(m)	(m³)	Cap.	(l/s)	(l/s)
								Status
1.000	S4	22	113.910	-0.165	0.000	0.16	12.5	OK
1.001	S5	21	112.708	-0.167	0.000	0.15	14.0	OK
1.002	S6	21	112.031	-0.114	0.000	0.49	17.8	OK
1.003	S7	21	111.723	-0.292	0.000	0.11	32.6	OK
2.000	S1	22	113.425	-0.250	0.000	0.24	55.2	OK
2.001	S2	21	112.763	-0.252	0.000	0.24	71.6	OK
2.002	S3	21	111.596	-0.309	0.000	0.21	81.7	OK
1.004	S8	21	111.264	-0.186	0.000	0.65	126.1	OK
1.005	S9	20	111.039	-0.270	0.000	0.34	148.0	OK
1.006	S10	21	110.316	-0.303	0.000	0.23	151.1	OK
1.007	S11	20	108.862	-0.438	0.000	0.16	181.2	OK
1.008	S12	26	107.327	-0.223	0.000	0.41	197.6	OK
3.000	S13	22	110.639	-0.186	0.000	0.07	6.4	OK
3.001	S14	21	109.535	-0.230	0.000	0.12	21.9	OK
3.002	S15	20	108.827	-0.233	0.000	0.11	28.4	OK

©1982-2019 Innovyze

PJS Consulting Engineers Limited

Unit 4 Winking Hill Farm

Kingston-on-Soar, Nottingham

Nottinghamshire NG11 0DP

Date 29/06/2023 13:54

File SW Model 17.05.23.mdx

Lutterworth Road

Burbage

Designed by matt.leask

Checked by

Innovyze

Network 2019.1

Page 68



Summary Wizard of 480 minute 100 year Summer I+40% for Surface Water Network

Simulation Criteria

Areal Reduction Factor 1.000

Hot Start (mins) 0

Hot Start Level (mm) 0

Manhole Headloss Coeff (Global) 0.500

Foul Sewage per hectare (l/s) 0.000

Additional Flow - % of Total Flow 0.000

MADD Factor * 10m³/ha Storage 0.000

Inlet Coeffiecient 0.800

Flow per Person per Day (l/per/day) 0.000

Number of Input Hydrographs 0

Number of Offline Controls 5

Number of Time/Area Diagrams 0

Number of Online Controls 3

Number of Storage Structures 2

Number of Real Time Controls 0

Synthetic Rainfall Details

Rainfall Model FSR

Region England and Wales Cv (Summer) 0.750

M5-60 (mm) 19.600 Cv (Winter) 0.840

Margin for Flood Risk Warning (mm) 300.0

Analysis Timestep 2.5 Second Increment (Extended)

DTS Status OFF

DVD Status OFF

Inertia Status OFF

Profile(s) Summer and Winter

Duration(s) (mins) 15, 30, 60, 120, 180, 240, 360, 480, 600, 720, 960, 1440

Return Period(s) (years) 1, 30, 100

Climate Change (%) 0, 0, 40

Water

US/MH

Storm

Level

Depth

Volume

Flow /

Overflow

Pipe

PN

Name

Rank

(m)

(m)

(m³)

Cap.

(l/s)

(l/s)

Status

PN

Name

Rank

(m)

(m)

(m³)

Cap.

(l/s)

(l/s)

Status

1.000

S4

27

113.903

-0.172

0.000

0.13

10.0

OK

1.001

S5

27

112.702

-0.173

0.000

0.12

11.2

OK

1.002

S6

27

112.017

-0.128

0.000

0.39

14.2

OK

1.003

S7

27

111.715

-0.300

0.000

0.09

26.0

OK

2.000

S1

27

113.412

-0.263

0.000

0.19

44.0

OK

2.001

S2

27

112.750

-0.265

0.000

0.19

57.0

OK

2.002

S3

27

111.579

-0.326

0.000

0.17

65.1

OK

1.004

S8

27

111.229

-0.221

0.000

0.52

100.6

OK

1.005

S9

27

111.017

-0.292

0.000

0.27

118.2

OK

1.006

S10

27

110.300

-0.319

0.000

0.19

120.6

OK

1.007

S11

27

108.843

-0.457

0.000

0.13

144.7

OK

1.008

S12

27

107.327

-0.223

0.000

0.33

158.6

OK

3.000

S13

27

110.634

-0.191

0.000

0.06

5.1

OK

3.001

S14

27

109.528

-0.237

0.000

0.10

17.4

OK

3.002

S15

27

108.821

-0.239

0.000


0.09

22.6

OK

©1982-2019 Innovyze

PJS Consulting Engineers Limited				Page 70																																																																																																																																																										
Unit 4 Winking Hill Farm Kingston-on-Soar, Nottingham Nottinghamshire NG11 0DP		Lutterworth Road Burbage																																																																																																																																																												
Date 29/06/2023 13:54		Designed by matt.leask																																																																																																																																																												
File SW Model 17.05.23.mdx		Checked by																																																																																																																																																												
Innovyze		Network 2019.1																																																																																																																																																												
<u>Summary Wizard of 600 minute 100 year Summer I+40% for Surface Water Network</u>																																																																																																																																																														
<u>Simulation Criteria</u>																																																																																																																																																														
Areal Reduction Factor 1.000		Additional Flow - % of Total Flow 0.000																																																																																																																																																												
Hot Start (mins) 0		MADD Factor * 10m³/ha Storage 0.000																																																																																																																																																												
Hot Start Level (mm) 0		Inlet Coefficient 0.800																																																																																																																																																												
Manhole Headloss Coeff (Global) 0.500		Flow per Person per Day (l/per/day) 0.000																																																																																																																																																												
Foul Sewage per hectare (l/s) 0.000																																																																																																																																																														
Number of Input Hydrographs 0		Number of Offline Controls 5		Number of Time/Area Diagrams 0																																																																																																																																																										
Number of Online Controls 3		Number of Storage Structures 2		Number of Real Time Controls 0																																																																																																																																																										
<u>Synthetic Rainfall Details</u>																																																																																																																																																														
Rainfall Model		FSR		Ratio R 0.401																																																																																																																																																										
Region England and Wales		Cv (Summer) 0.750																																																																																																																																																												
M5-60 (mm)		19.600		Cv (Winter) 0.840																																																																																																																																																										
Margin for Flood Risk Warning (mm)		300.0																																																																																																																																																												
Analysis Timestep 2.5		Second Increment (Extended)																																																																																																																																																												
DTS Status		OFF																																																																																																																																																												
DVD Status		OFF																																																																																																																																																												
Inertia Status		OFF																																																																																																																																																												
Profile(s)		Summer and Winter																																																																																																																																																												
Duration(s) (mins)		15, 30, 60, 120, 180, 240, 360, 480, 600, 720, 960, 1440																																																																																																																																																												
Return Period(s) (years)		1, 30, 100																																																																																																																																																												
Climate Change (%)		0, 0, 40																																																																																																																																																												
<table><tr><th></th><th>US/MH</th><th>Storm</th><th>Water Level</th><th>Surcharged Depth</th><th>Flooded Volume</th><th>Flow / Overflow</th><th>Pipe Flow</th><th></th></tr><tr><th>PN</th><th>Name</th><th>Rank</th><th>(m)</th><th>(m)</th><th>(m³)</th><th>Cap. (l/s)</th><th>(l/s)</th><th>Status</th></tr><tr><td>1.000</td><td>S4</td><td>32</td><td>113.899</td><td>-0.176</td><td>0.000</td><td>0.11</td><td>8.4</td><td>OK</td></tr><tr><td>1.001</td><td>S5</td><td>32</td><td>112.698</td><td>-0.177</td><td>0.000</td><td>0.10</td><td>9.4</td><td>OK</td></tr><tr><td>1.002</td><td>S6</td><td>32</td><td>112.008</td><td>-0.137</td><td>0.000</td><td>0.33</td><td>11.9</td><td>OK</td></tr><tr><td>1.003</td><td>S7</td><td>32</td><td>111.707</td><td>-0.308</td><td>0.000</td><td>0.07</td><td>21.8</td><td>OK</td></tr><tr><td>2.000</td><td>S1</td><td>32</td><td>113.401</td><td>-0.274</td><td>0.000</td><td>0.16</td><td>36.9</td><td>OK</td></tr><tr><td>2.001</td><td>S2</td><td>32</td><td>112.739</td><td>-0.276</td><td>0.000</td><td>0.16</td><td>47.8</td><td>OK</td></tr><tr><td>2.002</td><td>S3</td><td>32</td><td>111.568</td><td>-0.337</td><td>0.000</td><td>0.14</td><td>54.6</td><td>OK</td></tr><tr><td>1.004</td><td>S8</td><td>32</td><td>111.206</td><td>-0.244</td><td>0.000</td><td>0.43</td><td>84.3</td><td>OK</td></tr><tr><td>1.005</td><td>S9</td><td>32</td><td>111.003</td><td>-0.306</td><td>0.000</td><td>0.22</td><td>99.0</td><td>OK</td></tr><tr><td>1.006</td><td>S10</td><td>32</td><td>110.287</td><td>-0.332</td><td>0.000</td><td>0.16</td><td>101.0</td><td>OK</td></tr><tr><td>1.007</td><td>S11</td><td>32</td><td>108.832</td><td>-0.468</td><td>0.000</td><td>0.11</td><td>121.3</td><td>OK</td></tr><tr><td>1.008</td><td>S12</td><td>28</td><td>107.317</td><td>-0.233</td><td>0.000</td><td>0.27</td><td>132.9</td><td>OK</td></tr><tr><td>3.000</td><td>S13</td><td>32</td><td>110.631</td><td>-0.194</td><td>0.000</td><td>0.05</td><td>4.3</td><td>OK</td></tr><tr><td>3.001</td><td>S14</td><td>32</td><td>109.523</td><td>-0.242</td><td>0.000</td><td>0.08</td><td>14.6</td><td>OK</td></tr><tr><td>3.002</td><td>S15</td><td>32</td><td>108.815</td><td>-0.245</td><td>0.000</td><td>0.08</td><td>19.0</td><td>OK</td></tr></table>							US/MH	Storm	Water Level	Surcharged Depth	Flooded Volume	Flow / Overflow	Pipe Flow		PN	Name	Rank	(m)	(m)	(m³)	Cap. (l/s)	(l/s)	Status	1.000	S4	32	113.899	-0.176	0.000	0.11	8.4	OK	1.001	S5	32	112.698	-0.177	0.000	0.10	9.4	OK	1.002	S6	32	112.008	-0.137	0.000	0.33	11.9	OK	1.003	S7	32	111.707	-0.308	0.000	0.07	21.8	OK	2.000	S1	32	113.401	-0.274	0.000	0.16	36.9	OK	2.001	S2	32	112.739	-0.276	0.000	0.16	47.8	OK	2.002	S3	32	111.568	-0.337	0.000	0.14	54.6	OK	1.004	S8	32	111.206	-0.244	0.000	0.43	84.3	OK	1.005	S9	32	111.003	-0.306	0.000	0.22	99.0	OK	1.006	S10	32	110.287	-0.332	0.000	0.16	101.0	OK	1.007	S11	32	108.832	-0.468	0.000	0.11	121.3	OK	1.008	S12	28	107.317	-0.233	0.000	0.27	132.9	OK	3.000	S13	32	110.631	-0.194	0.000	0.05	4.3	OK	3.001	S14	32	109.523	-0.242	0.000	0.08	14.6	OK	3.002	S15	32	108.815	-0.245	0.000	0.08	19.0	OK
	US/MH	Storm	Water Level	Surcharged Depth	Flooded Volume	Flow / Overflow	Pipe Flow																																																																																																																																																							
PN	Name	Rank	(m)	(m)	(m³)	Cap. (l/s)	(l/s)	Status																																																																																																																																																						
1.000	S4	32	113.899	-0.176	0.000	0.11	8.4	OK																																																																																																																																																						
1.001	S5	32	112.698	-0.177	0.000	0.10	9.4	OK																																																																																																																																																						
1.002	S6	32	112.008	-0.137	0.000	0.33	11.9	OK																																																																																																																																																						
1.003	S7	32	111.707	-0.308	0.000	0.07	21.8	OK																																																																																																																																																						
2.000	S1	32	113.401	-0.274	0.000	0.16	36.9	OK																																																																																																																																																						
2.001	S2	32	112.739	-0.276	0.000	0.16	47.8	OK																																																																																																																																																						
2.002	S3	32	111.568	-0.337	0.000	0.14	54.6	OK																																																																																																																																																						
1.004	S8	32	111.206	-0.244	0.000	0.43	84.3	OK																																																																																																																																																						
1.005	S9	32	111.003	-0.306	0.000	0.22	99.0	OK																																																																																																																																																						
1.006	S10	32	110.287	-0.332	0.000	0.16	101.0	OK																																																																																																																																																						
1.007	S11	32	108.832	-0.468	0.000	0.11	121.3	OK																																																																																																																																																						
1.008	S12	28	107.317	-0.233	0.000	0.27	132.9	OK																																																																																																																																																						
3.000	S13	32	110.631	-0.194	0.000	0.05	4.3	OK																																																																																																																																																						
3.001	S14	32	109.523	-0.242	0.000	0.08	14.6	OK																																																																																																																																																						
3.002	S15	32	108.815	-0.245	0.000	0.08	19.0	OK																																																																																																																																																						
©1982-2019 Innovyze																																																																																																																																																														

PJS Consulting Engineers Limited		Page 72
Unit 4 Winking Hill Farm Kingston-on-Soar, Nottingham Nottinghamshire NG11 ODP		
Lutterworth Road Burbage		
Date 29/06/2023 13:54 File SW Model 17.05.23.mdx		
Designed by matt.leask Checked by		
Innovyze		Network 2019.1

Summary Wizard of 720 minute 100 year Summer I+40% for Surface Water Network

Simulation Criteria

Areal Reduction Factor	1.000	Additional Flow - % of Total Flow	0.000
Hot Start (mins)	0	MADD Factor * 10m³/ha Storage	0.000
Hot Start Level (mm)	0	Inlet Coefficient	0.800
Manhole Headloss Coeff (Global)	0.500	Flow per Person per Day (l/per/day)	0.000
Foul Sewage per hectare (l/s)	0.000		

Number of Input Hydrographs 0 Number of Offline Controls 5 Number of Time/Area Diagrams 0
Number of Online Controls 3 Number of Storage Structures 2 Number of Real Time Controls 0

Synthetic Rainfall Details


Rainfall Model	FSR	Ratio R	0.401
Region	England and Wales	Cv (Summer)	0.750
M5-60 (mm)	19.600	Cv (Winter)	0.840

Margin for Flood Risk Warning (mm) 300.0
Analysis Timestep 2.5 Second Increment (Extended)
DTS Status OFF
DVD Status OFF
Inertia Status OFF

Profile(s) Summer and Winter
Duration(s) (mins) 15, 30, 60, 120, 180, 240, 360, 480, 600, 720, 960, 1440
Return Period(s) (years) 1, 30, 100
Climate Change (%) 0, 0, 40

PN	US/MH Name	Storm Rank	Water	Surcharged	Flooded	Pipe		Status
			Level (m)	Depth (m)	Volume (m³)	Flow / Overflow (l/s)	Flow (l/s)	
1.000	S4	34	113.896	-0.179	0.000	0.09	7.2	OK
1.001	S5	34	112.695	-0.180	0.000	0.09	8.1	OK
1.002	S6	34	112.001	-0.144	0.000	0.28	10.3	OK
1.003	S7	34	111.701	-0.314	0.000	0.06	18.8	OK
2.000	S1	34	113.393	-0.282	0.000	0.14	31.9	OK
2.001	S2	34	112.732	-0.283	0.000	0.14	41.3	OK
2.002	S3	34	111.560	-0.345	0.000	0.12	47.2	OK
1.004	S8	34	111.190	-0.260	0.000	0.37	73.0	OK
1.005	S9	34	110.993	-0.316	0.000	0.19	85.7	OK
1.006	S10	34	110.278	-0.341	0.000	0.14	87.4	OK
1.007	S11	34	108.823	-0.477	0.000	0.09	104.9	OK
1.008	S12	29	107.313	-0.237	0.000	0.24	115.0	OK
3.000	S13	34	110.629	-0.196	0.000	0.04	3.7	OK
3.001	S14	34	109.518	-0.247	0.000	0.07	12.6	OK
3.002	S15	34	108.810	-0.250	0.000	0.07	16.4	OK

©1982-2019 Innovyze

PJS Consulting Engineers Limited		Page 74
Unit 4 Winking Hill Farm Kingston-on-Soar, Nottingham Nottinghamshire NG11 0DP		
Lutterworth Road Burbage		
Date 29/06/2023 13:54 File SW Model 17.05.23.mdx		
Designed by matt.leask Checked by		
Innovyze		Network 2019.1

Summary Wizard of 960 minute 100 year Summer I+40% for Surface Water Network

Simulation Criteria

Areal Reduction Factor	1.000	Additional Flow - % of Total Flow	0.000
Hot Start (mins)	0	MADD Factor * 10m³/ha Storage	0.000
Hot Start Level (mm)	0	Inlet Coefficient	0.800
Manhole Headloss Coeff (Global)	0.500	Flow per Person per Day (l/per/day)	0.000
Foul Sewage per hectare (l/s)	0.000		

Number of Input Hydrographs	0	Number of Offline Controls	5	Number of Time/Area Diagrams	0
Number of Online Controls	3	Number of Storage Structures	2	Number of Real Time Controls	0

Synthetic Rainfall Details


Rainfall Model	FSR	Ratio R	0.401
Region	England and Wales	Cv (Summer)	0.750
M5-60 (mm)	19.600	Cv (Winter)	0.840

Margin for Flood Risk Warning (mm)	300.0
Analysis Timestep	2.5 Second Increment (Extended)
DTS Status	OFF
DVD Status	OFF
Inertia Status	OFF

Profile(s)	Summer and Winter
Duration(s) (mins)	15, 30, 60, 120, 180, 240, 360, 480, 600, 720, 960, 1440
Return Period(s) (years)	1, 30, 100
Climate Change (%)	0, 0, 40

PN	US/MH Name	Storm Rank	Water	Surcharged	Flooded	Pipe		Status
			Level	Depth	Volume	Flow / Overflow	Flow	
			(m)	(m)	(m³)	Cap.	(l/s)	(l/s)
1.000	S4	40	113.890	-0.185	0.000	0.07	5.7	OK
1.001	S5	40	112.689	-0.186	0.000	0.07	6.4	OK
1.002	S6	40	111.992	-0.153	0.000	0.23	8.2	OK
1.003	S7	40	111.694	-0.321	0.000	0.05	15.0	OK
2.000	S1	40	113.383	-0.292	0.000	0.11	25.3	OK
2.001	S2	40	112.722	-0.293	0.000	0.11	32.9	OK
2.002	S3	40	111.549	-0.356	0.000	0.10	37.5	OK
1.004	S8	40	111.167	-0.283	0.000	0.30	58.0	OK
1.005	S9	40	110.976	-0.333	0.000	0.15	68.1	OK
1.006	S10	40	110.267	-0.352	0.000	0.11	69.5	OK
1.007	S11	40	108.808	-0.492	0.000	0.08	83.4	OK
1.008	S12	30	107.279	-0.271	0.000	0.19	91.4	OK
3.000	S13	40	110.626	-0.199	0.000	0.03	3.0	OK
3.001	S14	40	109.511	-0.254	0.000	0.06	10.0	OK
3.002	S15	40	108.804	-0.256	0.000	0.05	13.1	OK

©1982-2019 Innovyze

PJS Consulting Engineers Limited		Page 76
Unit 4 Winking Hill Farm Kingston-on-Soar, Nottingham Nottinghamshire NG11 0DP		
Lutterworth Road Burbage		
Date 29/06/2023 13:54 File SW Model 17.05.23.mdx		
Designed by matt.leask Checked by		
Innovyze		Network 2019.1

Summary Wizard of 1440 minute 100 year Summer I+40% for Surface Water Network

Simulation Criteria

Areal Reduction Factor	1.000	Additional Flow - % of Total Flow	0.000
Hot Start (mins)	0	MADD Factor * 10m³/ha Storage	0.000
Hot Start Level (mm)	0	Inlet Coefficient	0.800
Manhole Headloss Coeff (Global)	0.500	Flow per Person per Day (l/per/day)	0.000
Foul Sewage per hectare (l/s)	0.000		

Number of Input Hydrographs	0	Number of Offline Controls	5	Number of Time/Area Diagrams	0
Number of Online Controls	3	Number of Storage Structures	2	Number of Real Time Controls	0

Synthetic Rainfall Details

Rainfall Model	FSR	Ratio R	0.401
Region	England and Wales	Cv (Summer)	0.750
M5-60 (mm)	19.600	Cv (Winter)	0.840

Margin for Flood Risk Warning (mm)	300.0
Analysis Timestep	2.5 Second Increment (Extended)
DTS Status	OFF
DVD Status	OFF
Inertia Status	OFF

Profile(s)	Summer and Winter
Duration(s) (mins)	15, 30, 60, 120, 180, 240, 360, 480, 600, 720, 960, 1440
Return Period(s) (years)	1, 30, 100
Climate Change (%)	0, 0, 40

PN	US/MH Name	Storm Rank	Water	Surcharged	Flooded	Pipe		Status
			Level (m)	Depth (m)	Volume (m³)	Flow / Overflow (l/s)	Flow (l/s)	
1.000	S4	47	113.883	-0.192	0.000	0.05	4.2	OK
1.001	S5	47	112.682	-0.193	0.000	0.05	4.7	OK
1.002	S6	47	111.980	-0.165	0.000	0.16	5.9	OK
1.003	S7	47	111.686	-0.329	0.000	0.04	10.8	OK
2.000	S1	47	113.371	-0.304	0.000	0.08	18.3	OK
2.001	S2	47	112.709	-0.306	0.000	0.08	23.8	OK
2.002	S3	47	111.534	-0.371	0.000	0.07	27.1	OK
1.004	S8	47	111.141	-0.309	0.000	0.22	41.9	OK
1.005	S9	47	110.959	-0.350	0.000	0.11	49.2	OK
1.006	S10	47	110.252	-0.367	0.000	0.08	50.2	OK
1.007	S11	47	108.790	-0.510	0.000	0.05	60.3	OK
1.008	S12	32	107.228	-0.322	0.000	0.14	66.1	OK
3.000	S13	47	110.623	-0.202	0.000	0.02	2.1	OK
3.001	S14	47	109.504	-0.261	0.000	0.04	7.3	OK
3.002	S15	47	108.798	-0.262	0.000	0.04	9.4	OK

©1982-2019 Innovyze

PJS Consulting Engineers Limited

Unit 4 Winking Hill Farm

Kingston-on-Soar, Nottingham

Nottinghamshire NG11 0DP

Date 29/06/2023 13:54

File SW Model 17.05.23.mdx

Lutterworth Road

Burbage

Designed by matt.leask

Checked by

Innovyze

Network 2019.1

Page 78



Summary Wizard of 15 minute 1 year Winter I+0% for Surface Water Network

Simulation Criteria

Areal Reduction Factor 1.000

Hot Start (mins) 0

Hot Start Level (mm) 0

Manhole Headloss Coeff (Global) 0.500

Foul Sewage per hectare (l/s) 0.000

Additional Flow - % of Total Flow 0.000

MADD Factor * 10m³/ha Storage 0.000

Inlet Coeffiecient 0.800

Flow per Person per Day (l/per/day) 0.000

Number of Input Hydrographs 0

Number of Offline Controls 5

Number of Time/Area Diagrams 0

Number of Online Controls 3

Number of Storage Structures 2

Number of Real Time Controls 0

Synthetic Rainfall Details

Rainfall Model FSR

Region England and Wales Cv (Summer) 0.750

M5-60 (mm) 19.600

Ratio R 0.401

Cv (Winter) 0.840

Margin for Flood Risk Warning (mm) 300.0

Analysis Timestep 2.5 Second Increment (Extended)

DTS Status OFF

DVD Status OFF

Inertia Status OFF

Profile(s) Summer and Winter

Duration(s) (mins) 15, 30, 60, 120, 180, 240, 360, 480, 600, 720, 960, 1440

Return Period(s) (years) 1, 30, 100

Climate Change (%) 0, 0, 40

Water

US/MH Storm

Level

Depth

Volume

Flow /

Overflow

Pipe

PN

Name

Rank

(m)

(m)

(m³)

Cap.

(l/s)

(l/s)

Status

1.000

S4

19

113.916

-0.159

0.000

0.19

14.3

OK

1.001

S5

19

112.714

-0.161

0.000

0.17

15.9

OK

1.002

S6

19

112.039

-0.106

0.000

0.55

19.7

OK

1.003

S7

19

111.725

-0.290

0.000

0.12

34.1

OK

2.000

S1

19

113.437

-0.238

0.000

0.28

63.7

OK

2.001

S2

19

112.772

-0.243

0.000

0.26

79.5

OK

2.002

S3

19

111.604

-0.301

0.000

0.24

90.1

OK

1.004

S8

19

111.278

-0.172

0.000

0.69

135.4

OK

1.005

S9

19

111.044

-0.265

0.000

0.35

155.8

OK

1.006

S10

19

110.320

-0.299

0.000

0.24

157.6

OK

1.007

S11

19

108.866

-0.434

0.000

0.17

185.6

OK

1.008

S12

31

107.244

-0.306

0.000

0.41

201.0

OK

3.000

S13

19

110.643

-0.182

0.000

0.08

7.5

OK

3.001

S14

19

109.537

-0.228

0.000

0.13

22.7

OK

3.002

S15

19

108.829

-0.231

0.000


0.12

29.0

OK

©1982-2019 Innovyze

PJS Consulting Engineers Limited			Page 80																																																																																																																																																						
Unit 4 Winking Hill Farm Kingston-on-Soar, Nottingham Nottinghamshire NG11 0DP		Lutterworth Road Burbage																																																																																																																																																							
Date 29/06/2023 13:54		Designed by matt.leask																																																																																																																																																							
File SW Model 17.05.23.mdx		Checked by																																																																																																																																																							
Innovyze		Network 2019.1																																																																																																																																																							
<u>Summary Wizard of 30 minute 1 year Winter I+0% for Surface Water Network</u>																																																																																																																																																									
<u>Simulation Criteria</u>																																																																																																																																																									
Areal Reduction Factor 1.000		Additional Flow - % of Total Flow 0.000																																																																																																																																																							
Hot Start (mins) 0		MADD Factor * 10m³/ha Storage 0.000																																																																																																																																																							
Hot Start Level (mm) 0		Inlet Coefficient 0.800																																																																																																																																																							
Manhole Headloss Coeff (Global) 0.500		Flow per Person per Day (l/per/day) 0.000																																																																																																																																																							
Foul Sewage per hectare (l/s) 0.000																																																																																																																																																									
Number of Input Hydrographs 0 Number of Offline Controls 5 Number of Time/Area Diagrams 0																																																																																																																																																									
Number of Online Controls 3 Number of Storage Structures 2 Number of Real Time Controls 0																																																																																																																																																									
<u>Synthetic Rainfall Details</u>																																																																																																																																																									
Rainfall Model		FSR		Ratio R 0.401																																																																																																																																																					
Region England and Wales		Cv (Summer)		0.750																																																																																																																																																					
M5-60 (mm)		Cv (Winter)		0.840																																																																																																																																																					
Margin for Flood Risk Warning (mm)		300.0																																																																																																																																																							
Analysis Timestep 2.5		Second Increment (Extended)																																																																																																																																																							
DTS Status		OFF																																																																																																																																																							
DVD Status		OFF																																																																																																																																																							
Inertia Status		OFF																																																																																																																																																							
Profile(s)		Summer and Winter																																																																																																																																																							
Duration(s) (mins)		15, 30, 60, 120, 180, 240, 360, 480, 600, 720, 960, 1440																																																																																																																																																							
Return Period(s) (years)		1, 30, 100																																																																																																																																																							
Climate Change (%)		0, 0, 40																																																																																																																																																							
<table><thead><tr><th rowspan="2">PN</th><th rowspan="2">US/MH Name</th><th rowspan="2">Storm Rank</th><th>Water Level</th><th>Surcharged Depth</th><th>Flooded Volume</th><th>Flow / Overflow</th><th>Pipe Flow</th><th rowspan="2">Status</th></tr><tr><th>(m)</th><th>(m)</th><th>(m³)</th><th>Cap. (l/s)</th><th>(l/s)</th></tr></thead><tbody><tr><td>1.000</td><td>S4</td><td>26</td><td>113.907</td><td>-0.168</td><td>0.000</td><td>0.15</td><td>11.3</td><td>OK</td></tr><tr><td>1.001</td><td>S5</td><td>26</td><td>112.705</td><td>-0.170</td><td>0.000</td><td>0.14</td><td>12.6</td><td>OK</td></tr><tr><td>1.002</td><td>S6</td><td>26</td><td>112.024</td><td>-0.121</td><td>0.000</td><td>0.43</td><td>15.7</td><td>OK</td></tr><tr><td>1.003</td><td>S7</td><td>26</td><td>111.718</td><td>-0.297</td><td>0.000</td><td>0.10</td><td>28.1</td><td>OK</td></tr><tr><td>2.000</td><td>S1</td><td>26</td><td>113.419</td><td>-0.256</td><td>0.000</td><td>0.22</td><td>50.1</td><td>OK</td></tr><tr><td>2.001</td><td>S2</td><td>26</td><td>112.756</td><td>-0.259</td><td>0.000</td><td>0.21</td><td>63.8</td><td>OK</td></tr><tr><td>2.002</td><td>S3</td><td>26</td><td>111.587</td><td>-0.318</td><td>0.000</td><td>0.19</td><td>72.3</td><td>OK</td></tr><tr><td>1.004</td><td>S8</td><td>26</td><td>111.243</td><td>-0.207</td><td>0.000</td><td>0.57</td><td>110.3</td><td>OK</td></tr><tr><td>1.005</td><td>S9</td><td>26</td><td>111.025</td><td>-0.284</td><td>0.000</td><td>0.29</td><td>128.7</td><td>OK</td></tr><tr><td>1.006</td><td>S10</td><td>26</td><td>110.306</td><td>-0.313</td><td>0.000</td><td>0.20</td><td>131.1</td><td>OK</td></tr><tr><td>1.007</td><td>S11</td><td>26</td><td>108.849</td><td>-0.451</td><td>0.000</td><td>0.14</td><td>156.0</td><td>OK</td></tr><tr><td>1.008</td><td>S12</td><td>37</td><td>107.198</td><td>-0.352</td><td>0.000</td><td>0.35</td><td>169.8</td><td>OK</td></tr><tr><td>3.000</td><td>S13</td><td>26</td><td>110.637</td><td>-0.188</td><td>0.000</td><td>0.06</td><td>5.8</td><td>OK</td></tr><tr><td>3.001</td><td>S14</td><td>26</td><td>109.530</td><td>-0.235</td><td>0.000</td><td>0.11</td><td>18.8</td><td>OK</td></tr><tr><td>3.002</td><td>S15</td><td>26</td><td>108.823</td><td>-0.237</td><td>0.000</td><td>0.10</td><td>24.3</td><td>OK</td></tr></tbody></table>					PN	US/MH Name	Storm Rank	Water Level	Surcharged Depth	Flooded Volume	Flow / Overflow	Pipe Flow	Status	(m)	(m)	(m³)	Cap. (l/s)	(l/s)	1.000	S4	26	113.907	-0.168	0.000	0.15	11.3	OK	1.001	S5	26	112.705	-0.170	0.000	0.14	12.6	OK	1.002	S6	26	112.024	-0.121	0.000	0.43	15.7	OK	1.003	S7	26	111.718	-0.297	0.000	0.10	28.1	OK	2.000	S1	26	113.419	-0.256	0.000	0.22	50.1	OK	2.001	S2	26	112.756	-0.259	0.000	0.21	63.8	OK	2.002	S3	26	111.587	-0.318	0.000	0.19	72.3	OK	1.004	S8	26	111.243	-0.207	0.000	0.57	110.3	OK	1.005	S9	26	111.025	-0.284	0.000	0.29	128.7	OK	1.006	S10	26	110.306	-0.313	0.000	0.20	131.1	OK	1.007	S11	26	108.849	-0.451	0.000	0.14	156.0	OK	1.008	S12	37	107.198	-0.352	0.000	0.35	169.8	OK	3.000	S13	26	110.637	-0.188	0.000	0.06	5.8	OK	3.001	S14	26	109.530	-0.235	0.000	0.11	18.8	OK	3.002	S15	26	108.823	-0.237	0.000	0.10	24.3	OK
PN	US/MH Name	Storm Rank	Water Level	Surcharged Depth				Flooded Volume	Flow / Overflow	Pipe Flow	Status																																																																																																																																														
			(m)	(m)	(m³)	Cap. (l/s)	(l/s)																																																																																																																																																		
1.000	S4	26	113.907	-0.168	0.000	0.15	11.3	OK																																																																																																																																																	
1.001	S5	26	112.705	-0.170	0.000	0.14	12.6	OK																																																																																																																																																	
1.002	S6	26	112.024	-0.121	0.000	0.43	15.7	OK																																																																																																																																																	
1.003	S7	26	111.718	-0.297	0.000	0.10	28.1	OK																																																																																																																																																	
2.000	S1	26	113.419	-0.256	0.000	0.22	50.1	OK																																																																																																																																																	
2.001	S2	26	112.756	-0.259	0.000	0.21	63.8	OK																																																																																																																																																	
2.002	S3	26	111.587	-0.318	0.000	0.19	72.3	OK																																																																																																																																																	
1.004	S8	26	111.243	-0.207	0.000	0.57	110.3	OK																																																																																																																																																	
1.005	S9	26	111.025	-0.284	0.000	0.29	128.7	OK																																																																																																																																																	
1.006	S10	26	110.306	-0.313	0.000	0.20	131.1	OK																																																																																																																																																	
1.007	S11	26	108.849	-0.451	0.000	0.14	156.0	OK																																																																																																																																																	
1.008	S12	37	107.198	-0.352	0.000	0.35	169.8	OK																																																																																																																																																	
3.000	S13	26	110.637	-0.188	0.000	0.06	5.8	OK																																																																																																																																																	
3.001	S14	26	109.530	-0.235	0.000	0.11	18.8	OK																																																																																																																																																	
3.002	S15	26	108.823	-0.237	0.000	0.10	24.3	OK																																																																																																																																																	
©1982-2019 Innovyze																																																																																																																																																									

PJS Consulting Engineers Limited		Page 82
Unit 4 Winking Hill Farm Kingston-on-Soar, Nottingham Nottinghamshire NG11 0DP		
Lutterworth Road Burbage		
Date 29/06/2023 13:54 File SW Model 17.05.23.mdx		
Designed by matt.leask Checked by		
Innovyze		Network 2019.1

Summary Wizard of 60 minute 1 year Winter I+0% for Surface Water Network

Simulation Criteria

Areal Reduction Factor	1.000	Additional Flow - % of Total Flow	0.000
Hot Start (mins)	0	MADD Factor * 10m³/ha Storage	0.000
Hot Start Level (mm)	0	Inlet Coefficient	0.800
Manhole Headloss Coeff (Global)	0.500	Flow per Person per Day (l/per/day)	0.000
Foul Sewage per hectare (l/s)	0.000		

Number of Input Hydrographs 0 Number of Offline Controls 5 Number of Time/Area Diagrams 0
Number of Online Controls 3 Number of Storage Structures 2 Number of Real Time Controls 0

Synthetic Rainfall Details

Rainfall Model	FSR	Ratio R	0.401
Region	England and Wales	Cv (Summer)	0.750
M5-60 (mm)	19.600	Cv (Winter)	0.840

Margin for Flood Risk Warning (mm) 300.0
Analysis Timestep 2.5 Second Increment (Extended)
DTS Status OFF
DVD Status OFF
Inertia Status OFF

Profile(s) Summer and Winter
Duration(s) (mins) 15, 30, 60, 120, 180, 240, 360, 480, 600, 720, 960, 1440
Return Period(s) (years) 1, 30, 100
Climate Change (%) 0, 0, 40

PN	US/MH Name	Storm Rank	Water	Surcharged	Flooded	Pipe		Status
			Level (m)	Depth (m)	Volume (m³)	Flow / Overflow (l/s)	Flow (l/s)	
1.000	S4	33	113.897	-0.178	0.000	0.10	7.7	OK
1.001	S5	33	112.696	-0.179	0.000	0.09	8.6	OK
1.002	S6	33	112.004	-0.141	0.000	0.30	10.8	OK
1.003	S7	33	111.703	-0.312	0.000	0.07	19.6	OK
2.000	S1	33	113.396	-0.279	0.000	0.15	33.8	OK
2.001	S2	33	112.734	-0.281	0.000	0.14	43.5	OK
2.002	S3	33	111.562	-0.343	0.000	0.13	49.6	OK
1.004	S8	33	111.195	-0.255	0.000	0.39	76.3	OK
1.005	S9	33	110.996	-0.313	0.000	0.20	89.4	OK
1.006	S10	33	110.281	-0.338	0.000	0.14	91.1	OK
1.007	S11	33	108.826	-0.474	0.000	0.10	109.0	OK
1.008	S12	41	107.151	-0.399	0.000	0.24	119.3	OK
3.000	S13	33	110.630	-0.195	0.000	0.04	3.9	OK
3.001	S14	33	109.519	-0.246	0.000	0.07	13.1	OK
3.002	S15	33	108.811	-0.249	0.000	0.07	17.0	OK

©1982-2019 Innovyze

PJS Consulting Engineers Limited

Unit 4 Winking Hill Farm
Kingston-on-Soar, Nottingham
Nottinghamshire NG11 0DP

Date 29/06/2023 13:54
File SW Model 17.05.23.mdx

Innovyze

Lutterworth Road
Burbage

Designed by matt.leask
Checked by

Network 2019.1

Page 84



Summary Wizard of 120 minute 1 year Winter I+0% for Surface Water Network

Simulation Criteria

Areal Reduction Factor 1.000

Hot Start (mins) 0

Hot Start Level (mm) 0

Manhole Headloss Coeff (Global) 0.500

Foul Sewage per hectare (l/s) 0.000

Additional Flow - % of Total Flow 0.000

MADD Factor * 10m³/ha Storage 0.000

Inlet Coeffiecient 0.800

Flow per Person per Day (l/per/day) 0.000

Number of Input Hydrographs 0

Number of Offline Controls 5

Number of Time/Area Diagrams 0

Number of Online Controls 3

Number of Storage Structures 2

Number of Real Time Controls 0

Synthetic Rainfall Details

Rainfall Model FSR

Region England and Wales Cv (Summer) 0.750

M5-60 (mm) 19.600 Cv (Winter) 0.840

Margin for Flood Risk Warning (mm) 300.0

Analysis Timestep 2.5 Second Increment (Extended)

DTS Status OFF

DVD Status OFF

Inertia Status OFF

Profile(s) Summer and Winter

Duration(s) (mins) 15, 30, 60, 120, 180, 240, 360, 480, 600, 720, 960, 1440

Return Period(s) (years) 1, 30, 100

Climate Change (%) 0, 0, 40

Water

US/MH

Storm

Level

Depth

Volume

Flow /

Overflow

Pipe

PN

Name

Rank

(m)

(m)

(m³)

Cap.

(l/s)

(l/s)

Status

Surcharged

Flooded

Flow

Flow

1.000

S4

45

113.886

-0.189

0.000

0.06

4.9

OK

1.001

S5

45

112.685

-0.190

0.000

0.06

5.4

OK

1.002

S6

45

111.986

-0.159

0.000

0.19

6.9

OK

1.003

S7

45

111.690

-0.325

0.000

0.04

12.6

OK

2.000

S1

45

113.377

-0.298

0.000

0.09

21.4

OK

2.001

S2

45

112.716

-0.299

0.000

0.09

27.7

OK

2.002

S3

45

111.541

-0.364

0.000

0.08

31.6

OK

1.004

S8

45

111.152

-0.298

0.000

0.25

48.7

OK

1.005

S9

45

110.966

-0.343

0.000

0.13

57.2

OK

1.006

S10

45

110.260

-0.359

0.000

0.09

58.3

OK

1.007

S11

45

108.797

-0.503

0.000

0.06

69.9

OK

1.008

S12

48

107.108

-0.442

0.000

0.16

76.6

OK

3.000

S13

45

110.625

-0.200

0.000

0.03

2.5

OK

3.001

S14

45

109.507

-0.258

0.000

0.05

8.4

OK

3.002

S15

45

108.800

-0.260


0.000

0.04

10.9

OK

©1982-2019 Innovyze

PJS Consulting Engineers Limited		Page 86
Unit 4 Winking Hill Farm Kingston-on-Soar, Nottingham Nottinghamshire NG11 ODP		
Lutterworth Road Burbage		
Date 29/06/2023 13:54 File SW Model 17.05.23.mdx		
Designed by matt.leask Checked by		
Innovyze		Network 2019.1

Summary Wizard of 180 minute 1 year Winter I+0% for Surface Water Network

Simulation Criteria

Areal Reduction Factor	1.000	Additional Flow - % of Total Flow	0.000
Hot Start (mins)	0	MADD Factor * 10m³/ha Storage	0.000
Hot Start Level (mm)	0	Inlet Coefficient	0.800
Manhole Headloss Coeff (Global)	0.500	Flow per Person per Day (l/per/day)	0.000
Foul Sewage per hectare (l/s)	0.000		

Number of Input Hydrographs 0 Number of Offline Controls 5 Number of Time/Area Diagrams 0
Number of Online Controls 3 Number of Storage Structures 2 Number of Real Time Controls 0

Synthetic Rainfall Details

Rainfall Model	FSR	Ratio R	0.401
Region	England and Wales	Cv (Summer)	0.750
M5-60 (mm)	19.600	Cv (Winter)	0.840

Margin for Flood Risk Warning (mm) 300.0
Analysis Timestep 2.5 Second Increment (Extended)
DTS Status OFF
DVD Status OFF
Inertia Status OFF

Profile(s) Summer and Winter
Duration(s) (mins) 15, 30, 60, 120, 180, 240, 360, 480, 600, 720, 960, 1440
Return Period(s) (years) 1, 30, 100
Climate Change (%) 0, 0, 40

PN	US/MH Name	Storm Rank	Water	Surcharged	Flooded	Pipe		Status
			Level (m)	Depth (m)	Volume (m³)	Flow / Overflow (l/s)	Flow (l/s)	
1.000	S4	52	113.881	-0.194	0.000	0.05	3.7	OK
1.001	S5	52	112.680	-0.195	0.000	0.05	4.1	OK
1.002	S6	52	111.976	-0.169	0.000	0.14	5.2	OK
1.003	S7	52	111.684	-0.331	0.000	0.03	9.5	OK
2.000	S1	52	113.366	-0.309	0.000	0.07	16.2	OK
2.001	S2	52	112.704	-0.311	0.000	0.07	21.0	OK
2.002	S3	52	111.528	-0.377	0.000	0.06	23.9	OK
1.004	S8	52	111.132	-0.318	0.000	0.19	37.0	OK
1.005	S9	52	110.953	-0.356	0.000	0.10	43.4	OK
1.006	S10	52	110.246	-0.373	0.000	0.07	44.2	OK
1.007	S11	52	108.784	-0.516	0.000	0.05	53.1	OK
1.008	S12	53	107.087	-0.463	0.000	0.12	58.1	OK
3.000	S13	52	110.622	-0.203	0.000	0.02	1.9	OK
3.001	S14	52	109.502	-0.263	0.000	0.04	6.4	OK
3.002	S15	52	108.796	-0.264	0.000	0.03	8.3	OK

©1982-2019 Innovyze

PJS Consulting Engineers Limited

Unit 4 Winking Hill Farm
Kingston-on-Soar, Nottingham
Nottinghamshire NG11 0DP

Date 29/06/2023 13:54
File SW Model 17.05.23.mdx

Innovyze

Lutterworth Road
Burbage

Designed by matt.leask
Checked by

Network 2019.1

Page 90



Summary Wizard of 360 minute 1 year Winter I+0% for Surface Water Network

Simulation Criteria

Areal Reduction Factor 1.000

Hot Start (mins) 0

Hot Start Level (mm) 0

Manhole Headloss Coeff (Global) 0.500

Foul Sewage per hectare (l/s) 0.000

Additional Flow - % of Total Flow 0.000

MADD Factor * 10m³/ha Storage 0.000

Inlet Coeffiecient 0.800

Flow per Person per Day (l/per/day) 0.000

Number of Input Hydrographs 0

Number of Offline Controls 5

Number of Time/Area Diagrams 0

Number of Online Controls 3

Number of Storage Structures 2

Number of Real Time Controls 0

Synthetic Rainfall Details

Rainfall Model FSR

Region England and Wales Cv (Summer) 0.750

M5-60 (mm) 19.600 Cv (Winter) 0.840

Ratio R 0.401

Margin for Flood Risk Warning (mm) 300.0

Analysis Timestep 2.5 Second Increment (Extended)

DTS Status OFF

DVD Status OFF

Inertia Status OFF

Profile(s) Summer and Winter


Duration(s) (mins) 15, 30, 60, 120, 180, 240, 360, 480, 600, 720, 960, 1440

Return Period(s) (years) 1, 30, 100

Climate Change (%) 0, 0, 40

PN	US/MH Name	Storm Rank	Water	Surcharged	Flooded	Flow / Cap.	Overflow (l/s)	Pipe	Status
			Level (m)	Depth (m)	Volume (m³)			Flow (l/s)	
1.000	S4	62	113.875	-0.200	0.000	0.03	2.2	OK	
1.001	S5	62	112.675	-0.200	0.000	0.03	2.5	OK	
1.002	S6	62	111.965	-0.180	0.000	0.09	3.2	OK	
1.003	S7	62	111.675	-0.340	0.000	0.02	5.9	OK	
2.000	S1	62	113.350	-0.325	0.000	0.04	9.9	OK	
2.001	S2	62	112.689	-0.326	0.000	0.04	12.9	OK	
2.002	S3	62	111.512	-0.393	0.000	0.04	14.7	OK	
1.004	S8	62	111.102	-0.348	0.000	0.12	22.7	OK	
1.005	S9	62	110.930	-0.379	0.000	0.06	26.6	OK	
1.006	S10	62	110.228	-0.391	0.000	0.04	27.2	OK	
1.007	S11	62	108.767	-0.533	0.000	0.03	32.6	OK	
1.008	S12	62	107.057	-0.493	0.000	0.07	35.7	OK	
3.000	S13	62	110.614	-0.211	0.000	0.01	1.2	OK	
3.001	S14	62	109.496	-0.269	0.000	0.02	3.9	OK	
3.002	S15	62	108.789	-0.271	0.000	0.02	5.1	OK	

©1982-2019 Innovyze

PJS Consulting Engineers Limited		Page 92
Unit 4 Winking Hill Farm Kingston-on-Soar, Nottingham Nottinghamshire NG11 0DP		
Lutterworth Road Burbage		
Date 29/06/2023 13:54 File SW Model 17.05.23.mdx		
Designed by matt.leask Checked by		
Innovyze	Network 2019.1	

Summary Wizard of 480 minute 1 year Winter I+0% for Surface Water Network

Simulation Criteria

Areal Reduction Factor	1.000	Additional Flow - % of Total Flow	0.000
Hot Start (mins)	0	MADD Factor * 10m³/ha Storage	0.000
Hot Start Level (mm)	0	Inlet Coefficient	0.800
Manhole Headloss Coeff (Global)	0.500	Flow per Person per Day (l/per/day)	0.000
Foul Sewage per hectare (l/s)	0.000		

Number of Input Hydrographs	0	Number of Offline Controls	5
Number of Online Controls	3	Number of Storage Structures	2
		Number of Real Time Controls	0

Synthetic Rainfall Details


Rainfall Model	FSR	Ratio R	0.401
Region England and Wales Cv (Summer)	0.750		
M5-60 (mm)	19.600	Cv (Winter)	0.840

Margin for Flood Risk Warning (mm)		300.0	
Analysis Timestep	2.5 Second	Increment (Extended)	
DTS Status		OFF	
DVD Status		OFF	
Inertia Status		OFF	

Profile(s)		Summer and Winter	
Duration(s) (mins)	15, 30, 60, 120, 180, 240, 360, 480, 600, 720, 960, 1440		
Return Period(s) (years)	1, 30, 100		
Climate Change (%)	0, 0, 40		

				Water	Surcharged	Flooded		Pipe	
PN	US/MH Name	Storm Rank	Level (m)	Depth (m)	Volume (m³)	Flow / Cap.	Overflow (l/s)	Flow (l/s)	Status
1.000	S4	65	113.873	-0.202	0.000	0.02		1.8	OK
1.001	S5	65	112.673	-0.202	0.000	0.02		2.0	OK
1.002	S6	65	111.959	-0.186	0.000	0.07		2.6	OK
1.003	S7	65	111.669	-0.346	0.000	0.02		4.8	OK
2.000	S1	65	113.346	-0.329	0.000	0.04		8.0	OK
2.001	S2	65	112.685	-0.330	0.000	0.03		10.4	OK
2.002	S3	65	111.507	-0.398	0.000	0.03		11.9	OK
1.004	S8	65	111.092	-0.358	0.000	0.09		18.4	OK
1.005	S9	65	110.923	-0.386	0.000	0.05		21.6	OK
1.006	S10	65	110.223	-0.396	0.000	0.03		22.0	OK
1.007	S11	65	108.762	-0.538	0.000	0.02		26.5	OK
1.008	S12	65	107.044	-0.506	0.000	0.06		29.0	OK
3.000	S13	65	110.611	-0.214	0.000	0.01		0.9	OK
3.001	S14	65	109.491	-0.274	0.000	0.02		3.2	OK
3.002	S15	65	108.784	-0.276	0.000	0.02		4.1	OK

©1982-2019 Innovyze

PJS Consulting Engineers Limited		Page 94
Unit 4 Winking Hill Farm Kingston-on-Soar, Nottingham Nottinghamshire NG11 0DP		
Lutterworth Road Burbage		
Date 29/06/2023 13:54 File SW Model 17.05.23.mdx		
Designed by matt.leask Checked by		
Innovyze		Network 2019.1

Summary Wizard of 600 minute 1 year Winter I+0% for Surface Water Network

Simulation Criteria

Areal Reduction Factor	1.000	Additional Flow - % of Total Flow	0.000
Hot Start (mins)	0	MADD Factor * 10m³/ha Storage	0.000
Hot Start Level (mm)	0	Inlet Coefficient	0.800
Manhole Headloss Coeff (Global)	0.500	Flow per Person per Day (l/per/day)	0.000
Foul Sewage per hectare (l/s)	0.000		

Number of Input Hydrographs 0 Number of Offline Controls 5 Number of Time/Area Diagrams 0
Number of Online Controls 3 Number of Storage Structures 2 Number of Real Time Controls 0

Synthetic Rainfall Details


Rainfall Model	FSR	Ratio R	0.401
Region	England and Wales	Cv (Summer)	0.750
M5-60 (mm)	19.600	Cv (Winter)	0.840

Margin for Flood Risk Warning (mm) 300.0
Analysis Timestep 2.5 Second Increment (Extended)
DTS Status OFF
DVD Status OFF
Inertia Status OFF

Profile(s) Summer and Winter
Duration(s) (mins) 15, 30, 60, 120, 180, 240, 360, 480, 600, 720, 960, 1440
Return Period(s) (years) 1, 30, 100
Climate Change (%) 0, 0, 40

PN	US/MH Name	Storm Rank	Water	Surcharged	Flooded	Pipe		Status
			Level (m)	Depth (m)	Volume (m³)	Flow / Overflow (l/s)	Flow (l/s)	
1.000	S4	67	113.871	-0.204	0.000	0.02	1.5	OK
1.001	S5	67	112.670	-0.205	0.000	0.02	1.7	OK
1.002	S6	67	111.956	-0.189	0.000	0.06	2.2	OK
1.003	S7	67	111.664	-0.351	0.000	0.01	4.0	OK
2.000	S1	67	113.343	-0.332	0.000	0.03	6.8	OK
2.001	S2	67	112.682	-0.333	0.000	0.03	8.9	OK
2.002	S3	67	111.504	-0.401	0.000	0.03	10.1	OK
1.004	S8	67	111.084	-0.366	0.000	0.08	15.6	OK
1.005	S9	67	110.918	-0.391	0.000	0.04	18.3	OK
1.006	S10	67	110.219	-0.400	0.000	0.03	18.7	OK
1.007	S11	67	108.758	-0.542	0.000	0.02	22.5	OK
1.008	S12	67	107.036	-0.514	0.000	0.05	24.6	OK
3.000	S13	67	110.609	-0.216	0.000	0.01	0.8	OK
3.001	S14	67	109.487	-0.278	0.000	0.02	2.7	OK
3.002	S15	67	108.780	-0.280	0.000	0.01	3.5	OK

©1982-2019 Innovyze

PJS Consulting Engineers Limited		Page 96
Unit 4 Winking Hill Farm Kingston-on-Soar, Nottingham Nottinghamshire NG11 0DP		
Lutterworth Road Burbage		
Date 29/06/2023 13:54 File SW Model 17.05.23.mdx		
Designed by matt.leask Checked by		
Innovyze		Network 2019.1

Summary Wizard of 720 minute 1 year Winter I+0% for Surface Water Network

Simulation Criteria

Areal Reduction Factor	1.000	Additional Flow - % of Total Flow	0.000
Hot Start (mins)	0	MADD Factor * 10m³/ha Storage	0.000
Hot Start Level (mm)	0	Inlet Coefficient	0.800
Manhole Headloss Coeff (Global)	0.500	Flow per Person per Day (l/per/day)	0.000
Foul Sewage per hectare (l/s)	0.000		

Number of Input Hydrographs 0 Number of Offline Controls 5 Number of Time/Area Diagrams 0
Number of Online Controls 3 Number of Storage Structures 2 Number of Real Time Controls 0

Synthetic Rainfall Details

Rainfall Model	FSR	Ratio R	0.401
Region	England and Wales	Cv (Summer)	0.750
M5-60 (mm)	19.600	Cv (Winter)	0.840

Margin for Flood Risk Warning (mm) 300.0
Analysis Timestep 2.5 Second Increment (Extended)
DTS Status OFF
DVD Status OFF
Inertia Status OFF

Profile(s) Summer and Winter
Duration(s) (mins) 15, 30, 60, 120, 180, 240, 360, 480, 600, 720, 960, 1440
Return Period(s) (years) 1, 30, 100
Climate Change (%) 0, 0, 40

PN	US/MH Name	Storm Rank	Water	Surcharged	Flooded	Flow / Overflow (l/s)	Pipe	Status
			Level (m)	Depth (m)	Volume (m³)		Flow (l/s)	
1.000	S4	69	113.869	-0.206	0.000	0.02	1.4	OK
1.001	S5	69	112.668	-0.207	0.000	0.02	1.5	OK
1.002	S6	69	111.953	-0.192	0.000	0.05	1.9	OK
1.003	S7	69	111.661	-0.354	0.000	0.01	3.5	OK
2.000	S1	69	113.340	-0.335	0.000	0.03	6.0	OK
2.001	S2	69	112.680	-0.335	0.000	0.03	7.8	OK
2.002	S3	69	111.501	-0.404	0.000	0.02	8.9	OK
1.004	S8	69	111.078	-0.372	0.000	0.07	13.7	OK
1.005	S9	69	110.914	-0.395	0.000	0.04	16.1	OK
1.006	S10	69	110.217	-0.402	0.000	0.03	16.4	OK
1.007	S11	69	108.750	-0.550	0.000	0.02	19.7	OK
1.008	S12	69	107.031	-0.519	0.000	0.04	21.6	OK
3.000	S13	69	110.608	-0.217	0.000	0.01	0.7	OK
3.001	S14	69	109.484	-0.281	0.000	0.01	2.4	OK
3.002	S15	69	108.778	-0.282	0.000	0.01	3.1	OK

PJS Consulting Engineers Limited

Unit 4 Winking Hill Farm
Kingston-on-Soar, Nottingham
Nottinghamshire NG11 0DP

Date 29/06/2023 13:54
File SW Model 17.05.23.mdx

Innovyze

Lutterworth Road
Burbage

Designed by matt.leask
Checked by

Network 2019.1

Page 98



Summary Wizard of 960 minute 1 year Winter I+0% for Surface Water Network

Simulation Criteria

Areal Reduction Factor 1.000

Hot Start (mins) 0

Hot Start Level (mm) 0

Manhole Headloss Coeff (Global) 0.500

Foul Sewage per hectare (l/s) 0.000

Additional Flow - % of Total Flow 0.000

MADD Factor * 10m³/ha Storage 0.000

Inlet Coeffiecient 0.800

Flow per Person per Day (l/per/day) 0.000

Number of Input Hydrographs 0

Number of Offline Controls 5

Number of Time/Area Diagrams 0

Number of Online Controls 3

Number of Storage Structures 2

Number of Real Time Controls 0

Synthetic Rainfall Details

Rainfall Model FSR

Region England and Wales Cv (Summer) 0.750

M5-60 (mm) 19.600

Ratio R 0.401

Cv (Winter) 0.840

Margin for Flood Risk Warning (mm) 300.0

Analysis Timestep 2.5 Second Increment (Extended)

DTS Status OFF

DVD Status OFF

Inertia Status OFF

Profile(s) Summer and Winter

Duration(s) (mins) 15, 30, 60, 120, 180, 240, 360, 480, 600, 720, 960, 1440

Return Period(s) (years) 1, 30, 100

Climate Change (%) 0, 0, 40

Water

US/MH

Storm

Level

Depth

Volume

Flow /

Overflow

Pipe

Flow

Status

PN

Name

Rank

(m)

(m)

(m³)

Cap.

(l/s)

(l/s)

1.000

S4

71

113.865

-0.210

0.000

0.01

1.1

OK

1.001

S5

71

112.664

-0.211

0.000

0.01

1.2

OK

1.002

S6

71

111.950

-0.195

0.000

0.04

1.6

OK

1.003

S7

71

111.657

-0.358

0.000

0.01

2.9

OK

2.000

S1

71

113.338

-0.337

0.000

0.02

4.8

OK

2.001

S2

71

112.677

-0.338

0.000

0.02

6.3

OK

2.002

S3

71

111.495

-0.410

0.000

0.02

7.2

OK

1.004

S8

71

111.069

-0.381

0.000

0.06

11.1

OK

1.005

S9

71

110.910

-0.399

0.000

0.03

13.0

OK

1.006

S10

71

110.213

-0.406

0.000

0.02

13.3

OK

1.007

S11

71

108.741

-0.559

0.000

0.01

15.9

OK

1.008

S12

71

107.023

-0.527

0.000

0.04

17.5

OK

3.000

S13

71

110.607

-0.218

0.000

0.01

0.6

OK

3.001

S14

71

109.480

-0.285

0.000

0.01

1.9

OK

3.002

S15

71

108.774

-0.286


0.000

0.01

2.5

OK

©1982-2019 Innovyze

PJS Consulting Engineers Limited		Page 100
Unit 4 Winking Hill Farm Kingston-on-Soar, Nottingham Nottinghamshire NG11 0DP		
Lutterworth Road Burbage		
Date 29/06/2023 13:54 File SW Model 17.05.23.mdx		
Designed by matt.leask Checked by		
Innovyze		Network 2019.1

Summary Wizard of 1440 minute 1 year Winter I+0% for Surface Water Network

Simulation Criteria

Areal Reduction Factor	1.000	Additional Flow - % of Total Flow	0.000
Hot Start (mins)	0	MADD Factor * 10m³/ha Storage	0.000
Hot Start Level (mm)	0	Inlet Coefficient	0.800
Manhole Headloss Coeff (Global)	0.500	Flow per Person per Day (l/per/day)	0.000
Foul Sewage per hectare (l/s)	0.000		

Number of Input Hydrographs	0	Number of Offline Controls	5	Number of Time/Area Diagrams	0
Number of Online Controls	3	Number of Storage Structures	2	Number of Real Time Controls	0

Synthetic Rainfall Details

Rainfall Model	FSR	Ratio R	0.401
Region	England and Wales	Cv (Summer)	0.750
M5-60 (mm)	19.600	Cv (Winter)	0.840

Margin for Flood Risk Warning (mm)	300.0
Analysis Timestep	2.5 Second Increment (Extended)
DTS Status	OFF
DVD Status	OFF
Inertia Status	OFF

Profile(s)	Summer and Winter
Duration(s) (mins)	15, 30, 60, 120, 180, 240, 360, 480, 600, 720, 960, 1440
Return Period(s) (years)	1, 30, 100
Climate Change (%)	0, 0, 40

PN	US/MH Name	Storm Rank	Water Level (m)	Surcharged Depth (m)	Flooded Volume (m³)	Flow / Overflow Cap.	Pipe Flow (l/s)	Status
1.000	S4	72	113.861	-0.214	0.000	0.01	0.8	OK
1.001	S5	72	112.661	-0.214	0.000	0.01	0.9	OK
1.002	S6	72	111.946	-0.199	0.000	0.03	1.2	OK
1.003	S7	72	111.653	-0.362	0.000	0.01	2.1	OK
2.000	S1	72	113.328	-0.347	0.000	0.02	3.6	OK
2.001	S2	72	112.667	-0.348	0.000	0.02	4.7	OK
2.002	S3	72	111.485	-0.420	0.000	0.01	5.3	OK
1.004	S8	72	111.059	-0.391	0.000	0.04	8.2	OK
1.005	S9	72	110.905	-0.404	0.000	0.02	9.7	OK
1.006	S10	72	110.201	-0.418	0.000	0.02	9.9	OK
1.007	S11	72	108.730	-0.570	0.000	0.01	11.9	OK
1.008	S12	72	107.015	-0.535	0.000	0.03	13.0	OK
3.000	S13	72	110.605	-0.220	0.000	0.00	0.4	OK
3.001	S14	72	109.477	-0.288	0.000	0.01	1.4	OK
3.002	S15	72	108.771	-0.289	0.000	0.01	1.9	OK


©1982-2019 Innovyze

PJS Consulting Engineers Limited							Page 102																																																																																																																																																																									
Unit 4 Winking Hill Farm Kingston-on-Soar, Nottingham Nottinghamshire NG11 0DP				Lutterworth Road Burbage																																																																																																																																																																												
Date 29/06/2023 13:54				Designed by matt.leask																																																																																																																																																																												
File SW Model 17.05.23.mdx				Checked by																																																																																																																																																																												
Innovyze				Network 2019.1																																																																																																																																																																												
<u>Summary Wizard of 15 minute 30 year Winter I+0% for Surface Water Network</u>																																																																																																																																																																																
<u>Simulation Criteria</u>																																																																																																																																																																																
Areal Reduction Factor		1.000		Additional Flow - % of Total Flow		0.000																																																																																																																																																																										
Hot Start (mins)		0		MADD Factor * 10m³/ha Storage		0.000																																																																																																																																																																										
Hot Start Level (mm)		0		Inlet Coefficient		0.800																																																																																																																																																																										
Manhole Headloss Coeff (Global)		0.500		Flow per Person per Day (l/per/day)		0.000																																																																																																																																																																										
Foul Sewage per hectare (l/s)		0.000																																																																																																																																																																														
Number of Input Hydrographs		0		Number of Offline Controls		5		Number of Time/Area Diagrams		0																																																																																																																																																																						
Number of Online Controls		3		Number of Storage Structures		2		Number of Real Time Controls 0																																																																																																																																																																								
<u>Synthetic Rainfall Details</u>																																																																																																																																																																																
Rainfall Model		FSR		Ratio R		0.401																																																																																																																																																																										
Region		England and Wales		Cv (Summer)		0.750																																																																																																																																																																										
M5-60 (mm)		19.600		Cv (Winter)		0.840																																																																																																																																																																										
Margin for Flood Risk Warning (mm)						300.0																																																																																																																																																																										
Analysis Timestep		2.5		Second Increment (Extended)																																																																																																																																																																												
DTS Status						OFF																																																																																																																																																																										
DVD Status						OFF																																																																																																																																																																										
Inertia Status						OFF																																																																																																																																																																										
Profile(s)						Summer and Winter																																																																																																																																																																										
Duration(s) (mins)		15, 30, 60, 120, 180, 240, 360, 480, 600, 720,				960, 1440																																																																																																																																																																										
Return Period(s) (years)						1, 30, 100																																																																																																																																																																										
Climate Change (%)						0, 0, 40																																																																																																																																																																										
<table><tr><th rowspan="2">PN</th><th rowspan="2">US/MH Name</th><th rowspan="2">Storm Rank</th><th>Water Level</th><th>Surcharged Depth</th><th>Flooded Volume</th><th>Flow / Cap.</th><th>Overflow</th><th>Pipe Flow</th><th rowspan="2">Status</th></tr><tr><th>(m)</th><th>(m)</th><th>(m³)</th><th>(l/s)</th><th>(l/s)</th><th>(l/s)</th></tr><tr><td>1.000</td><td>S4</td><td>6</td><td>113.958</td><td>-0.117</td><td>0.000</td><td>0.45</td><td></td><td>35.2</td><td>OK</td></tr><tr><td>1.001</td><td>S5</td><td>6</td><td>112.755</td><td>-0.120</td><td>0.000</td><td>0.43</td><td></td><td>39.4</td><td>OK</td></tr><tr><td>1.002</td><td>S6</td><td>6</td><td>112.261</td><td>0.116</td><td>0.000</td><td>1.40</td><td></td><td>50.6</td><td>SURCHARGED</td></tr><tr><td>1.003</td><td>S7</td><td>6</td><td>111.807</td><td>-0.208</td><td>0.000</td><td>0.31</td><td></td><td>92.1</td><td>OK</td></tr><tr><td>2.000</td><td>S1</td><td>6</td><td>113.534</td><td>-0.141</td><td>0.000</td><td>0.69</td><td></td><td>156.3</td><td>OK</td></tr><tr><td>2.001</td><td>S2</td><td>6</td><td>112.871</td><td>-0.144</td><td>0.000</td><td>0.68</td><td></td><td>204.2</td><td>OK</td></tr><tr><td>2.002</td><td>S3</td><td>6</td><td>111.938</td><td>0.033</td><td>0.000</td><td>0.61</td><td></td><td>232.1</td><td>SURCHARGED</td></tr><tr><td>1.004</td><td>S8</td><td>6</td><td>111.763</td><td>0.313</td><td>0.000</td><td>1.82</td><td></td><td>354.9</td><td>SURCHARGED</td></tr><tr><td>1.005</td><td>S9</td><td>6</td><td>111.205</td><td>-0.104</td><td>0.000</td><td>0.94</td><td></td><td>412.6</td><td>OK</td></tr><tr><td>1.006</td><td>S10</td><td>6</td><td>110.434</td><td>-0.185</td><td>0.000</td><td>0.65</td><td></td><td>419.5</td><td>OK</td></tr><tr><td>1.007</td><td>S11</td><td>6</td><td>108.985</td><td>-0.315</td><td>0.000</td><td>0.45</td><td></td><td>498.8</td><td>OK</td></tr><tr><td>1.008</td><td>S12</td><td>7</td><td>108.277</td><td>0.727</td><td>0.000</td><td>1.07</td><td></td><td>519.3</td><td>SURCHARGED</td></tr><tr><td>3.000</td><td>S13</td><td>6</td><td>110.669</td><td>-0.156</td><td>0.000</td><td>0.20</td><td></td><td>18.4</td><td>OK</td></tr><tr><td>3.001</td><td>S14</td><td>6</td><td>109.592</td><td>-0.173</td><td>0.000</td><td>0.37</td><td></td><td>65.5</td><td>OK</td></tr><tr><td>3.002</td><td>S15</td><td>6</td><td>108.882</td><td>-0.178</td><td>0.000</td><td>0.34</td><td></td><td>85.4</td><td>OK</td></tr></table>											PN	US/MH Name	Storm Rank	Water Level	Surcharged Depth	Flooded Volume	Flow / Cap.	Overflow	Pipe Flow	Status	(m)	(m)	(m³)	(l/s)	(l/s)	(l/s)	1.000	S4	6	113.958	-0.117	0.000	0.45		35.2	OK	1.001	S5	6	112.755	-0.120	0.000	0.43		39.4	OK	1.002	S6	6	112.261	0.116	0.000	1.40		50.6	SURCHARGED	1.003	S7	6	111.807	-0.208	0.000	0.31		92.1	OK	2.000	S1	6	113.534	-0.141	0.000	0.69		156.3	OK	2.001	S2	6	112.871	-0.144	0.000	0.68		204.2	OK	2.002	S3	6	111.938	0.033	0.000	0.61		232.1	SURCHARGED	1.004	S8	6	111.763	0.313	0.000	1.82		354.9	SURCHARGED	1.005	S9	6	111.205	-0.104	0.000	0.94		412.6	OK	1.006	S10	6	110.434	-0.185	0.000	0.65		419.5	OK	1.007	S11	6	108.985	-0.315	0.000	0.45		498.8	OK	1.008	S12	7	108.277	0.727	0.000	1.07		519.3	SURCHARGED	3.000	S13	6	110.669	-0.156	0.000	0.20		18.4	OK	3.001	S14	6	109.592	-0.173	0.000	0.37		65.5	OK	3.002	S15	6	108.882	-0.178	0.000	0.34		85.4	OK
PN	US/MH Name	Storm Rank	Water Level	Surcharged Depth	Flooded Volume	Flow / Cap.	Overflow	Pipe Flow	Status																																																																																																																																																																							
			(m)	(m)	(m³)	(l/s)	(l/s)	(l/s)																																																																																																																																																																								
1.000	S4	6	113.958	-0.117	0.000	0.45		35.2	OK																																																																																																																																																																							
1.001	S5	6	112.755	-0.120	0.000	0.43		39.4	OK																																																																																																																																																																							
1.002	S6	6	112.261	0.116	0.000	1.40		50.6	SURCHARGED																																																																																																																																																																							
1.003	S7	6	111.807	-0.208	0.000	0.31		92.1	OK																																																																																																																																																																							
2.000	S1	6	113.534	-0.141	0.000	0.69		156.3	OK																																																																																																																																																																							
2.001	S2	6	112.871	-0.144	0.000	0.68		204.2	OK																																																																																																																																																																							
2.002	S3	6	111.938	0.033	0.000	0.61		232.1	SURCHARGED																																																																																																																																																																							
1.004	S8	6	111.763	0.313	0.000	1.82		354.9	SURCHARGED																																																																																																																																																																							
1.005	S9	6	111.205	-0.104	0.000	0.94		412.6	OK																																																																																																																																																																							
1.006	S10	6	110.434	-0.185	0.000	0.65		419.5	OK																																																																																																																																																																							
1.007	S11	6	108.985	-0.315	0.000	0.45		498.8	OK																																																																																																																																																																							
1.008	S12	7	108.277	0.727	0.000	1.07		519.3	SURCHARGED																																																																																																																																																																							
3.000	S13	6	110.669	-0.156	0.000	0.20		18.4	OK																																																																																																																																																																							
3.001	S14	6	109.592	-0.173	0.000	0.37		65.5	OK																																																																																																																																																																							
3.002	S15	6	108.882	-0.178	0.000	0.34		85.4	OK																																																																																																																																																																							
©1982-2019 Innovyze																																																																																																																																																																																

PJS Consulting Engineers Limited		Page 105
Unit 4 Winking Hill Farm Kingston-on-Soar, Nottingham Nottinghamshire NG11 0DP	Lutterworth Road Burbage	
Date 29/06/2023 13:54 File SW Model 17.05.23.mdx	Designed by matt.leask Checked by	
Innovyze	Network 2019.1	

Summary Wizard of 30 minute 30 year Winter I+0% for Surface Water Network

PN	US/MH Name	Storm Rank	Water Level (m)	Surcharged Depth (m)	Flooded Volume (m³)	Flow / Cap. (l/s)	Overflow (l/s)	Pipe Flow (l/s)	Status
1.009	S16	11	107.704	0.390	0.000	1.86		493.6	SURCHARGED
1.010	S17	11	107.453	0.210	0.000	2.32		499.9	SURCHARGED
1.011	S18	23	107.306	0.088	0.000	1.67		498.1	SURCHARGED
4.000	S38	10	111.691	-0.619	0.000	0.02		48.4	OK
4.001	S39	10	111.252	-0.608	0.000	0.03	4.9	43.5	OK
4.002	S40	10	111.208	-0.622	0.000	0.01	3.5	40.0	OK
4.003	S41	11	111.107	-0.433	0.000	0.00	20.5	20.5	OK
4.004	S42	11	109.205	-0.635	0.000	0.01	2.3	35.4	OK
4.005	S43	11	108.163	-0.487	0.000	0.00	17.4	17.4	OK
1.012	S32	27	107.181	0.007	0.000	0.92		513.9	SURCHARGED
5.000	S22	10	111.882	-0.113	0.000	0.50		32.8	OK
5.001	S23	10	111.178	-0.057	0.000	0.91		32.7	OK
5.002	S24	10	111.091	-0.079	0.000	0.88		87.3	OK
5.003	S25	10	110.776	-0.239	0.000	0.28		96.6	OK
5.004	S26	10	109.581	-0.244	0.000	0.26		127.4	OK
5.005	S27	11	107.581	0.461	0.000	1.34		143.3	SURCHARGED
5.006	S28	11	107.460	0.398	0.000	1.77		149.8	SURCHARGED
5.007	S29	18	107.345	0.326	0.000	1.17		153.5	SURCHARGED
5.008	S30	24	107.282	0.318	0.000	1.16		161.9	SURCHARGED
5.009	S31	26	107.193	0.310	0.000	1.28		186.5	SURCHARGED
1.013	S33	26	107.077	0.098	0.000	1.36		467.1	SURCHARGED
1.014	S34	26	106.946	0.017	0.000	1.09		466.0	SURCHARGED
1.015	S35	45	106.668	-0.107	0.000	0.05		21.9	OK
1.016	S36	45	106.188	-0.087	0.000	0.69		21.9	OK

PJS Consulting Engineers Limited		Page 106
Unit 4 Winking Hill Farm Kingston-on-Soar, Nottingham Nottinghamshire NG11 ODP		
Lutterworth Road Burbage		
Date 29/06/2023 13:54 File SW Model 17.05.23.mdx		
Designed by matt.leask Checked by		
Innovyze		Network 2019.1

Summary Wizard of 60 minute 30 year Winter I+0% for Surface Water Network

Simulation Criteria

Areal Reduction Factor 1.000	Additional Flow - % of Total Flow 0.000
Hot Start (mins) 0	MADD Factor * 10m³/ha Storage 0.000
Hot Start Level (mm) 0	Inlet Coefficient 0.800
Manhole Headloss Coeff (Global) 0.500	Flow per Person per Day (l/per/day) 0.000
Foul Sewage per hectare (l/s) 0.000	

Number of Input Hydrographs 0	Number of Offline Controls 5	Number of Time/Area Diagrams 0
Number of Online Controls 3	Number of Storage Structures 2	Number of Real Time Controls 0

Synthetic Rainfall Details


Rainfall Model	FSR	Ratio R 0.401
Region England and Wales Cv (Summer)	0.750	
M5-60 (mm)	19.600	Cv (Winter) 0.840

Margin for Flood Risk Warning (mm)	300.0
Analysis Timestep 2.5 Second Increment (Extended)	
DTS Status	OFF
DVD Status	OFF
Inertia Status	OFF

Profile(s)	Summer and Winter
Duration(s) (mins)	15, 30, 60, 120, 180, 240, 360, 480, 600, 720, 960, 1440
Return Period(s) (years)	1, 30, 100
Climate Change (%)	0, 0, 40

PN	US/MH Name	Storm Rank	Water	Surcharged	Flooded	Pipe		Status
			Level (m)	Depth (m)	Volume (m³)	Flow / Overflow (l/s)	Flow (l/s)	
1.000	S4	15	113.924	-0.151	0.000	0.24	18.5	OK
1.001	S5	15	112.722	-0.153	0.000	0.23	20.7	OK
1.002	S6	15	112.063	-0.082	0.000	0.73	26.2	OK
1.003	S7	15	111.741	-0.274	0.000	0.16	48.2	OK
2.000	S1	15	113.455	-0.220	0.000	0.36	81.5	OK
2.001	S2	15	112.793	-0.222	0.000	0.35	105.8	OK
2.002	S3	15	111.629	-0.276	0.000	0.32	120.9	OK
1.004	S8	15	111.348	-0.102	0.000	0.96	186.3	OK
1.005	S9	15	111.083	-0.226	0.000	0.50	218.4	OK
1.006	S10	15	110.351	-0.268	0.000	0.34	222.8	OK
1.007	S11	15	108.899	-0.401	0.000	0.24	266.9	OK
1.008	S12	19	107.435	-0.115	0.000	0.60	292.3	OK
3.000	S13	15	110.648	-0.177	0.000	0.10	9.5	OK
3.001	S14	15	109.552	-0.213	0.000	0.18	32.4	OK
3.002	S15	15	108.843	-0.217	0.000	0.17	42.1	OK

©1982-2019 Innovyze

PJS Consulting Engineers Limited		Page 108
Unit 4 Winking Hill Farm Kingston-on-Soar, Nottingham Nottinghamshire NG11 0DP		
Lutterworth Road Burbage		
Date 29/06/2023 13:54 File SW Model 17.05.23.mdx		
Designed by matt.leask Checked by		
Innovyze		Network 2019.1

Summary Wizard of 120 minute 30 year Winter I+0% for Surface Water Network

Simulation Criteria

Areal Reduction Factor	1.000	Additional Flow - % of Total Flow	0.000
Hot Start (mins)	0	MADD Factor * 10m³/ha Storage	0.000
Hot Start Level (mm)	0	Inlet Coefficient	0.800
Manhole Headloss Coeff (Global)	0.500	Flow per Person per Day (l/per/day)	0.000
Foul Sewage per hectare (l/s)	0.000		

Number of Input Hydrographs 0 Number of Offline Controls 5 Number of Time/Area Diagrams 0
Number of Online Controls 3 Number of Storage Structures 2 Number of Real Time Controls 0

Synthetic Rainfall Details

Rainfall Model	FSR	Ratio R	0.401
Region	England and Wales	Cv (Summer)	0.750
M5-60 (mm)	19.600	Cv (Winter)	0.840

Margin for Flood Risk Warning (mm) 300.0
Analysis Timestep 2.5 Second Increment (Extended)
DTS Status OFF
DVD Status OFF
Inertia Status OFF

Profile(s)

Duration(s) (mins)	15, 30, 60, 120, 180, 240, 360, 480, 600, 720, 960, 1440
Return Period(s) (years)	1, 30, 100
Climate Change (%)	0, 0, 40

PN	US/MH Name	Storm Rank	Water	Surcharged	Flooded	Pipe		Status
			Level (m)	Depth (m)	Volume (m³)	Flow / Overflow (l/s)	Flow (l/s)	
1.000	S4	25	113.907	-0.168	0.000	0.15	11.4	OK
1.001	S5	25	112.706	-0.169	0.000	0.14	12.8	OK
1.002	S6	25	112.025	-0.120	0.000	0.45	16.2	OK
1.003	S7	25	111.719	-0.296	0.000	0.10	29.8	OK
2.000	S1	25	113.419	-0.256	0.000	0.22	50.3	OK
2.001	S2	25	112.758	-0.257	0.000	0.22	65.3	OK
2.002	S3	25	111.590	-0.315	0.000	0.20	74.6	OK
1.004	S8	25	111.249	-0.201	0.000	0.59	115.2	OK
1.005	S9	25	111.029	-0.280	0.000	0.31	135.1	OK
1.006	S10	25	110.309	-0.310	0.000	0.21	137.9	OK
1.007	S11	25	108.854	-0.446	0.000	0.15	165.4	OK
1.008	S12	34	107.218	-0.332	0.000	0.37	181.1	OK
3.000	S13	25	110.637	-0.188	0.000	0.06	5.9	OK
3.001	S14	25	109.532	-0.233	0.000	0.11	20.0	OK
3.002	S15	24	108.825	-0.235	0.000	0.10	26.0	OK

©1982-2019 Innovyze

PJS Consulting Engineers Limited							Page 110																																																																																																																																																						
Unit 4 Winking Hill Farm Kingston-on-Soar, Nottingham Nottinghamshire NG11 0DP				Lutterworth Road Burbage																																																																																																																																																									
Date 29/06/2023 13:54				Designed by matt.leask																																																																																																																																																									
File SW Model 17.05.23.mdx				Checked by																																																																																																																																																									
Innovyze				Network 2019.1																																																																																																																																																									
<u>Summary Wizard of 180 minute 30 year Winter I+0% for Surface Water Network</u>																																																																																																																																																													
<u>Simulation Criteria</u>																																																																																																																																																													
Areal Reduction Factor		1.000		Additional Flow - % of Total Flow		0.000																																																																																																																																																							
Hot Start (mins)		0		MADD Factor * 10m³/ha Storage		0.000																																																																																																																																																							
Hot Start Level (mm)		0		Inlet Coefficient		0.800																																																																																																																																																							
Manhole Headloss Coeff (Global)		0.500		Flow per Person per Day (l/per/day)		0.000																																																																																																																																																							
Foul Sewage per hectare (l/s)		0.000																																																																																																																																																											
Number of Input Hydrographs			0			Number of Offline Controls																																																																																																																																																							
			5			Number of Time/Area Diagrams																																																																																																																																																							
			0																																																																																																																																																										
Number of Online Controls			3			Number of Storage Structures																																																																																																																																																							
			2			Number of Real Time Controls																																																																																																																																																							
			0																																																																																																																																																										
<u>Synthetic Rainfall Details</u>																																																																																																																																																													
Rainfall Model		FSR		Ratio R		0.401																																																																																																																																																							
Region		England and Wales		Cv (Summer)		0.750																																																																																																																																																							
M5-60 (mm)		19.600		Cv (Winter)		0.840																																																																																																																																																							
Margin for Flood Risk Warning (mm)						300.0																																																																																																																																																							
Analysis Timestep		2.5		Second Increment (Extended)																																																																																																																																																									
DTS Status						OFF																																																																																																																																																							
DVD Status						OFF																																																																																																																																																							
Inertia Status						OFF																																																																																																																																																							
Profile(s)						Summer and Winter																																																																																																																																																							
Duration(s) (mins)		15, 30, 60, 120, 180, 240, 360, 480, 600, 720, 960, 1440																																																																																																																																																											
Return Period(s) (years)		1, 30, 100																																																																																																																																																											
Climate Change (%)		0, 0, 40																																																																																																																																																											
<table><tr><th rowspan="2">PN</th><th rowspan="2">US/MH Name</th><th rowspan="2">Storm Rank</th><th>Water Level</th><th>Surcharged Depth</th><th>Flooded Volume</th><th>Flow / Overflow</th><th>Pipe Flow</th><th rowspan="2">Status</th></tr><tr><th>(m)</th><th>(m)</th><th>(m³)</th><th>Cap. (l/s)</th><th>(l/s)</th></tr><tr><td>1.000</td><td>S4</td><td>31</td><td>113.899</td><td>-0.176</td><td>0.000</td><td>0.11</td><td>8.5</td><td>OK</td></tr><tr><td>1.001</td><td>S5</td><td>31</td><td>112.698</td><td>-0.177</td><td>0.000</td><td>0.10</td><td>9.5</td><td>OK</td></tr><tr><td>1.002</td><td>S6</td><td>31</td><td>112.009</td><td>-0.136</td><td>0.000</td><td>0.33</td><td>12.0</td><td>OK</td></tr><tr><td>1.003</td><td>S7</td><td>31</td><td>111.707</td><td>-0.308</td><td>0.000</td><td>0.07</td><td>22.1</td><td>OK</td></tr><tr><td>2.000</td><td>S1</td><td>31</td><td>113.401</td><td>-0.274</td><td>0.000</td><td>0.17</td><td>37.3</td><td>OK</td></tr><tr><td>2.001</td><td>S2</td><td>31</td><td>112.740</td><td>-0.275</td><td>0.000</td><td>0.16</td><td>48.4</td><td>OK</td></tr><tr><td>2.002</td><td>S3</td><td>31</td><td>111.569</td><td>-0.336</td><td>0.000</td><td>0.15</td><td>55.3</td><td>OK</td></tr><tr><td>1.004</td><td>S8</td><td>31</td><td>111.208</td><td>-0.242</td><td>0.000</td><td>0.44</td><td>85.4</td><td>OK</td></tr><tr><td>1.005</td><td>S9</td><td>31</td><td>111.004</td><td>-0.305</td><td>0.000</td><td>0.23</td><td>100.2</td><td>OK</td></tr><tr><td>1.006</td><td>S10</td><td>31</td><td>110.288</td><td>-0.331</td><td>0.000</td><td>0.16</td><td>102.2</td><td>OK</td></tr><tr><td>1.007</td><td>S11</td><td>31</td><td>108.832</td><td>-0.468</td><td>0.000</td><td>0.11</td><td>122.7</td><td>OK</td></tr><tr><td>1.008</td><td>S12</td><td>40</td><td>107.164</td><td>-0.386</td><td>0.000</td><td>0.28</td><td>134.4</td><td>OK</td></tr><tr><td>3.000</td><td>S13</td><td>31</td><td>110.631</td><td>-0.194</td><td>0.000</td><td>0.05</td><td>4.3</td><td>OK</td></tr><tr><td>3.001</td><td>S14</td><td>31</td><td>109.523</td><td>-0.242</td><td>0.000</td><td>0.08</td><td>14.8</td><td>OK</td></tr><tr><td>3.002</td><td>S15</td><td>31</td><td>108.815</td><td>-0.245</td><td>0.000</td><td>0.08</td><td>19.2</td><td>OK</td></tr></table>									PN	US/MH Name	Storm Rank	Water Level	Surcharged Depth	Flooded Volume	Flow / Overflow	Pipe Flow	Status	(m)	(m)	(m³)	Cap. (l/s)	(l/s)	1.000	S4	31	113.899	-0.176	0.000	0.11	8.5	OK	1.001	S5	31	112.698	-0.177	0.000	0.10	9.5	OK	1.002	S6	31	112.009	-0.136	0.000	0.33	12.0	OK	1.003	S7	31	111.707	-0.308	0.000	0.07	22.1	OK	2.000	S1	31	113.401	-0.274	0.000	0.17	37.3	OK	2.001	S2	31	112.740	-0.275	0.000	0.16	48.4	OK	2.002	S3	31	111.569	-0.336	0.000	0.15	55.3	OK	1.004	S8	31	111.208	-0.242	0.000	0.44	85.4	OK	1.005	S9	31	111.004	-0.305	0.000	0.23	100.2	OK	1.006	S10	31	110.288	-0.331	0.000	0.16	102.2	OK	1.007	S11	31	108.832	-0.468	0.000	0.11	122.7	OK	1.008	S12	40	107.164	-0.386	0.000	0.28	134.4	OK	3.000	S13	31	110.631	-0.194	0.000	0.05	4.3	OK	3.001	S14	31	109.523	-0.242	0.000	0.08	14.8	OK	3.002	S15	31	108.815	-0.245	0.000	0.08	19.2	OK
PN	US/MH Name	Storm Rank	Water Level	Surcharged Depth	Flooded Volume	Flow / Overflow	Pipe Flow	Status																																																																																																																																																					
			(m)	(m)	(m³)	Cap. (l/s)	(l/s)																																																																																																																																																						
1.000	S4	31	113.899	-0.176	0.000	0.11	8.5	OK																																																																																																																																																					
1.001	S5	31	112.698	-0.177	0.000	0.10	9.5	OK																																																																																																																																																					
1.002	S6	31	112.009	-0.136	0.000	0.33	12.0	OK																																																																																																																																																					
1.003	S7	31	111.707	-0.308	0.000	0.07	22.1	OK																																																																																																																																																					
2.000	S1	31	113.401	-0.274	0.000	0.17	37.3	OK																																																																																																																																																					
2.001	S2	31	112.740	-0.275	0.000	0.16	48.4	OK																																																																																																																																																					
2.002	S3	31	111.569	-0.336	0.000	0.15	55.3	OK																																																																																																																																																					
1.004	S8	31	111.208	-0.242	0.000	0.44	85.4	OK																																																																																																																																																					
1.005	S9	31	111.004	-0.305	0.000	0.23	100.2	OK																																																																																																																																																					
1.006	S10	31	110.288	-0.331	0.000	0.16	102.2	OK																																																																																																																																																					
1.007	S11	31	108.832	-0.468	0.000	0.11	122.7	OK																																																																																																																																																					
1.008	S12	40	107.164	-0.386	0.000	0.28	134.4	OK																																																																																																																																																					
3.000	S13	31	110.631	-0.194	0.000	0.05	4.3	OK																																																																																																																																																					
3.001	S14	31	109.523	-0.242	0.000	0.08	14.8	OK																																																																																																																																																					
3.002	S15	31	108.815	-0.245	0.000	0.08	19.2	OK																																																																																																																																																					
©1982-2019 Innovyze																																																																																																																																																													

PJS Consulting Engineers Limited

Unit 4 Winking Hill Farm
Kingston-on-Soar, Nottingham
Nottinghamshire NG11 0DP

Date 29/06/2023 13:54
File SW Model 17.05.23.mdx

Innovyze

Lutterworth Road
Burbage

Designed by matt.leask
Checked by

Network 2019.1


Page 111



Summary Wizard of 180 minute 30 year Winter I+0% for Surface Water Network

PN	US/MH Name	Storm Rank	Water Level (m)	Surcharged Depth (m)	Flooded Volume (m³)	Flow / Cap.	Overflow (l/s)	Pipe Flow (l/s)	Status
1.009	S16	40	107.082	-0.232	0.000	0.60		158.1	OK
1.010	S17	40	107.003	-0.240	0.000	0.74		159.9	OK
1.011	S18	40	106.895	-0.323	0.000	0.54		159.8	OK
4.000	S38	31	111.640	-0.670	0.000	0.00		14.7	OK
4.001	S39	31	111.200	-0.660	0.000	0.01	0.9	13.8	OK
4.002	S40	31	111.160	-0.670	0.000	0.00	0.5	13.3	OK
4.003	S41	31	110.965	-0.575	0.000	0.00	7.6	7.6	OK
4.004	S42	31	109.163	-0.677	0.000	0.00	0.3	12.9	OK
4.005	S43	31	108.062	-0.588	0.000	0.00	6.5	6.5	OK
1.012	S32	34	106.876	-0.298	0.000	0.31		174.6	OK
5.000	S22	31	111.828	-0.167	0.000	0.15		10.0	OK
5.001	S23	31	111.090	-0.145	0.000	0.28		10.0	OK
5.002	S24	31	110.975	-0.195	0.000	0.27		26.4	OK
5.003	S25	31	110.713	-0.302	0.000	0.09		29.2	OK
5.004	S26	31	109.520	-0.305	0.000	0.08		38.4	OK
5.005	S27	40	106.919	-0.201	0.000	0.42		45.5	OK
5.006	S28	42	106.890	-0.172	0.000	0.57		48.3	OK
5.007	S29	35	106.885	-0.134	0.000	0.38		50.1	OK
5.008	S30	34	106.882	-0.082	0.000	0.39		53.6	OK
5.009	S31	34	106.879	-0.004	0.000	0.43		63.3	OK
1.013	S33	33	106.873	-0.106	0.000	0.68		232.0	OK
1.014	S34	32	106.868	-0.061	0.000	0.54		229.9	OK
1.015	S35	25	106.863	0.088	0.000	0.05		21.9	SURCHARGED
1.016	S36	27	106.188	-0.087	0.000	0.69		21.9	OK

©1982-2019 Innovyze

PJS Consulting Engineers Limited		Page 112
Unit 4 Winking Hill Farm Kingston-on-Soar, Nottingham Nottinghamshire NG11 0DP		
Lutterworth Road Burbage		
Date 29/06/2023 13:54 File SW Model 17.05.23.mdx		
Designed by matt.leask Checked by		
Innovyze		Network 2019.1

Summary Wizard of 240 minute 30 year Winter I+0% for Surface Water Network

Simulation Criteria

Areal Reduction Factor	1.000	Additional Flow - % of Total Flow	0.000
Hot Start (mins)	0	MADD Factor * 10m³/ha Storage	0.000
Hot Start Level (mm)	0	Inlet Coefficient	0.800
Manhole Headloss Coeff (Global)	0.500	Flow per Person per Day (l/per/day)	0.000
Foul Sewage per hectare (l/s)	0.000		

Number of Input Hydrographs 0 Number of Offline Controls 5 Number of Time/Area Diagrams 0
Number of Online Controls 3 Number of Storage Structures 2 Number of Real Time Controls 0

Synthetic Rainfall Details

Rainfall Model	FSR	Ratio R	0.401
Region	England and Wales	Cv (Summer)	0.750
M5-60 (mm)	19.600	Cv (Winter)	0.840


Margin for Flood Risk Warning (mm) 300.0
Analysis Timestep 2.5 Second Increment (Extended)
DTS Status OFF
DVD Status OFF
Inertia Status OFF

Profile(s)

Duration(s) (mins)	15, 30, 60, 120, 180, 240, 360, 480, 600, 720, 960, 1440
Return Period(s) (years)	1, 30, 100
Climate Change (%)	0, 0, 40

PN	US/MH Name	Storm Rank	Water	Surcharged	Flooded	Pipe		Status
			Level (m)	Depth (m)	Volume (m³)	Flow / Overflow (l/s)	Flow (l/s)	
1.000	S4	37	113.895	-0.180	0.000	0.09	6.8	OK
1.001	S5	37	112.693	-0.182	0.000	0.08	7.6	OK
1.002	S6	37	111.999	-0.146	0.000	0.27	9.7	OK
1.003	S7	37	111.699	-0.316	0.000	0.06	17.7	OK
2.000	S1	37	113.390	-0.285	0.000	0.13	30.0	OK
2.001	S2	37	112.729	-0.286	0.000	0.13	38.9	OK
2.002	S3	37	111.557	-0.348	0.000	0.12	44.4	OK
1.004	S8	37	111.184	-0.266	0.000	0.35	68.6	OK
1.005	S9	37	110.988	-0.321	0.000	0.18	80.6	OK
1.006	S10	37	110.275	-0.344	0.000	0.13	82.2	OK
1.007	S11	37	108.820	-0.480	0.000	0.09	98.6	OK
1.008	S12	43	107.141	-0.409	0.000	0.22	108.1	OK
3.000	S13	37	110.628	-0.197	0.000	0.04	3.5	OK
3.001	S14	37	109.516	-0.249	0.000	0.07	11.9	OK
3.002	S15	37	108.808	-0.252	0.000	0.06	15.5	OK

©1982-2019 Innovyze

PJS Consulting Engineers Limited		Page 114
Unit 4 Winking Hill Farm Kingston-on-Soar, Nottingham Nottinghamshire NG11 ODP		
Lutterworth Road Burbage		
Date 29/06/2023 13:54 File SW Model 17.05.23.mdx		
Designed by matt.leask Checked by		
Innovyze		Network 2019.1

Summary Wizard of 360 minute 30 year Winter I+0% for Surface Water Network

Simulation Criteria

Areal Reduction Factor	1.000	Additional Flow - % of Total Flow	0.000
Hot Start (mins)	0	MADD Factor * 10m³/ha Storage	0.000
Hot Start Level (mm)	0	Inlet Coefficient	0.800
Manhole Headloss Coeff (Global)	0.500	Flow per Person per Day (l/per/day)	0.000
Foul Sewage per hectare (l/s)	0.000		

Number of Input Hydrographs 0 Number of Offline Controls 5 Number of Time/Area Diagrams 0
Number of Online Controls 3 Number of Storage Structures 2 Number of Real Time Controls 0

Synthetic Rainfall Details

Rainfall Model	FSR	Ratio R	0.401
Region	England and Wales	Cv (Summer)	0.750
M5-60 (mm)	19.600	Cv (Winter)	0.840


Margin for Flood Risk Warning (mm) 300.0
Analysis Timestep 2.5 Second Increment (Extended)
DTS Status OFF
DVD Status OFF
Inertia Status OFF

Profile(s)

Duration(s) (mins)	15, 30, 60, 120, 180, 240, 360, 480, 600, 720, 960, 1440
Return Period(s) (years)	1, 30, 100
Climate Change (%)	0, 0, 40

PN	US/MH Name	Storm Rank	Water	Surcharged	Flooded	Flow / Overflow (l/s)	Pipe	Status
			Level (m)	Depth (m)	Volume (m³)		Flow (l/s)	
1.000	S4	44	113.887	-0.188	0.000	0.06	5.0	OK
1.001	S5	43	112.686	-0.189	0.000	0.06	5.6	OK
1.002	S6	43	111.987	-0.158	0.000	0.20	7.1	OK
1.003	S7	43	111.690	-0.325	0.000	0.04	13.0	OK
2.000	S1	44	113.378	-0.297	0.000	0.10	21.9	OK
2.001	S2	43	112.717	-0.298	0.000	0.09	28.5	OK
2.002	S3	43	111.543	-0.362	0.000	0.09	32.5	OK
1.004	S8	43	111.154	-0.296	0.000	0.26	50.2	OK
1.005	S9	43	110.968	-0.341	0.000	0.13	58.9	OK
1.006	S10	43	110.261	-0.358	0.000	0.09	60.2	OK
1.007	S11	43	108.799	-0.501	0.000	0.07	72.2	OK
1.008	S12	46	107.111	-0.439	0.000	0.16	79.1	OK
3.000	S13	44	110.625	-0.200	0.000	0.03	2.6	OK
3.001	S14	43	109.508	-0.257	0.000	0.05	8.7	OK
3.002	S15	43	108.801	-0.259	0.000	0.05	11.3	OK

©1982-2019 Innovyze

PJS Consulting Engineers Limited		Page 116
Unit 4 Winking Hill Farm Kingston-on-Soar, Nottingham Nottinghamshire NG11 0DP		
Lutterworth Road Burbage		
Date 29/06/2023 13:54 File SW Model 17.05.23.mdx		
Designed by matt.leask Checked by		
Innovyze		Network 2019.1

Summary Wizard of 480 minute 30 year Winter I+0% for Surface Water Network

Simulation Criteria

Areal Reduction Factor	1.000	Additional Flow - % of Total Flow	0.000
Hot Start (mins)	0	MADD Factor * 10m³/ha Storage	0.000
Hot Start Level (mm)	0	Inlet Coefficient	0.800
Manhole Headloss Coeff (Global)	0.500	Flow per Person per Day (l/per/day)	0.000
Foul Sewage per hectare (l/s)	0.000		

Number of Input Hydrographs 0 Number of Offline Controls 5 Number of Time/Area Diagrams 0
Number of Online Controls 3 Number of Storage Structures 2 Number of Real Time Controls 0

Synthetic Rainfall Details

Rainfall Model	FSR	Ratio R	0.401
Region	England and Wales	Cv (Summer)	0.750
M5-60 (mm)	19.600	Cv (Winter)	0.840

Margin for Flood Risk Warning (mm) 300.0
Analysis Timestep 2.5 Second Increment (Extended)
DTS Status OFF
DVD Status OFF
Inertia Status OFF

Profile(s) Summer and Winter
Duration(s) (mins) 15, 30, 60, 120, 180, 240, 360, 480, 600, 720, 960, 1440
Return Period(s) (years) 1, 30, 100
Climate Change (%) 0, 0, 40

PN	US/MH Name	Storm Rank	Water	Surcharged	Flooded	Pipe		Status
			Level (m)	Depth (m)	Volume (m³)	Flow / Overflow (l/s)	Flow (l/s)	
1.000	S4	51	113.883	-0.192	0.000	0.05	4.0	OK
1.001	S5	51	112.682	-0.193	0.000	0.05	4.5	OK
1.002	S6	51	111.979	-0.166	0.000	0.16	5.7	OK
1.003	S7	51	111.685	-0.330	0.000	0.04	10.4	OK
2.000	S1	51	113.369	-0.306	0.000	0.08	17.6	OK
2.001	S2	51	112.708	-0.307	0.000	0.08	22.8	OK
2.002	S3	51	111.532	-0.373	0.000	0.07	26.0	OK
1.004	S8	51	111.138	-0.312	0.000	0.21	40.2	OK
1.005	S9	51	110.957	-0.352	0.000	0.11	47.2	OK
1.006	S10	51	110.250	-0.369	0.000	0.07	48.1	OK
1.007	S11	51	108.788	-0.512	0.000	0.05	57.8	OK
1.008	S12	52	107.093	-0.457	0.000	0.13	63.3	OK
3.000	S13	51	110.623	-0.202	0.000	0.02	2.0	OK
3.001	S14	51	109.503	-0.262	0.000	0.04	7.0	OK
3.002	S15	51	108.797	-0.263	0.000	0.04	9.0	OK

PJS Consulting Engineers Limited

Unit 4 Winking Hill Farm
Kingston-on-Soar, Nottingham
Nottinghamshire NG11 0DP

Date 29/06/2023 13:54
File SW Model 17.05.23.mdx

Innovyze

Lutterworth Road
Burbage

Designed by matt.leask
Checked by

Network 2019.1

Page 118



Summary Wizard of 600 minute 30 year Winter I+0% for Surface Water Network

Simulation Criteria

Areal Reduction Factor 1.000

Hot Start (mins) 0

Hot Start Level (mm) 0

Manhole Headloss Coeff (Global) 0.500

Foul Sewage per hectare (l/s) 0.000

Additional Flow - % of Total Flow 0.000

MADD Factor * 10m³/ha Storage 0.000

Inlet Coefficient 0.800

Flow per Person per Day (l/per/day) 0.000

Number of Input Hydrographs 0

Number of Offline Controls 5

Number of Time/Area Diagrams 0

Number of Online Controls 3

Number of Storage Structures 2

Number of Real Time Controls 0

Synthetic Rainfall Details

Rainfall Model FSR

Region England and Wales Cv (Summer) 0.750

M5-60 (mm) 19.600 Cv (Winter) 0.840

Ratio R 0.401

Margin for Flood Risk Warning (mm) 300.0

Analysis Timestep 2.5 Second Increment (Extended)

DTS Status OFF

DVD Status OFF

Inertia Status OFF

Profile(s) Summer and Winter

Duration(s) (mins) 15, 30, 60, 120, 180, 240, 360, 480, 600, 720, 960, 1440

Return Period(s) (years) 1, 30, 100

Climate Change (%) 0, 0, 40

PN	US/MH Name	Storm Rank	Water	Surcharged	Flooded	Flow / Cap.	Overflow	Pipe	Status
			Level (m)	Depth (m)	Volume (m³)		(l/s)	Flow (l/s)	
1.000	S4	53	113.880	-0.195	0.000	0.04	3.3	OK	
1.001	S5	53	112.679	-0.196	0.000	0.04	3.8	OK	
1.002	S6	53	111.974	-0.171	0.000	0.13	4.8	OK	
1.003	S7	53	111.682	-0.333	0.000	0.03	8.7	OK	
2.000	S1	53	113.362	-0.313	0.000	0.07	14.8	OK	
2.001	S2	53	112.701	-0.314	0.000	0.06	19.1	OK	
2.002	S3	53	111.524	-0.381	0.000	0.06	21.9	OK	
1.004	S8	53	111.125	-0.325	0.000	0.17	33.8	OK	
1.005	S9	53	110.950	-0.359	0.000	0.09	39.6	OK	
1.006	S10	53	110.242	-0.377	0.000	0.06	40.5	OK	
1.007	S11	53	108.780	-0.520	0.000	0.04	48.6	OK	
1.008	S12	54	107.082	-0.468	0.000	0.11	53.2	OK	
3.000	S13	53	110.620	-0.205	0.000	0.02	1.7	OK	
3.001	S14	53	109.500	-0.265	0.000	0.03	5.8	OK	
3.002	S15	53	108.794	-0.266	0.000	0.03	7.6	OK	


©1982-2019 Innovyze

PJS Consulting Engineers Limited		Page 121
Unit 4 Winking Hill Farm Kingston-on-Soar, Nottingham Nottinghamshire NG11 0DP	Lutterworth Road Burbage	
Date 29/06/2023 13:54	Designed by matt.leask	
File SW Model 17.05.23.mdx	Checked by	
Innovyze	Network 2019.1	

Summary Wizard of 720 minute 30 year Winter I+0% for Surface Water Network

			Water	Surcharged	Flooded			Pipe	
PN	US/MH Name	Storm Rank	Level (m)	Depth (m)	Volume (m³)	Flow / Cap.	Overflow (l/s)	Flow (l/s)	Status
1.009	S16	58	106.900	-0.414	0.000	0.20		54.3	OK
1.010	S17	52	106.847	-0.396	0.000	0.26		55.0	OK
1.011	S18	47	106.845	-0.373	0.000	0.18		55.0	OK
4.000	S38	58	111.620	-0.690	0.000	0.00		5.0	OK
4.001	S39	58	111.174	-0.686	0.000	0.00	0.1	4.9	OK
4.002	S40	58	111.141	-0.689	0.000	0.00	0.1	4.8	OK
4.003	S41	58	110.911	-0.629	0.000	0.00	2.8	2.8	OK
4.004	S42	58	109.148	-0.692	0.000	0.00	0.0	4.7	OK
4.005	S43	58	108.015	-0.635	0.000	0.00	2.3	2.3	OK
1.012	S32	38	106.842	-0.332	0.000	0.11		60.2	OK
5.000	S22	58	111.803	-0.192	0.000	0.05		3.4	OK
5.001	S23	58	111.056	-0.179	0.000	0.10		3.4	OK
5.002	S24	58	110.931	-0.239	0.000	0.09		9.1	OK
5.003	S25	58	110.682	-0.333	0.000	0.03		10.0	OK
5.004	S26	58	109.491	-0.334	0.000	0.03		13.2	OK
5.005	S27	55	106.852	-0.268	0.000	0.15		15.6	OK
5.006	S28	48	106.850	-0.212	0.000	0.20		16.6	OK
5.007	S29	39	106.848	-0.171	0.000	0.13		17.2	OK
5.008	S30	38	106.846	-0.118	0.000	0.13		18.4	OK
5.009	S31	38	106.844	-0.039	0.000	0.15		21.7	OK
1.013	S33	38	106.840	-0.139	0.000	0.21		71.2	OK
1.014	S34	36	106.837	-0.092	0.000	0.16		70.6	OK
1.015	S35	29	106.834	0.059	0.000	0.05		21.9	SURCHARGED
1.016	S36	21	106.188	-0.087	0.000	0.69		21.9	OK

©1982-2019 Innovyze

PJS Consulting Engineers Limited		Page 122
Unit 4 Winking Hill Farm Kingston-on-Soar, Nottingham Nottinghamshire NG11 0DP		
Lutterworth Road Burbage		
Date 29/06/2023 13:54 File SW Model 17.05.23.mdx		
Designed by matt.leask Checked by		
Innovyze		Network 2019.1

Summary Wizard of 960 minute 30 year Winter I+0% for Surface Water Network

Simulation Criteria

Areal Reduction Factor	1.000	Additional Flow - % of Total Flow	0.000
Hot Start (mins)	0	MADD Factor * 10m³/ha Storage	0.000
Hot Start Level (mm)	0	Inlet Coefficient	0.800
Manhole Headloss Coeff (Global)	0.500	Flow per Person per Day (l/per/day)	0.000
Foul Sewage per hectare (l/s)	0.000		

Number of Input Hydrographs 0 Number of Offline Controls 5 Number of Time/Area Diagrams 0
Number of Online Controls 3 Number of Storage Structures 2 Number of Real Time Controls 0


Synthetic Rainfall Details

Rainfall Model	FSR	Ratio R	0.401
Region	England and Wales	Cv (Summer)	0.750
M5-60 (mm)	19.600	Cv (Winter)	0.840

Margin for Flood Risk Warning (mm) 300.0
Analysis Timestep 2.5 Second Increment (Extended)
DTS Status OFF
DVD Status OFF
Inertia Status OFF

Profile(s) Summer and Winter
Duration(s) (mins) 15, 30, 60, 120, 180, 240, 360, 480, 600, 720, 960, 1440
Return Period(s) (years) 1, 30, 100
Climate Change (%) 0, 0, 40

PN	US/MH Name	Storm Rank	Water	Surcharged	Flooded	Flow / Overflow (l/s)	Pipe	Status
			Level (m)	Depth (m)	Volume (m³)		Flow (l/s)	
1.000	S4	61	113.875	-0.200	0.000	0.03	2.3	OK
1.001	S5	61	112.675	-0.200	0.000	0.03	2.6	OK
1.002	S6	61	111.966	-0.179	0.000	0.09	3.3	OK
1.003	S7	61	111.676	-0.339	0.000	0.02	6.0	OK
2.000	S1	61	113.351	-0.324	0.000	0.05	10.2	OK
2.001	S2	61	112.690	-0.325	0.000	0.04	13.3	OK
2.002	S3	61	111.512	-0.393	0.000	0.04	15.1	OK
1.004	S8	61	111.103	-0.347	0.000	0.12	23.4	OK
1.005	S9	61	110.932	-0.377	0.000	0.06	27.5	OK
1.006	S10	61	110.229	-0.390	0.000	0.04	28.0	OK
1.007	S11	61	108.768	-0.532	0.000	0.03	33.6	OK
1.008	S12	61	107.059	-0.491	0.000	0.08	36.9	OK
3.000	S13	61	110.614	-0.211	0.000	0.01	1.2	OK
3.001	S14	61	109.496	-0.269	0.000	0.02	4.1	OK
3.002	S15	61	108.790	-0.270	0.000	0.02	5.3	OK

PJS Consulting Engineers Limited		Page 124
Unit 4 Winking Hill Farm Kingston-on-Soar, Nottingham Nottinghamshire NG11 0DP		
Lutterworth Road Burbage		
Date 29/06/2023 13:54 File SW Model 17.05.23.mdx		
Designed by matt.leask Checked by		
Innovyze		Network 2019.1

Summary Wizard of 1440 minute 30 year Winter I+0% for Surface Water Network

Simulation Criteria

Areal Reduction Factor 1.000	Additional Flow - % of Total Flow 0.000
Hot Start (mins) 0	MADD Factor * 10m³/ha Storage 0.000
Hot Start Level (mm) 0	Inlet Coefficient 0.800
Manhole Headloss Coeff (Global) 0.500	Flow per Person per Day (l/per/day) 0.000
Foul Sewage per hectare (l/s) 0.000	

Number of Input Hydrographs 0	Number of Offline Controls 5	Number of Time/Area Diagrams 0
Number of Online Controls 3	Number of Storage Structures 2	Number of Real Time Controls 0

Synthetic Rainfall Details

Rainfall Model	FSR	Ratio R 0.401
Region England and Wales Cv (Summer)	0.750	
M5-60 (mm)	19.600 Cv (Winter)	0.840

Margin for Flood Risk Warning (mm)	300.0
Analysis Timestep 2.5 Second Increment (Extended)	
DTS Status	OFF
DVD Status	OFF
Inertia Status	OFF

Profile(s)	Summer and Winter
Duration(s) (mins)	15, 30, 60, 120, 180, 240, 360, 480, 600, 720, 960, 1440
Return Period(s) (years)	1, 30, 100
Climate Change (%)	0, 0, 40

PN	US/MH Name	Storm Rank	Water Level (m)	Surcharged Depth (m)	Flooded Volume (m³)	Flow / Overflow Cap. (l/s)	Pipe Flow (l/s)	Status
1.000	S4	66	113.873	-0.202	0.000	0.02	1.7	OK
1.001	S5	66	112.672	-0.203	0.000	0.02	1.9	OK
1.002	S6	66	111.958	-0.187	0.000	0.07	2.4	OK
1.003	S7	66	111.667	-0.348	0.000	0.01	4.4	OK
2.000	S1	66	113.344	-0.331	0.000	0.03	7.4	OK
2.001	S2	66	112.683	-0.332	0.000	0.03	9.6	OK
2.002	S3	66	111.505	-0.400	0.000	0.03	11.0	OK
1.004	S8	66	111.089	-0.361	0.000	0.09	17.0	OK
1.005	S9	66	110.920	-0.389	0.000	0.05	20.0	OK
1.006	S10	66	110.221	-0.398	0.000	0.03	20.4	OK
1.007	S11	66	108.761	-0.539	0.000	0.02	24.5	OK
1.008	S12	66	107.040	-0.510	0.000	0.06	26.8	OK
3.000	S13	66	110.610	-0.215	0.000	0.01	0.9	OK
3.001	S14	66	109.489	-0.276	0.000	0.02	2.9	OK
3.002	S15	66	108.782	-0.278	0.000	0.02	3.8	OK

©1982-2019 Innovyze



Micro
Drainage

Simulation Criteria

Number of Input Hydrographs	0	Number of Offline Controls	5	Number of Time/Area Diagrams	0
Number of Online Controls	3	Number of Storage Structures	2	Number of Real Time Controls	0

Rainfall Model	FSR	Ratio R	0.401
Region	England and Wales	Cv (Summer)	0.750
M5-60 (mm)	19.600	Cv (Winter)	0.840

	Profile(s)	Summer and Winter
	Duration(s) (mins)	15, 30, 60, 120, 180, 240, 360, 480, 600, 720, 960, 1440
Return Period(s) (years)		1, 30, 100
Climate Change (%)		0, 0, 40

WARNING: The analysis maybe unstable. Please see the method of analysis help for more details.

PN	US/MH Name	Storm Rank	Water	Surcharged	Flooded	Pipe		Status
			Level (m)	Depth (m)	Volume (m³)	Flow / Cap.	Overflow (l/s)	
1.000	S4	1	114.451	0.376	0.000	0.79	61.0	SURCHARGED
1.001	S5	1	113.754	0.879	0.000	0.69	63.0	FLOOD RISK
1.002	S6	1	113.402	1.257	2.013	2.04	73.9	FLOOD
1.003	S7	1	113.058	1.043	0.545	0.42	123.2	FLOOD
2.000	S1	1	115.057	1.382	2.496	1.09	246.9	FLOOD
2.001	S2	1	114.270	1.255	4.663	0.95	287.2	FLOOD
2.002	S3	1	113.305	1.400	0.181	0.87	332.1	FLOOD
1.004	S8	1	112.960	1.510	4.563	2.40	468.1	FLOOD
1.005	S9	1	112.156	0.847	4.919	1.27	560.1	FLOOD
1.006	S10	1	111.257	0.638	0.000	0.88	568.6	FLOOD RISK
1.007	S11	1	110.410	1.110	0.000	0.59	652.9	FLOOD RISK
1.008	S12	1	109.774	2.224	0.275	1.49	725.1	FLOOD

Simulation Criteria

Number of Input Hydrographs	0	Number of Offline Controls	5	Number of Time/Area Diagrams	0
Number of Online Controls	3	Number of Storage Structures	2	Number of Real Time Controls	0

Rainfall Model	FSR	Ratio R	0.401
Region	England and Wales	Cv (Summer)	0.750
M5-60 (mm)	19.600	Cv (Winter)	0.840

Profile(s)	Summer and Winter
Duration(s) (mins)	15, 30, 60, 120, 180, 240, 360, 480, 600, 720, 960, 1440
Return Period(s) (years)	1, 30, 100
Climate Change (%)	0, 0, 40

©1982-2019 Innovyze


PJS Consulting Engineers Limited		Page 129
Unit 4 Winking Hill Farm Kingston-on-Soar, Nottingham Nottinghamshire NG11 0DP	Lutterworth Road Burbage	
Date 29/06/2023 13:54 File SW Model 17.05.23.mdx	Designed by matt.leask Checked by	
Innovyze	Network 2019.1	

Summary Wizard of 30 minute 100 year Winter I+40% for Surface Water Network

PN	US/MH Name	Storm Rank	Water Level (m)	Surcharged Depth (m)	Flooded Volume (m³)	Flow / Cap. (l/s)	Overflow (l/s)	Pipe Flow (l/s)	Status
1.009	S16	3	109.100	1.786	0.000	2.96		786.6	SURCHARGED
1.010	S17	2	108.507	1.264	0.000	3.69		794.4	SURCHARGED
1.011	S18	1	108.142	0.924	0.000	2.66		790.3	SURCHARGED
4.000	S38	4	111.720	-0.590	0.000	0.03		88.7	OK
4.001	S39	4	111.309	-0.551	0.000	0.05	10.1	80.3	OK
4.002	S40	4	111.305	-0.525	0.000	0.03	13.0	69.9	OK
4.003	S41	4	111.300	-0.240	0.000	0.01	29.1	29.1	FLOOD RISK
4.004	S42	4	109.224	-0.616	0.000	0.02	4.1	56.9	OK
4.005	S43	4	108.305	-0.345	0.000	0.00	24.8	24.8	OK
1.012	S32	1	107.807	0.633	0.000	1.49		836.6	FLOOD RISK
5.000	S22	4	112.164	0.169	0.000	0.89		58.5	SURCHARGED
5.001	S23	4	111.557	0.322	0.000	1.69		60.8	SURCHARGED
5.002	S24	4	111.390	0.220	0.000	1.57		155.2	SURCHARGED
5.003	S25	4	110.829	-0.186	0.000	0.50		171.8	OK
5.004	S26	4	109.835	0.010	0.000	0.46		223.7	SURCHARGED
5.005	S27	4	109.319	2.199	0.000	2.35		251.5	SURCHARGED
5.006	S28	4	108.943	1.881	0.000	3.07		260.4	SURCHARGED
5.007	S29	3	108.525	1.506	0.000	2.03		267.2	SURCHARGED
5.008	S30	2	108.304	1.340	0.000	2.05		284.9	SURCHARGED
5.009	S31	2	107.980	1.097	0.000	2.26		329.9	SURCHARGED
1.013	S33	1	107.507	0.528	0.000	2.17		745.0	SURCHARGED
1.014	S34	20	107.162	0.233	0.000	1.74		745.1	SURCHARGED
1.015	S35	21	107.005	0.230	0.000	0.05		21.9	SURCHARGED
1.016	S36	44	106.188	-0.087	0.000	0.69		21.9	OK

PJS Consulting Engineers Limited							Page 130																		
Unit 4 Winking Hill Farm Kingston-on-Soar, Nottingham Nottinghamshire NG11 0DP				Lutterworth Road Burbage																					
Date 29/06/2023 13:54				Designed by matt.leask																					
File SW Model 17.05.23.mdx				Checked by																					
Innovyze				Network 2019.1																					
<u>Summary Wizard of 60 minute 100 year Winter I+40% for Surface Water Network</u>																									
<u>Simulation Criteria</u>																									
Areal Reduction Factor		1.000		Additional Flow - % of Total Flow		0.000																			
Hot Start (mins)		0		MADD Factor * 10m³/ha Storage		0.000																			
Hot Start Level (mm)		0		Inlet Coefficient		0.800																			
Manhole Headloss Coeff (Global)		0.500		Flow per Person per Day (l/per/day)		0.000																			
Foul Sewage per hectare (l/s)		0.000																							
Number of Input Hydrographs		0		Number of Offline Controls		5		Number of Time/Area Diagrams		0															
Number of Online Controls		3		Number of Storage Structures		2		Number of Real Time Controls 0																	
<u>Synthetic Rainfall Details</u>																									
Rainfall Model		FSR		Ratio R		0.401																			
Region		England and Wales		Cv (Summer)		0.750																			
M5-60 (mm)		19.600		Cv (Winter)		0.840																			
Margin for Flood Risk Warning (mm)						300.0																			
Analysis Timestep		2.5		Second Increment (Extended)																					
DTS Status						OFF																			
DVD Status						OFF																			
Inertia Status						OFF																			
Profile(s)						Summer and Winter																			
Duration(s) (mins)		15, 30, 60, 120, 180, 240, 360, 480, 600, 720, 960, 1440																							
Return Period(s) (years)						1, 30, 100																			
Climate Change (%)						0, 0, 40																			
<table><tr><th rowspan="2">PN</th><th rowspan="2">US/MH Name</th><th rowspan="2">Storm Rank</th><th>Water</th><th>Surcharged</th><th>Flooded</th><th colspan="2">Pipe</th><th rowspan="2">Status</th></tr><tr><th>Level (m)</th><th>Depth (m)</th><th>Volume (m³)</th><th>Flow / Cap.</th><th>Overflow (l/s)</th><th>Flow (l/s)</th></tr></table>											PN	US/MH Name	Storm Rank	Water	Surcharged	Flooded	Pipe		Status	Level (m)	Depth (m)	Volume (m³)	Flow / Cap.	Overflow (l/s)	Flow (l/s)
PN	US/MH Name	Storm Rank	Water	Surcharged	Flooded	Pipe		Status																	
			Level (m)	Depth (m)	Volume (m³)	Flow / Cap.	Overflow (l/s)		Flow (l/s)																
1.000	S4	8	113.954	-0.121	0.000	0.44	34.0	OK																	
1.001	S5	8	112.751	-0.124	0.000	0.42	38.1	OK																	
1.002	S6	8	112.233	0.088	0.000	1.33	48.2	SURCHARGED																	
1.003	S7	8	111.780	-0.235	0.000	0.30	88.6	OK																	
2.000	S1	8	113.524	-0.151	0.000	0.66	150.0	OK																	
2.001	S2	8	112.860	-0.155	0.000	0.64	194.7	OK																	
2.002	S3	8	111.878	-0.027	0.000	0.58	221.5	OK																	
1.004	S8	8	111.723	0.273	0.000	1.75	341.8	SURCHARGED																	
1.005	S9	8	111.196	-0.113	0.000	0.91	400.6	OK																	
1.006	S10	8	110.429	-0.190	0.000	0.63	408.9	OK																	
1.007	S11	8	108.979	-0.321	0.000	0.44	489.2	OK																	
1.008	S12	6	108.618	1.068	0.000	1.07	521.2	SURCHARGED																	
3.000	S13	8	110.667	-0.158	0.000	0.19	17.5	OK																	
3.001	S14	8	109.585	-0.180	0.000	0.34	59.7	OK																	
3.002	S15	8	108.875	-0.185	0.000	0.31	77.5	OK																	

| ©1982-2019 Innovyze | | | | | | | | | | |

PJS Consulting Engineers Limited		Page 132
Unit 4 Winking Hill Farm Kingston-on-Soar, Nottingham Nottinghamshire NG11 ODP		
Lutterworth Road Burbage		
Date 29/06/2023 13:54 File SW Model 17.05.23.mdx		
Designed by matt.leask Checked by		
Innovyze		Network 2019.1

Summary Wizard of 120 minute 100 year Winter I+40% for Surface Water Network

Simulation Criteria

Areal Reduction Factor 1.000	Additional Flow - % of Total Flow 0.000
Hot Start (mins) 0	MADD Factor * 10m³/ha Storage 0.000
Hot Start Level (mm) 0	Inlet Coefficient 0.800
Manhole Headloss Coeff (Global) 0.500	Flow per Person per Day (l/per/day) 0.000
Foul Sewage per hectare (l/s) 0.000	

Number of Input Hydrographs 0 Number of Offline Controls 5 Number of Time/Area Diagrams 0
Number of Online Controls 3 Number of Storage Structures 2 Number of Real Time Controls 0

Synthetic Rainfall Details


Rainfall Model	FSR	Ratio R 0.401
Region England and Wales Cv (Summer)	0.750	
M5-60 (mm)	19.600 Cv (Winter)	0.840

Margin for Flood Risk Warning (mm) 300.0
Analysis Timestep 2.5 Second Increment (Extended)
DTS Status OFF
DVD Status OFF
Inertia Status OFF

Profile(s) Summer and Winter
Duration(s) (mins) 15, 30, 60, 120, 180, 240, 360, 480, 600, 720, 960, 1440
Return Period(s) (years) 1, 30, 100
Climate Change (%) 0, 0, 40

PN	US/MH Name	Storm Rank	Water Level (m)	Surcharged Depth (m)	Flooded Volume (m³)	Flow / Cap.	Overflow (l/s)	Pipe Flow (l/s)	Status
1.000	S4	14	113.929	-0.146	0.000	0.27		21.0	OK
1.001	S5	14	112.727	-0.148	0.000	0.26		23.6	OK
1.002	S6	14	112.076	-0.069	0.000	0.82		29.8	OK
1.003	S7	14	111.749	-0.266	0.000	0.19		54.8	OK
2.000	S1	14	113.467	-0.208	0.000	0.41		92.6	OK
2.001	S2	14	112.804	-0.211	0.000	0.40		120.2	OK
2.002	S3	14	111.641	-0.264	0.000	0.36		137.3	OK
1.004	S8	14	111.453	0.003	0.000	1.09		211.9	SURCHARGED
1.005	S9	14	111.101	-0.208	0.000	0.56		248.6	OK
1.006	S10	14	110.364	-0.255	0.000	0.39		253.7	OK
1.007	S11	14	108.913	-0.387	0.000	0.27		304.3	OK
1.008	S12	13	107.505	-0.045	0.000	0.68		333.1	OK
3.000	S13	14	110.651	-0.174	0.000	0.12		10.8	OK
3.001	S14	14	109.558	-0.207	0.000	0.21		36.8	OK
3.002	S15	14	108.849	-0.211	0.000	0.19		47.8	OK

©1982-2019 Innovyze

PJS Consulting Engineers Limited		Page 134
Unit 4 Winking Hill Farm Kingston-on-Soar, Nottingham Nottinghamshire NG11 0DP		
Lutterworth Road Burbage		
Date 29/06/2023 13:54 File SW Model 17.05.23.mdx		
Designed by matt.leask Checked by		
Innovyze		Network 2019.1

Summary Wizard of 180 minute 100 year Winter I+40% for Surface Water Network

Simulation Criteria

Areal Reduction Factor	1.000	Additional Flow - % of Total Flow	0.000
Hot Start (mins)	0	MADD Factor * 10m³/ha Storage	0.000
Hot Start Level (mm)	0	Inlet Coefficient	0.800
Manhole Headloss Coeff (Global)	0.500	Flow per Person per Day (l/per/day)	0.000
Foul Sewage per hectare (l/s)	0.000		

Number of Input Hydrographs	0	Number of Offline Controls	5	Number of Time/Area Diagrams	0
Number of Online Controls	3	Number of Storage Structures	2	Number of Real Time Controls	0

Synthetic Rainfall Details

Rainfall Model	FSR	Ratio R	0.401
Region	England and Wales	Cv (Summer)	0.750
M5-60 (mm)	19.600	Cv (Winter)	0.840

Margin for Flood Risk Warning (mm)	300.0
Analysis Timestep	2.5 Second Increment (Extended)
DTS Status	OFF
DVD Status	OFF
Inertia Status	OFF

Profile(s)	Summer and Winter
Duration(s) (mins)	15, 30, 60, 120, 180, 240, 360, 480, 600, 720, 960, 1440
Return Period(s) (years)	1, 30, 100
Climate Change (%)	0, 0, 40

PN	US/MH Name	Storm Rank	Water	Surcharged	Flooded	Pipe		Status
			Level (m)	Depth (m)	Volume (m³)	Flow / Overflow (l/s)	Flow (l/s)	
1.000	S4	17	113.918	-0.157	0.000	0.20	15.5	OK
1.001	S5	17	112.716	-0.159	0.000	0.19	17.4	OK
1.002	S6	17	112.047	-0.098	0.000	0.61	22.1	OK
1.003	S7	17	111.732	-0.283	0.000	0.14	40.5	OK
2.000	S1	17	113.441	-0.234	0.000	0.30	68.5	OK
2.001	S2	17	112.778	-0.237	0.000	0.29	88.8	OK
2.002	S3	17	111.612	-0.293	0.000	0.27	101.4	OK
1.004	S8	17	111.307	-0.143	0.000	0.80	156.7	OK
1.005	S9	17	111.061	-0.248	0.000	0.42	183.9	OK
1.006	S10	17	110.334	-0.285	0.000	0.29	187.6	OK
1.007	S11	17	108.883	-0.417	0.000	0.20	225.1	OK
1.008	S12	23	107.401	-0.149	0.000	0.51	246.7	OK
3.000	S13	17	110.645	-0.180	0.000	0.09	8.0	OK
3.001	S14	17	109.543	-0.222	0.000	0.15	27.2	OK
3.002	S15	17	108.835	-0.225	0.000	0.14	35.3	OK

©1982-2019 Innovyze

PJS Consulting Engineers Limited				Page 136																																																																																																																																																																																																													
Unit 4 Winking Hill Farm Kingston-on-Soar, Nottingham Nottinghamshire NG11 0DP				Lutterworth Road Burbage																																																																																																																																																																																																													
Date 29/06/2023 13:54				Designed by matt.leask																																																																																																																																																																																																													
File SW Model 17.05.23.mdx				Checked by																																																																																																																																																																																																													
Innovyze				Network 2019.1																																																																																																																																																																																																													
<u>Summary Wizard of 240 minute 100 year Winter I+40% for Surface Water Network</u>																																																																																																																																																																																																																	
<u>Simulation Criteria</u>																																																																																																																																																																																																																	
Areal Reduction Factor 1.000				Additional Flow - % of Total Flow 0.000																																																																																																																																																																																																													
Hot Start (mins) 0				MADD Factor * 10m³/ha Storage 0.000																																																																																																																																																																																																													
Hot Start Level (mm) 0				Inlet Coefficient 0.800																																																																																																																																																																																																													
Manhole Headloss Coeff (Global) 0.500				Flow per Person per Day (l/per/day) 0.000																																																																																																																																																																																																													
Foul Sewage per hectare (l/s) 0.000																																																																																																																																																																																																																	
Number of Input Hydrographs 0				Number of Offline Controls 5				Number of Time/Area Diagrams 0																																																																																																																																																																																																									
Number of Online Controls 3				Number of Storage Structures 2				Number of Real Time Controls 0																																																																																																																																																																																																									
<u>Synthetic Rainfall Details</u>																																																																																																																																																																																																																	
Rainfall Model				FSR				Ratio R 0.401																																																																																																																																																																																																									
Region England and Wales				Cv (Summer) 0.750																																																																																																																																																																																																													
M5-60 (mm)				19.600				Cv (Winter) 0.840																																																																																																																																																																																																									
Margin for Flood Risk Warning (mm)				300.0																																																																																																																																																																																																													
Analysis Timestep 2.5				Second Increment (Extended)																																																																																																																																																																																																													
DTS Status				OFF																																																																																																																																																																																																													
DVD Status				OFF																																																																																																																																																																																																													
Inertia Status				OFF																																																																																																																																																																																																													
Profile(s)				Summer and Winter																																																																																																																																																																																																													
Duration(s) (mins)				15, 30, 60, 120, 180, 240, 360, 480, 600, 720, 960, 1440																																																																																																																																																																																																													
Return Period(s) (years)				1, 30, 100																																																																																																																																																																																																													
Climate Change (%)				0, 0, 40																																																																																																																																																																																																													
<table><tr><th colspan="3"></th><th>Water</th><th>Surcharged</th><th>Flooded</th><th colspan="2"></th><th>Pipe</th><th colspan="2"></th></tr><tr><th></th><th>US/MH</th><th>Storm</th><th>Level</th><th>Depth</th><th>Volume</th><th>Flow /</th><th>Overflow</th><th>Flow</th><th colspan="2"></th></tr><tr><th>PN</th><th>Name</th><th>Rank</th><th>(m)</th><th>(m)</th><th>(m³)</th><th>Cap.</th><th>(l/s)</th><th>(l/s)</th><th>Status</th><th></th></tr><tr><td>1.000</td><td>S4</td><td>23</td><td>113.910</td><td>-0.165</td><td>0.000</td><td>0.16</td><td></td><td>12.4</td><td>OK</td><td></td></tr><tr><td>1.001</td><td>S5</td><td>22</td><td>112.708</td><td>-0.167</td><td>0.000</td><td>0.15</td><td></td><td>13.9</td><td>OK</td><td></td></tr><tr><td>1.002</td><td>S6</td><td>22</td><td>112.031</td><td>-0.114</td><td>0.000</td><td>0.49</td><td></td><td>17.7</td><td>OK</td><td></td></tr><tr><td>1.003</td><td>S7</td><td>22</td><td>111.723</td><td>-0.292</td><td>0.000</td><td>0.11</td><td></td><td>32.4</td><td>OK</td><td></td></tr><tr><td>2.000</td><td>S1</td><td>23</td><td>113.425</td><td>-0.250</td><td>0.000</td><td>0.24</td><td></td><td>54.9</td><td>OK</td><td></td></tr><tr><td>2.001</td><td>S2</td><td>22</td><td>112.763</td><td>-0.252</td><td>0.000</td><td>0.24</td><td></td><td>71.1</td><td>OK</td><td></td></tr><tr><td>2.002</td><td>S3</td><td>22</td><td>111.595</td><td>-0.310</td><td>0.000</td><td>0.21</td><td></td><td>81.2</td><td>OK</td><td></td></tr><tr><td>1.004</td><td>S8</td><td>22</td><td>111.263</td><td>-0.187</td><td>0.000</td><td>0.64</td><td></td><td>125.5</td><td>OK</td><td></td></tr><tr><td>1.005</td><td>S9</td><td>22</td><td>111.038</td><td>-0.271</td><td>0.000</td><td>0.33</td><td></td><td>147.3</td><td>OK</td><td></td></tr><tr><td>1.006</td><td>S10</td><td>22</td><td>110.315</td><td>-0.304</td><td>0.000</td><td>0.23</td><td></td><td>150.3</td><td>OK</td><td></td></tr><tr><td>1.007</td><td>S11</td><td>21</td><td>108.861</td><td>-0.439</td><td>0.000</td><td>0.16</td><td></td><td>180.4</td><td>OK</td><td></td></tr><tr><td>1.008</td><td>S12</td><td>20</td><td>107.427</td><td>-0.123</td><td>0.000</td><td>0.40</td><td></td><td>197.1</td><td>OK</td><td></td></tr><tr><td>3.000</td><td>S13</td><td>23</td><td>110.639</td><td>-0.186</td><td>0.000</td><td>0.07</td><td></td><td>6.4</td><td>OK</td><td></td></tr><tr><td>3.001</td><td>S14</td><td>22</td><td>109.535</td><td>-0.230</td><td>0.000</td><td>0.12</td><td></td><td>21.7</td><td>OK</td><td></td></tr><tr><td>3.002</td><td>S15</td><td>21</td><td>108.827</td><td>-0.233</td><td>0.000</td><td>0.11</td><td></td><td>28.3</td><td>OK</td><td></td></tr></table>															Water	Surcharged	Flooded			Pipe				US/MH	Storm	Level	Depth	Volume	Flow /	Overflow	Flow			PN	Name	Rank	(m)	(m)	(m³)	Cap.	(l/s)	(l/s)	Status		1.000	S4	23	113.910	-0.165	0.000	0.16		12.4	OK		1.001	S5	22	112.708	-0.167	0.000	0.15		13.9	OK		1.002	S6	22	112.031	-0.114	0.000	0.49		17.7	OK		1.003	S7	22	111.723	-0.292	0.000	0.11		32.4	OK		2.000	S1	23	113.425	-0.250	0.000	0.24		54.9	OK		2.001	S2	22	112.763	-0.252	0.000	0.24		71.1	OK		2.002	S3	22	111.595	-0.310	0.000	0.21		81.2	OK		1.004	S8	22	111.263	-0.187	0.000	0.64		125.5	OK		1.005	S9	22	111.038	-0.271	0.000	0.33		147.3	OK		1.006	S10	22	110.315	-0.304	0.000	0.23		150.3	OK		1.007	S11	21	108.861	-0.439	0.000	0.16		180.4	OK		1.008	S12	20	107.427	-0.123	0.000	0.40		197.1	OK		3.000	S13	23	110.639	-0.186	0.000	0.07		6.4	OK		3.001	S14	22	109.535	-0.230	0.000	0.12		21.7	OK		3.002	S15	21	108.827	-0.233	0.000	0.11		28.3	OK	
			Water	Surcharged	Flooded			Pipe																																																																																																																																																																																																									
	US/MH	Storm	Level	Depth	Volume	Flow /	Overflow	Flow																																																																																																																																																																																																									
PN	Name	Rank	(m)	(m)	(m³)	Cap.	(l/s)	(l/s)	Status																																																																																																																																																																																																								
1.000	S4	23	113.910	-0.165	0.000	0.16		12.4	OK																																																																																																																																																																																																								
1.001	S5	22	112.708	-0.167	0.000	0.15		13.9	OK																																																																																																																																																																																																								
1.002	S6	22	112.031	-0.114	0.000	0.49		17.7	OK																																																																																																																																																																																																								
1.003	S7	22	111.723	-0.292	0.000	0.11		32.4	OK																																																																																																																																																																																																								
2.000	S1	23	113.425	-0.250	0.000	0.24		54.9	OK																																																																																																																																																																																																								
2.001	S2	22	112.763	-0.252	0.000	0.24		71.1	OK																																																																																																																																																																																																								
2.002	S3	22	111.595	-0.310	0.000	0.21		81.2	OK																																																																																																																																																																																																								
1.004	S8	22	111.263	-0.187	0.000	0.64		125.5	OK																																																																																																																																																																																																								
1.005	S9	22	111.038	-0.271	0.000	0.33		147.3	OK																																																																																																																																																																																																								
1.006	S10	22	110.315	-0.304	0.000	0.23		150.3	OK																																																																																																																																																																																																								
1.007	S11	21	108.861	-0.439	0.000	0.16		180.4	OK																																																																																																																																																																																																								
1.008	S12	20	107.427	-0.123	0.000	0.40		197.1	OK																																																																																																																																																																																																								
3.000	S13	23	110.639	-0.186	0.000	0.07		6.4	OK																																																																																																																																																																																																								
3.001	S14	22	109.535	-0.230	0.000	0.12		21.7	OK																																																																																																																																																																																																								
3.002	S15	21	108.827	-0.233	0.000	0.11		28.3	OK																																																																																																																																																																																																								
©1982-2019 Innovyze																																																																																																																																																																																																																	

PJS Consulting Engineers Limited

Unit 4 Winking Hill Farm

Kingston-on-Soar, Nottingham

Nottinghamshire NG11 0DP

Date 29/06/2023 13:54

File SW Model 17.05.23.mdx

Lutterworth Road

Burbage

Designed by matt.leask

Checked by

Innovyze

Network 2019.1

Page 138



Summary Wizard of 360 minute 100 year Winter I+40% for Surface Water Network

Simulation Criteria

Areal Reduction Factor 1.000

Hot Start (mins) 0

Hot Start Level (mm) 0

Manhole Headloss Coeff (Global) 0.500

Foul Sewage per hectare (l/s) 0.000

Additional Flow - % of Total Flow 0.000

MADD Factor * 10m³/ha Storage 0.000

Inlet Coeffiecient 0.800

Flow per Person per Day (l/per/day) 0.000

Number of Input Hydrographs 0

Number of Offline Controls 5

Number of Time/Area Diagrams 0

Number of Online Controls 3

Number of Storage Structures 2

Number of Real Time Controls 0

Synthetic Rainfall Details

Rainfall Model FSR

Region England and Wales Cv (Summer) 0.750

M5-60 (mm) 19.600

Ratio R 0.401

Cv (Winter) 0.840

Margin for Flood Risk Warning (mm) 300.0

Analysis Timestep 2.5 Second Increment (Extended)

DTS Status OFF

DVD Status OFF

Inertia Status OFF

Profile(s) Summer and Winter

Duration(s) (mins) 15, 30, 60, 120, 180, 240, 360, 480, 600, 720, 960, 1440

Return Period(s) (years) 1, 30, 100

Climate Change (%) 0, 0, 40

			Water	Surcharged	Flooded		Pipe	
	US/MH	Storm	Level	Depth	Volume	Flow /	Overflow	Pipe
PN	Name	Rank	(m)	(m)	(m³)	Cap.	(l/s)	(l/s)
								Status
1.000	S4	30	113.901	-0.174	0.000	0.12	9.0	OK
1.001	S5	30	112.700	-0.175	0.000	0.11	10.1	OK
1.002	S6	30	112.012	-0.133	0.000	0.36	12.8	OK
1.003	S7	30	111.710	-0.305	0.000	0.08	23.6	OK
2.000	S1	30	113.405	-0.270	0.000	0.18	39.9	OK
2.001	S2	30	112.744	-0.271	0.000	0.17	51.7	OK
2.002	S3	30	111.573	-0.332	0.000	0.16	59.1	OK
1.004	S8	30	111.216	-0.234	0.000	0.47	91.2	OK
1.005	S9	30	111.009	-0.300	0.000	0.24	107.1	OK
1.006	S10	30	110.292	-0.327	0.000	0.17	109.3	OK
1.007	S11	29	108.837	-0.463	0.000	0.12	131.2	OK
1.008	S12	17	107.450	-0.100	0.000	0.30	143.8	OK
3.000	S13	30	110.633	-0.192	0.000	0.05	4.6	OK
3.001	S14	29	109.525	-0.240	0.000	0.09	15.8	OK
3.002	S15	29	108.817	-0.243	0.000	0.08	20.5	OK

©1982-2019 Innovyze

PJS Consulting Engineers Limited

Unit 4 Winking Hill Farm

Kingston-on-Soar, Nottingham

Nottinghamshire NG11 0DP

Date 29/06/2023 13:54

File SW Model 17.05.23.mdx

Lutterworth Road

Burbage

Designed by matt.leask

Checked by

Innovyze

Network 2019.1

Page 140



Summary Wizard of 480 minute 100 year Winter I+40% for Surface Water Network

Simulation Criteria

Areal Reduction Factor 1.000

Hot Start (mins) 0

Hot Start Level (mm) 0

Manhole Headloss Coeff (Global) 0.500

Foul Sewage per hectare (l/s) 0.000

Additional Flow - % of Total Flow 0.000

MADD Factor * 10m³/ha Storage 0.000

Inlet Coefficient 0.800

Flow per Person per Day (l/per/day) 0.000

Number of Input Hydrographs 0

Number of Offline Controls 5

Number of Time/Area Diagrams 0

Number of Online Controls 3

Number of Storage Structures 2

Number of Real Time Controls 0

Synthetic Rainfall Details

Rainfall Model FSR

Region England and Wales Cv (Summer) 0.750

M5-60 (mm) 19.600 Cv (Winter) 0.840

Ratio R 0.401

Margin for Flood Risk Warning (mm) 300.0

Analysis Timestep 2.5 Second Increment (Extended)

DTS Status OFF

DVD Status OFF

Inertia Status OFF

Profile(s) Summer and Winter


Duration(s) (mins) 15, 30, 60, 120, 180, 240, 360, 480, 600, 720, 960, 1440

Return Period(s) (years) 1, 30, 100

Climate Change (%) 0, 0, 40

PN	US/MH Name	Storm Rank	Water	Surcharged	Flooded	Flow / Cap.	Overflow (l/s)	Pipe	Status
			Level (m)	Depth (m)	Volume (m³)			Flow (l/s)	
1.000	S4	35	113.896	-0.179	0.000	0.09	7.2	OK	
1.001	S5	35	112.695	-0.180	0.000	0.09	8.1	OK	
1.002	S6	35	112.001	-0.144	0.000	0.28	10.2	OK	
1.003	S7	35	111.701	-0.314	0.000	0.06	18.8	OK	
2.000	S1	35	113.393	-0.282	0.000	0.14	31.8	OK	
2.001	S2	35	112.732	-0.283	0.000	0.14	41.2	OK	
2.002	S3	35	111.560	-0.345	0.000	0.12	47.1	OK	
1.004	S8	35	111.190	-0.260	0.000	0.37	72.7	OK	
1.005	S9	35	110.993	-0.316	0.000	0.19	85.4	OK	
1.006	S10	35	110.278	-0.341	0.000	0.13	87.1	OK	
1.007	S11	35	108.823	-0.477	0.000	0.09	104.6	OK	
1.008	S12	15	107.456	-0.094	0.000	0.24	114.6	OK	
3.000	S13	35	110.629	-0.196	0.000	0.04	3.7	OK	
3.001	S14	35	109.517	-0.248	0.000	0.07	12.6	OK	
3.002	S15	35	108.810	-0.250	0.000	0.07	16.4	OK	

©1982-2019 Innovyze

PJS Consulting Engineers Limited		Page 142
Unit 4 Winking Hill Farm Kingston-on-Soar, Nottingham Nottinghamshire NG11 0DP		
Lutterworth Road Burbage		
Date 29/06/2023 13:54 File SW Model 17.05.23.mdx		
Designed by matt.leask Checked by		
Innovyze		Network 2019.1

Summary Wizard of 600 minute 100 year Winter I+40% for Surface Water Network

Simulation Criteria

Areal Reduction Factor	1.000	Additional Flow - % of Total Flow	0.000
Hot Start (mins)	0	MADD Factor * 10m³/ha Storage	0.000
Hot Start Level (mm)	0	Inlet Coefficient	0.800
Manhole Headloss Coeff (Global)	0.500	Flow per Person per Day (l/per/day)	0.000
Foul Sewage per hectare (l/s)	0.000		

Number of Input Hydrographs	0	Number of Offline Controls	5	Number of Time/Area Diagrams	0
Number of Online Controls	3	Number of Storage Structures	2	Number of Real Time Controls	0

Synthetic Rainfall Details


Rainfall Model	FSR	Ratio R	0.401
Region	England and Wales	Cv (Summer)	0.750
M5-60 (mm)	19.600	Cv (Winter)	0.840

Margin for Flood Risk Warning (mm)	300.0
Analysis Timestep	2.5 Second Increment (Extended)
DTS Status	OFF
DVD Status	OFF
Inertia Status	OFF

Profile(s)	Summer and Winter
Duration(s) (mins)	15, 30, 60, 120, 180, 240, 360, 480, 600, 720, 960, 1440
Return Period(s) (years)	1, 30, 100
Climate Change (%)	0, 0, 40

PN	US/MH Name	Storm Rank	Water	Surcharged	Flooded	Pipe		Status
			Level (m)	Depth (m)	Volume (m³)	Flow / Overflow (l/s)	Flow (l/s)	
1.000	S4	39	113.891	-0.184	0.000	0.08	6.0	OK
1.001	S5	39	112.690	-0.185	0.000	0.07	6.8	OK
1.002	S6	39	111.994	-0.151	0.000	0.24	8.6	OK
1.003	S7	39	111.696	-0.319	0.000	0.05	15.7	OK
2.000	S1	39	113.385	-0.290	0.000	0.12	26.6	OK
2.001	S2	39	112.724	-0.291	0.000	0.11	34.5	OK
2.002	S3	39	111.551	-0.354	0.000	0.10	39.4	OK
1.004	S8	39	111.172	-0.278	0.000	0.31	60.9	OK
1.005	S9	39	110.980	-0.329	0.000	0.16	71.5	OK
1.006	S10	39	110.269	-0.350	0.000	0.11	73.0	OK
1.007	S11	39	108.812	-0.488	0.000	0.08	87.6	OK
1.008	S12	16	107.450	-0.100	0.000	0.20	96.0	OK
3.000	S13	39	110.627	-0.198	0.000	0.03	3.1	OK
3.001	S14	39	109.512	-0.253	0.000	0.06	10.6	OK
3.002	S15	39	108.805	-0.255	0.000	0.06	13.7	OK

©1982-2019 Innovyze

PJS Consulting Engineers Limited		Page 144
Unit 4 Winking Hill Farm Kingston-on-Soar, Nottingham Nottinghamshire NG11 0DP		
Lutterworth Road Burbage		
Date 29/06/2023 13:54 File SW Model 17.05.23.mdx		
Designed by matt.leask Checked by		
Innovyze		Network 2019.1

Summary Wizard of 720 minute 100 year Winter I+40% for Surface Water Network

Simulation Criteria

Areal Reduction Factor	1.000	Additional Flow - % of Total Flow	0.000
Hot Start (mins)	0	MADD Factor * 10m³/ha Storage	0.000
Hot Start Level (mm)	0	Inlet Coefficient	0.800
Manhole Headloss Coeff (Global)	0.500	Flow per Person per Day (l/per/day)	0.000
Foul Sewage per hectare (l/s)	0.000		

Number of Input Hydrographs	0	Number of Offline Controls	5	Number of Time/Area Diagrams	0
Number of Online Controls	3	Number of Storage Structures	2	Number of Real Time Controls	0

Synthetic Rainfall Details

Rainfall Model	FSR	Ratio R	0.401
Region	England and Wales	Cv (Summer)	0.750
M5-60 (mm)	19.600	Cv (Winter)	0.840

Margin for Flood Risk Warning (mm)	300.0
Analysis Timestep	2.5 Second Increment (Extended)
DTS Status	OFF
DVD Status	OFF
Inertia Status	OFF

Profile(s)	Summer and Winter
Duration(s) (mins)	15, 30, 60, 120, 180, 240, 360, 480, 600, 720, 960, 1440
Return Period(s) (years)	1, 30, 100
Climate Change (%)	0, 0, 40

PN	US/MH Name	Storm Rank	Water	Surcharged	Flooded	Pipe		Status
			Level (m)	Depth (m)	Volume (m³)	Flow / Overflow (l/s)	Flow (l/s)	
1.000	S4	42	113.888	-0.187	0.000	0.07	5.2	OK
1.001	S5	42	112.687	-0.188	0.000	0.06	5.9	OK
1.002	S6	42	111.989	-0.156	0.000	0.21	7.4	OK
1.003	S7	42	111.692	-0.323	0.000	0.05	13.6	OK
2.000	S1	42	113.380	-0.295	0.000	0.10	23.0	OK
2.001	S2	42	112.719	-0.296	0.000	0.10	29.9	OK
2.002	S3	42	111.546	-0.359	0.000	0.09	34.1	OK
1.004	S8	42	111.158	-0.292	0.000	0.27	52.7	OK
1.005	S9	42	110.971	-0.338	0.000	0.14	61.9	OK
1.006	S10	42	110.263	-0.356	0.000	0.10	63.2	OK
1.007	S11	42	108.802	-0.498	0.000	0.07	75.8	OK
1.008	S12	18	107.438	-0.112	0.000	0.17	83.1	OK
3.000	S13	42	110.625	-0.200	0.000	0.03	2.7	OK
3.001	S14	42	109.509	-0.256	0.000	0.05	9.1	OK
3.002	S15	42	108.802	-0.258	0.000	0.05	11.9	OK

©1982-2019 Innovyze

PJS Consulting Engineers Limited

Unit 4 Winking Hill Farm

Kingston-on-Soar, Nottingham

Nottinghamshire NG11 0DP

Date 29/06/2023 13:54

File SW Model 17.05.23.mdx

Lutterworth Road

Burbage

Designed by matt.leask

Checked by

Innovyze

Network 2019.1

Page 146



Summary Wizard of 960 minute 100 year Winter I+40% for Surface Water Network

Simulation Criteria

Areal Reduction Factor 1.000

Hot Start (mins) 0

Hot Start Level (mm) 0

Manhole Headloss Coeff (Global) 0.500

Foul Sewage per hectare (l/s) 0.000

Additional Flow - % of Total Flow 0.000

MADD Factor * 10m³/ha Storage 0.000

Inlet Coeffiecient 0.800

Flow per Person per Day (l/per/day) 0.000

Number of Input Hydrographs 0

Number of Offline Controls 5

Number of Time/Area Diagrams 0

Number of Online Controls 3

Number of Storage Structures 2

Number of Real Time Controls 0

Synthetic Rainfall Details

Rainfall Model FSR

Region England and Wales Cv (Summer) 0.750

M5-60 (mm) 19.600 Cv (Winter) 0.840

Ratio R 0.401

Margin for Flood Risk Warning (mm) 300.0

Analysis Timestep 2.5 Second Increment (Extended)

DTS Status OFF

DVD Status OFF

Inertia Status OFF

Profile(s) Summer and Winter

Duration(s) (mins) 15, 30, 60, 120, 180, 240, 360, 480, 600, 720, 960, 1440

Return Period(s) (years) 1, 30, 100

Climate Change (%) 0, 0, 40

PN	US/MH Name	Storm Rank	Water	Surcharged	Flooded	Flow / Cap.	Overflow (l/s)	Pipe	Status
			Level (m)	Depth (m)	Volume (m³)			Flow (l/s)	
1.000	S4	48	113.883	-0.192	0.000	0.05	4.2	OK	
1.001	S5	48	112.682	-0.193	0.000	0.05	4.7	OK	
1.002	S6	48	111.980	-0.165	0.000	0.16	5.9	OK	
1.003	S7	48	111.686	-0.329	0.000	0.04	10.8	OK	
2.000	S1	48	113.371	-0.304	0.000	0.08	18.3	OK	
2.001	S2	48	112.709	-0.306	0.000	0.08	23.7	OK	
2.002	S3	48	111.534	-0.371	0.000	0.07	27.1	OK	
1.004	S8	48	111.141	-0.309	0.000	0.22	41.9	OK	
1.005	S9	48	110.959	-0.350	0.000	0.11	49.2	OK	
1.006	S10	48	110.252	-0.367	0.000	0.08	50.2	OK	
1.007	S11	48	108.790	-0.510	0.000	0.05	60.3	OK	
1.008	S12	22	107.401	-0.149	0.000	0.14	66.0	OK	
3.000	S13	48	110.623	-0.202	0.000	0.02	2.1	OK	
3.001	S14	48	109.504	-0.261	0.000	0.04	7.3	OK	
3.002	S15	48	108.798	-0.262	0.000	0.04	9.4	OK	

©1982-2019 Innovyze

