Jenny Bristow

From: planning@hinckley-bosworth.gov.uk
Posted At: 26 October 2009 04:04
Conversation: ConsulteeAccess for Planning - Application Comments (09/00737/FUL)
Posted To: Planning Application Comments

Subject: ConsulteeAccess for Planning - Application Comments (09/00737/FUL)

ConsulteeAccess for Planning - Application Comments (09/00737/FUL)

"Chris Brown" has used the ConsulteeAccess for Planning website to submit their comments on a Planning Application. You have received this message because you are the Case Officer for this application or because this is a designated mailbox for ConsulteeAccess comments submissions.

Comments were submitted at 26/10/2009 11:04:01 from IP 192.168.0.3.

Application Summary

Application Number:
09/00737/FUL

Address:
11A Elmesthorpe Lane
Earl Shilton
Leicester
LE9 7PT

Proposal:
EXTENSIONS AND ALTERATIONS TO DWELLING (AMENDED SCHEME).

Case Officer:
Richard Wright

Customer Details

Name:
Chris Brown

Address:
HBBC

Postcode:

Email:
chris.brown@hinckley-bosworth.gov.uk

Phone Number:

Comments

Submission Type:

Comments:
If the partial or total paving of the front garden is intended, to replace the parking lost by the removal of the garage, the new access drives, parking and turning areas, paths, etc. should be constructed in a permeable paving system, with or without attenuation storage, depending on ground strata permeability. On low-permeability sites surface water dispersal may be augmented by piped land drains, installed in the foundations of the paving, discharging to an approved outlet. (See Environment Agency guidance on the permeable surfacing of front gardens)