Steve Atkinson MA(Oxon) MBA MioD FRSA
Chief Executive

Please Ask For: Mr R. Wright
Direct Dial/Ext: 01455 255894
Direct Fax:
Email: richard.wright@hinckley-bosworth.gov.uk
Your Ref: SP/1468
Our Ref: 10/00883/FUL
Date: 3 May 2011

Hinckley & Bosworth Borough Council

A Borough to be proud of

Mr Tony Masic
ADM Surveyors Ltd
3A The Parade
Needham Avenue
Leicestershire
LE2 9JW

Dear Mr Masic

Application: 10/00883/FUL - A O Henton Engineering Co Ltd, Cotes Road, Burbage, Leics.

I refer to your application for approval of details reserved by condition dated 21 March 2011 and additional details which followed the submission. I am able to provide you with an updated response.

REFERENCE: 10/00883/FUL

Condition No	Requirement	Details submitted	LPA response
Condition 4	Representative material samples	Sample materials received 23/03/2011	Roof tile, Monier Redland Duo, concrete interlocking, colour slate grey (268 mm x 330 mm) – **Acceptable** Brick, Hanson Breckland Multi Reserve (photo) – **Acceptable**
Condition 5	Scheme for the investigation of potential land contamination	Murray Rix Geotechnical – ref:EJM/GEOJOB/11-296L(B)	Details sent to Giles Rawdon for comment 30/03/2011 Response Giles Rawdon, EH 12/04/2011 – **details acceptable, cannot discharge condition until works complete**
Condition 7	Full details of the method of disposal of surface water drainage	Drainage Layout, dwg 10/1316-01-A	Details sent to Chris Brown, Environmental Health and Severn Trent 30/03/2011 Response Chris Brown, EH 31/03/2011 – **acceptable** Response Severn Trent Water 14/04/2011 - **acceptable**

Yours sincerely

Richard Wright
Area Planning Officer

Council Offices • Argents Mead • Hinckley • Leicestershire • LE10 1BZ
Telephone 01455 238141 • MDX No 716429 • Fax 01455 251172 • www.hinckley-bosworth.gov.uk