PLANNING APPLICATION COMMENT SHEET

RWR	**08/01013/FUL**	Dalebrook Farm Leicester Road Earl Shilton
17.10.2008	**CTF**	CONVERSION OF AGRICULTURAL
COMM		BUILDING TO DWELLING AND
		ALTERATIONS TO ACCESS
		Applicant : Mrs Squires
		Ward : Earl Shilton

ENVIRONMENTAL SERVICES COMMENTS.

This application was included on the list for W/E 17 Oct – and I've already commented. However, my additional comments would be: 'if the track is to be re-surfaced it should be executed in permeable paving (which could merely consist of gravel rather than block paving); or if impermeable paving is used it should shed surface water to a ditch or swale excavated parallel to the track.'

C Brown
Land drainage Engineer
Date:16/12/08

SIGNATURE: DATE