Norma Gudger

From: planning@hinckley-bosworth.gov.uk
Posted At: 01 June 2009 09:42
Conversation: PublicAccess for Planning - Application Comments (09/00369/FUL)
Posted To: Planning Application Comments

Subject: PublicAccess for Planning - Application Comments (09/00369/FUL)

PublicAccess for Planning - Application Comments (09/00369/FUL)

"Geoffrey Pendery" has used the PublicAccess for Planning website to submit their comments on a Planning Application. You have received this message because you are the Case Officer for this application or because this is a designated mailbox for PublicAccess comments submissions.

Comments were submitted at 01/06/2009 09:42:12 from IP 192.168.0.3.

Application Summary

Application Number:
09/00369/FUL

Address:
36 Grove Road
Burbage
Hinckley
LE10 2AD

Proposal:
ERECTION OF 1NO DWELLING

Case Officer:
Eleanor Shaw

Customer Details

Name:
Geoffrey Pendery

Address:
Community Services Department,
Leicestershire County Council,
County Hall,
Glenfield,
Leicester.

Postcode:
LE3 8TE

Email:
gpendery@leics.gov.uk

Phone Number:
0116 305 7084

Comments

Submission Type:
Customer wishes to comment on the Planning Application.

Comments:
Public footpath U62 will be intersected by the access drive to the proposed dwelling.

In the event of planning consent being granted, dropped kerbs should be provided for

the benefit of wheelchair users where the footpath is intersected by the access drive.

In order to enhance the safety of pedestrians while crossing the access drive, the footpath should also be clearly delineated to a minimum width of 1.8 metres by "zebra hatching."

The footpath should not be affected by any operations associated with the construction of the new dwelling, and pedestrians should be able to gain access safely along the route at all times.

PublicAccess for Planning. (c) CAPS Solutions Ltd.