Lesley Keal

From:	planning@hinckley-bosworth.gov.uk
Posted At:	26 October 2010 11:55
Conversation:	ConsulteeAccess for Planning - Application Comments (10/00590/FUL)
Posted To:	Planning Application Comments
Subject:	ConsulteeAccess for Planning - Application Comments (10/00590/FUL)

ConsulteeAccess for Planning - Application Comments (10/00590/FUL)

"Chris Brown" has used the ConsulteeAccess for Planning website to submit their comments on a Planning Application. You have received this message because you are the Case Officer for this application or because this is a designated mailbox for ConsulteeAccess comments submissions.

ConsulteeAccess for Planning - Application Comments for 10/00590/FUL "Chris Brown" you have been sent this email because you or somebody else has submitted a comment on a Planning Application to the planning department using your email address.
A summary of your comments is provided below.
Comments were submitted at 26/10/2010 11:54:55 from chris.brown@hinckley-bosworth.gov.uk
Application Summary

Application Number: 10/00590/FUL
Address:
Land At The Rear Of
34 Fern Crescent
Groby
Leicester
Leicestershire
LE6 0BE
Proposal:
CREATION OF NEW ACCESS,FORMATION OF NEW MENAGE, REPLACEMENT STABLE BLOCK AND ERECTION OF GARAGE FOR HORSE TRAILER BOX Case Officer:
Sarah Fryer
Customer Details

Name:
Chris Brown
Address:
empty
Comments:
Stables and livestock sheds:

Animal waste and surface water contaminated by animal waste must not be discharged to ditches, watercourses or soakaways. Slurry, contaminated runoff - including wash water - and leachate from stockpiled manure, must be collected in tanks (or lagoons) complying with the standards laid down in the 'Control of Pollution (Silage, Slurry and Agricultural Fuel Oil) Regulations 1991'. Clean roof water should be discharged to soakaways (subject to suitable ground strata), ditches or watercourses.

Access drives, parking and turning areas should be constructed in a permeable paving system, with or without attenuation storage, depending on ground strata permeability. On low-permeability sites surface water dispersal may be augmented by piped land drains, installed in the foundations of the paving, discharging to an approved outlet.
ConsulteeAccess for Planning. (c) CAPS Solutions Ltd.

ConsulteeAccess for Planning. (c) CAPS Solutions Ltd.