
From: public.access@hinckley-bosworth.gov.uk
Sent: 17 April 2025 10:37
To: Planning Application Comments
Subject: Consultee Comments for Planning Application 25/00241/DISCON
Categories: Yasmin

Consultee comments

Dear Sir/Madam,

A consultee has commented on a Planning Application. A summary of the comments is provided below.

Comments were submitted at 17/04/2025 10:36 AM from Mr Giles Rawdon (giles.rawdon@hinckley-bosworth.gov.uk) on behalf of HBBC ES Pollution 2.

Application Summary

Reference:	25/00241/DISCON
Address:	Land West Of Clickers Way Earl Shilton Leicestershire
Proposal:	Application to discharge condition 12 (Construction Environmental Management Plan) attached to planning permission 20/01225/FUL cr
Case Officer:	Lesley Keal

[Click for further information](#)

Comments Details

Will and plant/equipment be operated outside the site operating hours (e.g. generators/pumps etc)? if not this should be expressed in the CEMP if so details should be included including locations and noise data together with any details of proposed noise control.

Comments: Details of public liaison should included- this should include a letter drop to potentially affected residents including details of the works, timescales, likely impacts and a named contact in the event of complaints.

Details of noise monitoring should be included in the event of noise complaints. The site limit using BS5228 should be set at 65dB Laeq(t).

Kind regards