

Hinckley & Bosworth Borough Council

Town and Country Planning Act 1990 (as amended) Discharge of Conditions

DoC Decision Notice Condition Discharged

C/o Mr Sam Cripps
Turley
9 Colmore Row
Birmingham
B3 2BJ
United Kingdom

Details of Application:

Application Ref: 23/00903/DISCON
Proposal: Application to discharge condition 12 (External Lighting Statement) of planning application 22/00430/FUL
Location: Land East Of Hinckley Island Hotel Watling Street Burbage Hinckley

Condition 12

Lighting within the site shall be installed, maintained and operated in accordance with the details provided in the External Lighting Report carried out by CPW reference 220192 and dated 13.04.2022. Upon completion of the development, a statement of a suitably qualified contractor shall be submitted stating that any external lighting installation is fully compliant with the Institution of Lighting Professionals Guidance Notes on the Reduction of Obtrusive Light, Guidance Note 01/21; for a sign within zone E2.

C12 External Lighting – Received 13 September 2023

The details submitted are **ACCEPTABLE** and Condition 12 is hereby **DISCHARGED**, subject to the scheme being carried out strictly with the full terms of the condition.



Christopher Brown MRTPI
Head of Planning

Date : 29 September 2023