

**From:** public.access@hinckley-bosworth.gov.uk <public.access@hinckley-bosworth.gov.uk>  
**Sent:** 03 February 2026 15:49:17 UTC+00:00  
**To:** "PF - Planning" <planningapplications@hinckley-bosworth.gov.uk>  
**Subject:** Consultee Comments for Planning Application 25/01207/OUT  
**Categories:** Yasmin

## Consultee comments

Dear Sir/Madam,

A consultee has commented on a Planning Application. A summary of the comments is provided below.

Comments were submitted at 03/02/2026 3:49 PM from Mr Peter Reid (peter.reid@hinckley-bosworth.gov.uk) on behalf of HBBC Drainage.

### Application Summary

Reference:	25/01207/OUT
Address:	Land To The East Of Ashby Road Ashby Road Hinckley Leicestershire
Proposal:	Outline application for up to 103 dwellings (All matters reserved except access)
Case Officer:	Sullivan Archer

[Click for further information](#)

### Comments Details

No objection subject to the following conditions:

Comments: Development shall not begin until a scheme to provide a sustainable surface water drainage system in accordance with the Flood Risk Assessment and Drainage Strategy dated August 2025 has been submitted to and approved by the Local Planning Authority, and the scheme shall subsequently be implemented in accordance with the approved details before the development is completed.

Prior to commencement of development details in relation to the management of surface water on site during construction of the development shall be submitted to, and approved in writing by, the Local Planning Authority. Details should demonstrate how surface water will be managed on site to prevent an increase in flood risk

during the various construction stages of development from initial site works through to completion. This shall include temporary attenuation, additional treatment, controls, maintenance and protection. Details regarding the protection of any proposed infiltration areas should also be provided.

Prior to commencement of development details in relation to the long term maintenance of the sustainable surface water drainage system on the development shall be submitted to and approved in writing by the Local Planning Authority. Details of the SuDS Maintenance Plan should include responsibilities and schedules for routine maintenance, remedial actions and monitoring of the separate elements of the system and should also include procedures that must be implemented in the event of pollution incidents within the development site.

---

Kind regards

This email and any files sent with it are confidential. If this email isn't intended for you, please notify the sender immediately and then permanently delete it. You must not read, print, store, disclose, copy or take any other action in respect of this email. We routinely monitor incoming and outgoing email messages to ensure they comply with Hinckley & Bosworth Borough Council's policy on the use of electronic communications. The contents of emails may have to be disclosed to a request under the Data Protection Act 2018, Freedom of Information Act 2000 and/or the Environmental Information Regulations 2004. The views expressed by the author may not necessarily reflect the views or policies of Hinckley & Bosworth Borough Council. Attachments to email messages may contain viruses that may damage your system. Whilst Hinckley & Bosworth Borough Council has taken every reasonable precaution to minimise this risk, we cannot accept any liability for any damage you suffer as a result. You are advised to carry out your own virus checks before opening any attachment. Save paper - only print this email if necessary. Visit us online: [www.hinckley-bosworth.gov.uk](http://www.hinckley-bosworth.gov.uk) Main office: Hinckley Hub, Rugby Road, Hinckley, Leics LE10 0FR