
From: public.access@hinckley-bosworth.gov.uk
Sent: 12 September 2025 09:52
To: Planning Application Comments
Subject: Consultee Comments for Planning Application 25/00822/FUL
Categories: Yasmin

Consultee comments

Dear Sir/Madam,

A consultee has commented on a Planning Application. A summary of the comments is provided below.

Comments were submitted at 12/09/2025 9:51 AM from Mr Simon Smith (simon.smith@hinckley-bosworth.gov.uk) on behalf of HBBC ES Pollution 1.

Application Summary

Reference:	25/00822/FUL
Address:	Stoke Golding Methodist Church Main Street Stoke Golding Nuneaton Leicestershire CV13 6HP
Proposal:	Installation of externally mounted air conditioning and heat pump equipment
Case Officer:	Sophie Iliffe

[Click for further information](#)

Comments Details

Comments:	It is recommended that the new fence be close boarded with a density of 10kg/m2.
-----------	--

Kind regards