

Application address Former Factory Works Upper Bond Street, Hinckley.		Planning ref. 23/00383/FUL	
		Our ref. 2023/0383/04/F	
Description Proposed erection of residential apartments (following demolition Laban Tansey building,) and associated solar panels, parking, and landscaping on land between Druid Street and Upper Bond Street.		Consultation date 09/05/2023	
		Response date 24/05/2023	
Planning officer Matt Jedruch		Reviewing officer Jack Harriman	
Application type Full		Extension requested ☐	
Refer to standing advice ☐	Conditions ☐	Further consultation required ☒	Concerns ☐

Consultation checklist

No.	Description	Check
1	Location plan	☒
2	Proposed layout plan	☒
3	Evidence that the site can be drained	☐
4	Topographic and ground investigation details	☐
5	The total impermeable area pre and post development	☐
6	All potential flood risk sources have been identified and assessed	☐
7	Existing and proposed peak discharge rates	☐
8	Consideration of sustainable drainage systems	☐
9	Attenuation volume calculations	☐
10	Consideration of the maintenance and management of all drainage elements	☐

LLFA Key Observations and Advice

Leicestershire County Council as Lead Local Flood Authority (LLFA) notes that the 0.1ha brownfield site is located within Flood Zone 1 being at low risk of fluvial flooding and a low risk of surface water flooding.

The proposals are not include any consideration of flood or surface water drainage proposals. Due to the proposed number of dwellings this application is classified as major and thus these are advised to be necessary under the National Planning Policy Framework. A surface water

drainage strategy should be to a sufficient standard to address the items on the above checklist. For further guidance, the applicant can view the standing advice and the link at the bottom of this consultation response.

Leicestershire County Council as Lead Local Flood Authority (LLFA) advises the Local Planning Authority (LPA) that the application documents as submitted are insufficient for the LLFA to provide a substantive response at this stage. In order to provide a substantive response, the following information is required:

- Consideration of flood risk from all sources (note that this does not need to be a full NPPF compliant flood risk assessment)
 - A surface water drainage strategy that considers all items within the above checklist.
-

Advice to the Local Planning Authority

1. Standing Advice – National Planning Policy Framework

When determining planning applications, the local planning authority should ensure flood risk is not increased elsewhere and only consider development appropriate in areas at risk of flooding where informed by a site specific Flood Risk Assessment (FRA) confirming it will not put the users of the development at risk. Where an FRA is applicable this should be undertaken in accordance with the requirements of the National Planning Policy Framework and accompanying Planning Practice Guidance.

2. Standing Advice – Consent

Where there are any works proposed as part of an application which are likely to affect flows in an ordinary watercourse or ditch, the applicant will require consent under Section 23 of the Land Drainage Act 1991. This is in addition to any planning permission that may be granted. Guidance on this process and a sample application form can be found via the following website: <http://www.leicestershire.gov.uk/flood-risk-management>

Applicants are advised to refer to Leicestershire County Council's culverting policy contained within the Local Flood Risk Management Strategy Appendix document, available at the above link. No development should take place within 5 metres of any watercourse or ditch without first contacting the County Council for advice.

This consent does not consider local watercourse bylaws. It is the responsibility of the applicant to check if the local borough or district council has their own bylaws which the proposals will also need to consider.

3. Standing Advice – Maintenance

Note that it is the responsibility of the Local Planning Authority under the DEFRA/DCLG legislation (April 2015) to ensure that a system to facilitate the future maintenance of SuDS features can be managed and maintained in perpetuity before commencement of the works.

4. Standing Advice – Brownfield Development Runoff

For brownfield sites, the peak runoff rate from the development to any drain, sewer or surface water body for the 1 in 1 year rainfall event and the 1 in 100 year rainfall event must seek to discharge at greenfield runoff rate from the development for the same rainfall event. Where this is clearly demonstrated to not be reasonably practicable, discharge should be restricted as close to greenfield rates as reasonably practicable, but should never exceed the rate of discharge from the site prior to redevelopment.

The runoff volume from the development in the 1 in 100 year, 6 hour rainfall event should be constrained to a value as close as is reasonably practicable to the greenfield runoff volume for the same event, but should not exceed the runoff volume from the development site prior to redevelopment for that event. Where an increase in discharge volume is unavoidable, the proposals should discharge at QBar or provide alternative mitigation in line with CIRIA C753.

5. Standing Advice – Drainage and waste disposal

Where a drainage or waste disposal system is to be constructed or altered that is not proposed to be adopted by either the WASC (Water and Sewerage Company) or the County Council as highway authority then the system should be constructed in accordance with Part H of Building Regulations 2010.

6. Standing Advice – External surfaces

To prevent an increase in the discharge rate or volume due to development of external surfaces, permeable surface material should be utilised where possible, without an impermeable lining unless required to prevent mobilisation of contaminants or groundwater flooding.

Additional information and guidance is available here:

<https://www.leicestershire.gov.uk/environment-and-planning/flooding-and-drainage/>

Note: Response provided by the Lead Local Flood Authority under the delegated authority of the Director of Environment and Transport.