Denise Stone

From: planning@hinckley-bosworth.gov.uk
Posted At: 17 July 2009 13:48
Conversation: ConsulteeAccess for Planning - Application Comments (09/00507/FUL)
Posted To: Planning Application Comments

Subject: ConsulteeAccess for Planning - Application Comments (09/00507/FUL)

ConsulteeAccess for Planning - Application Comments (09/00507/FUL)

"Chris Brown" has used the ConsulteeAccess for Planning website to submit their comments on a Planning Application. You have received this message because you are the Case Officer for this application or because this is a designated mailbox for ConsulteeAccess comments submissions.

Comments were submitted at 17/07/2009 13:48:01 from IP 192.168.0.3.

Application Summary

Application Number:
09/00507/FUL

Address:
7 Desford Lane
Kirkby Mallory
Leicester
LE9 7QF

Proposal:
EXTENSIONS AND ALTERATIONS TO DWELLING INCLUDING ERECTION OF DETACHED GARAGE.

Case Officer:
Eleanor Shaw

Customer Details

Name:
Chris Brown

Address:
HBBC

Postcode:

Email:
chris.brown@hinckley-bosworth.gov.uk

Phone Number:

Comments

Submission Type:

Comments:
Surface water from roof areas should be discharged to a soakaway (subject to satisfactory ground stata), a swale or a ditch.

Access drives, parking and turning areas, paths and patios should be constructed in a permeable paving system, with or without attenuation storage, depending on ground strata permeability. On low-permeability sites surface water dispersal may be augmented by piped land drains, installed in the foundations of the paving,

discharging to an approved outlet.

ConsulteeAccess for Planning. (c) CAPS Solutions Ltd.