Denise Stone

From: planning@hinckley-bosworth.gov.uk
Posted At: 17 July 2009 13:59
Conversation: ConsulteeAccess for Planning - Application Comments (09/00504/FUL)
Posted To: Planning Application Comments

Subject: ConsulteeAccess for Planning - Application Comments (09/00504/FUL)

ConsulteeAccess for Planning - Application Comments (09/00504/FUL)

"Chris Brown" has used the ConsulteeAccess for Planning website to submit their comments on a Planning Application. You have received this message because you are the Case Officer for this application or because this is a designated mailbox for ConsulteeAccess comments submissions.

Comments were submitted at 17/07/2009 13:59:02 from IP 192.168.0.3.

Application Summary

Application Number:
09/00504/FUL

Address:
12 Marina Drive
Groby
Leicester
LE6 0DX

Proposal:
EXTENSIONS AND ALTERATIONS TO DWELLING.

Case Officer:
Richard Wright

Customer Details

Name:
Chris Brown

Address:
HBBC

Postcode:

Email:
chris.brown@hinckley-bosworth.gov.uk

Phone Number:

Comments

Submission Type:

Comments:
Access drives, parking and turning areas, paths and patios should be constructed in a permeable paving system, with or without attenuation storage, depending on ground strata permeability. On low-permeability sites surface water dispersal may be augmented by piped land drains, installed in the foundations of the paving, discharging to an approved outlet.