

Stephen Daykin Consulting Ltd		Page 0
33 Beaumaris Drive Gedling Nottingham NG4 2RA		
Date 01/01/0001 File E970 - NETWORK 2 (V4 JU...	Designed by SteveDaykin Checked by	
Innovyze	Network 2018.1.1	

STORM SEWER DESIGN by the Modified Rational Method

Design Criteria for E970 - NETWORK 2 (V2).SWS

Pipe Sizes E970 - NETWORK 2 (V2) Manhole Sizes E970 - NETWORK 2 (V2)

FSR Rainfall Model - England and Wales			
Return Period (years)	5	PIMP (%)	100
M5-60 (mm)	20.000	Add Flow / Climate Change (%)	10
Ratio R	0.400	Minimum Backdrop Height (m)	0.200
Maximum Rainfall (mm/hr)	0	Maximum Backdrop Height (m)	0.000
Maximum Time of Concentration (mins)	30	Min Design Depth for Optimisation (m)	1.200
Foul Sewage (l/s/ha)	0.000	Min Vel for Auto Design only (m/s)	0.75
Volumetric Runoff Coeff.	0.750	Min Slope for Optimisation (1:X)	500

Designed with Level Soffits

Time Area Diagram for E970 - NETWORK 2 (V2).SWS

Time (mins)	Area (ha)	Time (mins)	Area (ha)
0-4	0.959	4-8	0.618

Total Area Contributing (ha) = 1.577

Total Pipe Volume (m³) = 90.762

Network Design Table for E970 - NETWORK 2 (V2).SWS

- Indicates pipe length does not match coordinates

PN	Length (m)	Fall (m)	Slope (1:X)	I.Area (ha)	T.E. (mins)	Base Flow (l/s)	k (mm)	HYD SECT	DIA (mm)	Section Type	Auto Design
1.000	22.288	0.200	111.4	0.154	5.00	0.0	0.600	o	300	Pipe/Conduit	
1.001	18.448	0.275	67.1	0.054	0.00	0.0	0.600	o	300	Pipe/Conduit	
2.000	57.679	0.375	153.8	0.133	5.00	0.0	0.600	o	300	Pipe/Conduit	

Network Results Table

PN	Rain (mm/hr)	T.C. (mins)	US/IL (m)	Σ I.Area (ha)	Σ Base Flow (l/s)	Foul (l/s)	Add Flow (l/s)	Vel (m/s)	Cap (l/s)	Flow (l/s)
1.000	0.00	5.25	119.425	0.154	0.0	0.0	0.0	1.49	105.2	0.0
1.001	0.00	5.41	119.225	0.208	0.0	0.0	0.0	1.92	135.9	0.0
2.000	0.00	5.76	119.325	0.133	0.0	0.0	0.0	1.27	89.4	0.0

Stephen Daykin Consulting Ltd

33 Beaumaris Drive
Gedling
Nottingham NG4 2RA

Date 01/01/0001
File E970 - NETWORK 2 (V4 JU...

Innovyze

Page 1



Designed by SteveDaykin
Checked by

Network 2018.1.1

Network Design Table for E970 - NETWORK 2 (V2).SWS

PN	Length (m)	Fall (m)	Slope (1:X)	I.Area (ha)	T.E. (mins)	Base Flow (l/s)	k (mm)	HYD SECT	DIA (mm)	Section Type	Auto Design
1.002	69.832	3.075	22.7	0.152	0.00	0.0	0.600	o	300	Pipe/Conduit	
1.003	51.877	3.150	16.5	0.221	0.00	0.0	0.600	o	375	Pipe/Conduit	
3.000	55.541#	0.450	123.4	0.171	5.00	0.0	0.600	o	300	Pipe/Conduit	
1.004	46.198	2.596	17.8	0.151	0.00	0.0	0.600	o	450	Pipe/Conduit	
4.000	43.103	0.181	238.1	0.161	5.00	0.0	0.600	o	300	Pipe/Conduit	
1.005	63.100	2.429	26.0	0.176	0.00	0.0	0.600	o	600	Pipe/Conduit	
1.006	27.815	0.100	278.2	0.142	0.00	0.0	0.600	o	600	Pipe/Conduit	
1.007	11.291	0.075	150.5	0.062	0.00	0.0	0.600	ooo	49	Pipe/Conduit	
1.008	26.528	0.375	70.7	0.000	0.00	0.0	0.600	ooo	49	Pipe/Conduit	
1.009	9.759	0.400	24.4	0.000	0.00	0.0	0.600	o	300	Pipe/Conduit	
1.010	5.000	0.050	100.0	0.000	0.00	0.0	0.600	o	300	Pipe/Conduit	

Network Results Table

PN	Rain (mm/hr)	T.C. (mins)	US/IL (m)	Σ I.Area (ha)	Σ Base Flow (l/s)	Foul (l/s)	Add Flow (l/s)	Vel (m/s)	Cap (l/s)	Flow (l/s)
1.002	0.00	6.11	118.950	0.493	0.0	0.0	0.0	3.31	234.2	0.0
1.003	0.00	6.30	115.800	0.714	0.0	0.0	0.0	4.48	495.2	0.0
3.000	0.00	5.65	113.100	0.171	0.0	0.0	0.0	1.41	99.9	0.0
1.004	0.00	6.46	112.575	1.036	0.0	0.0	0.0	4.84	769.3	0.0
4.000	0.00	5.71	110.310	0.161	0.0	0.0	0.0	1.01	71.7	0.0
1.005	0.00	6.68	109.829	1.373	0.0	0.0	0.0	4.79	1354.5	0.0
1.006	0.00	7.00	107.400	1.515	0.0	0.0	0.0	1.46	411.4	0.0
1.007	0.00	7.10	107.300	1.577	0.0	0.0	0.0	1.98	1680.8	0.0
1.008	0.00	7.25	107.225	1.577	0.0	0.0	0.0	2.90	2457.0	0.0
1.009	0.00	7.30	106.775	1.577	0.0	0.0	0.0	3.20	225.9	0.0
1.010	0.00	7.35	106.375	1.577	0.0	0.0	0.0	1.57	111.1	0.0

Conduit Sections for E970 - NETWORK 2 (V2).SWS

NOTE: Diameters less than 66 refer to section numbers of hydraulic conduits. These conduits are marked by the symbols:- [] box culvert, \ / open channel, oo dual pipe, ooo triple pipe, O egg.

Section numbers < 0 are taken from user conduit table

Section Number	Conduit Type	Major Dimn. (mm)	Minor Dimn. (mm)	Side Slope (Deg)	Corner Splay (mm)	4*Hyd Radius (m)	XSect Area (m²)
49	ooo	1800	600			0.600	0.848

©1982-2018

Innovyze

Stephen Daykin Consulting Ltd		Page 2
33 Beaumaris Drive Gedling Nottingham NG4 2RA		
Date 01/01/0001 File E970 - NETWORK 2 (V4 JU...	Designed by SteveDaykin Checked by	
Innovyze	Network 2018.1.1	

Online Controls for E970 - NETWORK 2 (V2).SWS

Hydro-Brake® Optimum Manhole: 209, DS/PN: 1.009, Volume (m³): 31.8

Unit Reference	MD-SHE-0139-1000-1450-1000
Design Head (m)	1.450
Design Flow (l/s)	10.0
Flush-Flo™	Calculated
Objective	Minimise upstream storage
Application	Surface
Sump Available	Yes
Diameter (mm)	139
Invert Level (m)	106.850
Minimum Outlet Pipe Diameter (mm)	225
Suggested Manhole Diameter (mm)	1200


Control Points	Head (m)	Flow (l/s)
Design Point (Calculated)	1.450	10.0
Flush-Flo™	0.430	10.0
Kick-Flo®	0.911	8.0
Mean Flow over Head Range	-	8.7

The hydrological calculations have been based on the Head/Discharge relationship for the Hydro-Brake® Optimum as specified. Should another type of control device other than a Hydro-Brake Optimum® be utilised then these storage routing calculations will be invalidated

Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)
0.100	5.0	1.200	9.1	3.000	14.1	7.000	21.2
0.200	9.1	1.400	9.8	3.500	15.2	7.500	21.9
0.300	9.8	1.600	10.5	4.000	16.2	8.000	22.6
0.400	10.0	1.800	11.1	4.500	17.1	8.500	23.2
0.500	10.0	2.000	11.6	5.000	18.0	9.000	23.9
0.600	9.8	2.200	12.2	5.500	18.8	9.500	24.5
0.800	9.1	2.400	12.7	6.000	19.6		
1.000	8.4	2.600	13.2	6.500	20.4		

©1982-2018 Innovyze

Stephen Daykin Consulting Ltd		Page 3												
33 Beaumaris Drive Gedling Nottingham NG4 2RA														
Date 01/01/0001 File E970 - NETWORK 2 (V4 JU...	Designed by SteveDaykin Checked by													
Innovyze Network 2018.1.1														
<u>Storage Structures for E970 - NETWORK 2 (V2).SWS</u> <u>Tank or Pond Manhole: 209, DS/PN: 1.009</u> Invert Level (m) 106.900 <table><tr><td>Depth (m)</td><td>Area (m²)</td><td>Depth (m)</td><td>Area (m²)</td><td>Depth (m)</td><td>Area (m²)</td></tr><tr><td>0.000</td><td>658.0</td><td>1.500</td><td>1208.0</td><td>1.550</td><td>1431.0</td></tr></table>			Depth (m)	Area (m²)	Depth (m)	Area (m²)	Depth (m)	Area (m²)	0.000	658.0	1.500	1208.0	1.550	1431.0
Depth (m)	Area (m²)	Depth (m)	Area (m²)	Depth (m)	Area (m²)									
0.000	658.0	1.500	1208.0	1.550	1431.0									
©1982-2018 Innovyze														

Stephen Daykin Consulting Ltd		Page 4
33 Beaumaris Drive Gedling Nottingham NG4 2RA		
Date 01/01/0001 File E970 - NETWORK 2 (V4 JU...	Designed by SteveDaykin Checked by	
Innovyze Network 2018.1.1		

Summary of Critical Results by Maximum Level (Rank 1) for E970 - NETWORK 2 (V2).SWS

Simulation Criteria

Areal Reduction Factor	1.000	Additional Flow - % of Total Flow	7.000
Hot Start (mins)	0	MADD Factor * 10m³/ha Storage	1.000
Hot Start Level (mm)	0	Inlet Coeffiecient	0.800
Manhole Headloss Coeff (Global)	0.500	Flow per Person per Day (l/per/day)	0.000
Foul Sewage per hectare (l/s)	0.000		

Number of Input Hydrographs	0	Number of Storage Structures	1
Number of Online Controls	1	Number of Time/Area Diagrams	0
Number of Offline Controls	0	Number of Real Time Controls	0

Synthetic Rainfall Details

Rainfall Model	FSR	Ratio R	0.400
Region England and Wales Cv (Summer)	1.000		
M5-60 (mm)	20.000	Cv (Winter)	1.000

Margin for Flood Risk Warning (mm)	300.0
Analysis Timestep	2.5 Second Increment (Extended)
DTS Status	ON
DVD Status	OFF
Inertia Status	OFF

Profile(s)	Summer and Winter
Duration(s) (mins)	30, 60, 120, 180, 240, 360, 480, 600, 720, 960, 1440, 2160, 2880, 4320, 5760, 7200, 8640, 10080
Return Period(s) (years)	100
Climate Change (%)	40

PN	US/MH Name	Storm	Return Period	Climate Change	First (X) Surge	First (Y) Flood	First (Z) Overflow	Overflow Act.
1.000	200	30 Summer	100	+40%	100/30 Summer			
1.001	201	30 Summer	100	+40%	100/30 Summer			
2.000	212	30 Summer	100	+40%	100/30 Summer	100/30 Summer		
1.002	202	30 Summer	100	+40%	100/30 Summer	100/30 Summer		
1.003	203	30 Summer	100	+40%				
3.000	214	30 Summer	100	+40%	100/30 Summer			
1.004	204	30 Summer	100	+40%				
4.000	216	30 Summer	100	+40%	100/30 Summer			
1.005	205	30 Summer	100	+40%				
1.006	206	30 Summer	100	+40%	100/30 Summer			
1.007	207	960 Summer	100	+40%	100/60 Summer			
1.008	208	960 Summer	100	+40%	100/60 Summer			
1.009	209	960 Summer	100	+40%	100/30 Summer			
1.010	14	5760 Winter	100	+40%	100/30 Summer			

©1982-2018 Innovyze

Stephen Daykin Consulting Ltd		Page 5
33 Beaumaris Drive Gedling Nottingham NG4 2RA		
Date 01/01/0001 File E970 - NETWORK 2 (V4 JU...	Designed by SteveDaykin Checked by	
Innovyze	Network 2018.1.1	

Summary of Critical Results by Maximum Level (Rank 1) for E970 - NETWORK 2 (V2).SWS

PN	US/MH Name	Water Level (m)	Surcharged Depth (m)	Flooded Volume (m³)	Flow / Overflow Cap. (l/s)	Pipe Flow (l/s)	Status	Level Exceeded
1.000	200	121.437	1.712	0.000	1.20	111.7	FLOOD RISK	
1.001	201	121.133	1.608	0.000	1.27	148.3	FLOOD RISK	
2.000	212	121.008	1.383	1.853	0.96	81.4	FLOOD	1
1.002	202	120.663	1.413	7.525	1.21	271.3	FLOOD	1
1.003	203	116.096	-0.079	0.000	0.97	443.1	OK	
3.000	214	113.801	0.401	0.000	1.35	127.6	SURCHARGED	
1.004	204	112.934	-0.091	0.000	0.99	685.9	OK	
4.000	216	111.030	0.420	0.000	1.79	120.1	SURCHARGED	
1.005	205	110.358	-0.071	0.000	0.76	923.3	OK	
1.006	206	108.934	0.934	0.000	3.10	1026.0	SURCHARGED	
1.007	207	108.422	0.522	0.000	0.12	122.9	SURCHARGED	
1.008	208	108.422	0.597	0.000	0.07	122.5	FLOOD RISK	
1.009	209	108.421	1.346	0.000	0.06	10.0	FLOOD RISK	
1.010	14	107.258	0.583	0.000	0.52	31.7	SURCHARGED	