



IWNL NOTES

- PIPE MATERIAL NOTES

1. ALL ADAPTABLE SEWERS 300MM DIAMETER AND LESS SHALL BE HDPE PIPE SYSTEMS TO BS EN13476 AND BEDDED IN ACCORDANCE WITH BS EN 1295.
2. ALL CONCRETE PIPES SHALL BE CLASS 120 - TO EN 197 AND BS5155 5911-1. 2002. ALL CONCRETE MANHOLES SHALL BE TO BS EN 1917 AND BS6183.
3. ALL PIPE BEDDING SHALL BE CLASS 5 COMPLETE GRANULAR SURROUND UNLESS OTHERWISE SPECIFIED. REFER TO SEWER STANDARD CONSTRUCTION DETAILS FOR CONFIRMATION OF ACCEPTABLE AGGREGATE SIZES
4. ADAPTABLE PLASTIC SEWER PIPES SHOULD BE BS1 KITEMARKED (CERTIFIED TO WS 4-35-01).
5. SHOULD THE CONTRACTOR WISH TO CHANGE ANY MATERIAL, THIS WILL REQUIRE THE APPROVAL FROM THE APPROVING AUTHORITY IN WRITING AND ANY PROPOSED CHANGE SHOULD BE SOUGHT APPROVED PRIOR TO THE ORDERING OF ANY MATERIALS.

Stephen Daykin Consulting Ltd

A design consultancy for the development industry
33 Beaumaris Drive
Gedling
Nottingham
NG4 2RA

Tel 0115 9404321
mobile 07968 765381
steve@sdcivils.com

Managing Director
Stephen W Daykin I.Eng AMICE MCIHT