



BURN, CHEMICAL BURN, CONTAMINATION, DISEASE, ASPHYXIATION, POISONING

VNL NOTES

PIPE MATERIAL NOTES:

1. ALL ADAPTABLE SEWERS 300MM DIAMETER AND LESS SHALL BE HDPE PIPES TO BS EN13476 AND BEDDED IN ACCORDANCE WITH BS EN 1056.
2. ALL CONCRETE PIPES SHALL BE CLASS 120 TO EN 1916/BS 5911-1: 2002. ALL CONCRETE MANHOLES SHALL BE TO BS EN 1917 AND BS5913-3.
3. ALL PIPE BEDDING SHALL BE CLASS C COMPLETE GRANULAR SURROUND UNLESS OTHERWISE SPECIFIED. REFER TO SEWER STANDARD CONSTRUCTION DETAILS FOR CONFIRMATION OF ADEQUATE AGGREGATE SIZES
4. ADAPTABLE PLASTIC SEWER PIPES SHOULD BE TO BS1 KITEMARKED (CERTIFIED TO WS 435-01).
5. SHOULD THE CONTRACTOR WISH TO CHANGE ANY MATERIAL THIS WILL REQUIRE THE APPROVAL FROM THE ADOPTING AUTHORITY IN WRITING AND ANY PROPOSED CHANGE SHOULD SEEK APPROVAL PRIOR TO THE ORDERING OF ANY MATERIAL.

Stephen Daykin Consulting Ltd
A design consultancy for the development industry
33 Beaumaris Drive
Gedling
Nottingham
NG4 2RA

Tel 0115 9404321
mobile 07968 765381
steve@sdcivils.com

Managing Director
Stephen W Daykin I.Eng AMICE MCIHT

Rev	Description	Initial	Date
A	Updated to latest Arch Layout rev J rec 30.04.26	JW	08.06.26
B	General update of sewer profiles following change of design parameters Aug 26	SWD	20.08.26

ROAD AND SEWER LONG SECTIONS HINCKLEY



Dwg No. H0997-314-10 Rev B	
Scale 1:500	Date 17.03.2017
Drawn by JM	Checked by MM

NORTH MIDLANDS
Design & Technical Department
2 Horizon Place - Nottingham Business Park
NOTTINGHAM NG8 6BY