
From: public.access@hinckley-bosworth.gov.uk
Sent: 26 March 2025 17:07
To: Planning Application Comments
Subject: Consultee Comments for Planning Application 25/00230/DISCON
Categories: Yasmin

Consultee comments

Dear Sir/Madam,

A consultee has commented on a Planning Application. A summary of the comments is provided below.

Comments were submitted at 26/03/2025 5:06 PM from Mr Peter Reid (peter.reid@hinckley-bosworth.gov.uk) on behalf of HBBC Drainage.

Application Summary

Reference:	25/00230/DISCON
Address:	Land West Of Clickers Way Earl Shilton Leicestershire
Proposal:	Application to discharge C7 (Surface Water Drainage Scheme), C8 (Management of Surface Water During Construction) attached to planning permission 20/01225/FUL
Case Officer:	Lesley Keal

[Click for further information](#)

Comments Details

Comments: C7 - submitted details satisfactory in principle, construction details of all SuDS elements should be submitted for review along with a plan indicating exceedance flow routes.

C8 - submitted details satisfactory in principle, subject to discharge of Condition 7

Kind regards