Denise Stone

From: planning@hinckley-bosworth.gov.uk
Posted At: 05 August 2009 12:25
Conversation: ConsulteeAccess for Planning - Application Comments (09/00573/REM)
Posted To: Planning Application Comments

Subject: ConsulteeAccess for Planning - Application Comments (09/00573/REM)

ConsulteeAccess for Planning - Application Comments (09/00573/REM)

"Chris Brown" has used the ConsulteeAccess for Planning website to submit their comments on a Planning Application. You have received this message because you are the Case Officer for this application or because this is a designated mailbox for ConsulteeAccess comments submissions.

Comments were submitted at 05/08/2009 12:24:39 from IP 192.168.0.3.

Application Summary

Application Number:
09/00573/REM

Address:
Spinney Bank Farm
Higham Lane
Stoke Golding
Nuneaton
Leicestershire
CV13 6ES

Proposal:
ERECTION OF ONE AGRICULTURAL DWELLING

Case Officer:
Louise Forman

Customer Details

Name:
Chris Brown

Address:
HBBC

Postcode:

Email:
chris.brown@hinckley-bosworth.gov.uk

Phone Number:

Comments

Submission Type:
Customer wishes to comment on the Planning Application.

Comments:
Access drives, parking and turning areas, paths and patios should be constructed in a permeable paving system, with or without attenuation storage, depending on ground strata permeability. On low-permeability sites surface water dispersal may be augmented by piped land drains, installed in the foundations of the paving, discharging to an approved outlet.

The septic tank proposal will require the consent of the Environment Agency and must comply with the Agency's conditions.

ConsulteeAccess for Planning. (c) CAPS Solutions Ltd.