Denise Stone

From: planning@hinckley-bosworth.gov.uk
Posted At: 05 August 2009 12:48
Conversation: ConsulteeAccess for Planning - Application Comments (09/00540/FUL)
Posted To: Planning Application Comments

Subject: ConsulteeAccess for Planning - Application Comments (09/00540/FUL)

ConsulteeAccess for Planning - Application Comments (09/00540/FUL)

"Chris Brown" has used the ConsulteeAccess for Planning website to submit their comments on a Planning Application. You have received this message because you are the Case Officer for this application or because this is a designated mailbox for ConsulteeAccess comments submissions.

Comments were submitted at 05/08/2009 12:47:44 from IP 192.168.0.3.

Application Summary

Application Number:
09/00540/FUL

Address:
20 Laneside Drive
Hinckley
Leicestershire
LE10 1TG

Proposal:
EXTENSION AND ALTERATIONS TO DWELLING

Case Officer:
James Hicks

Customer Details

Name:
Chris Brown

Address:
HBBC

Postcode:

Email:
chris.brown@hinckley-bosworth.gov.uk

Phone Number:

Comments

Submission Type:

Comments:
If the front garden is to be paved over, the new surfaces should be constructed in a permeable paving system, with or without attenuation storage, depending on ground strata permeability. On low-permeability sites surface water dispersal may be augmented by piped land drains, installed in the foundations of the paving, discharging to an approved outlet.