

From: public.access@hinckley-bosworth.gov.uk
Sent: 09 July 2024 12:52
To: Planning Application Comments
Subject: Consultee Comments for Planning Application 24/00577/HOU

Consultee comments

Dear Sir/Madam,

A consultee has commented on a Planning Application. A summary of the comments is provided below.

Comments were submitted at 09/07/2024 12:52 PM from Mr Peter Reid (peter.reid@hinckley-bosworth.gov.uk) on behalf of HBBC Drainage.

Application Summary

Reference:	24/00577/HOU
Address:	2 Kennel Cottages From Ashby Road B4116 To Gopsall Estate Via Kennel Cottages Gopsall Twycross Atherstone Leicestershire CV9 3QJ
Proposal:	Construction of new outbuilding/office including the demolition of existing outbuilding
Case Officer:	Richard Wright

[Click for further information](#)

Comments Details

Note to Applicant:

Comments:	Rainwater from the detached outbuilding roof should be positively drained into a suitable water butt, soakaway or domestic drainage system, and not be permitted to discharge directly onto the surface of the application site and neighbouring properties.
-----------	--

Kind regards