

Application address Factory Units, 23 Wood Street, Hinckley.	Planning ref. 25/00087/REM
	Our ref. 2025/0087/04/F/R1
Description Approval of reserved matters (landscaping and layout) of outline planning permission 22/00695/HYB for the demolition of existing factory building and erection of a residential building comprising up to 12 residential units	Consultation date 12/05/2025
	Response date 26/05/2025
Planning officer Emma Baumber	Reviewing officer Jack Harriman
Application type Reserved Matters	Extension requested ☐
No concerns ☒	Further consultation required ☐

Lead Local Flood Authority Key Observations

Leicestershire County Council as Lead Local Flood Authority (LLFA) notes that the 0.18ha brownfield site is located within Flood Zone 1 being at low risk of fluvial flooding and a low to medium risk of surface water flooding. The proposals under 22/00695/HYB sought to discharge at 5 l/s via pervious paving and attenuation tanks to the Severn Trent Water (STW) combined sewer on Wood Street.

The layout and landscaping within this application are compatible with the surface water management proposals submitted in the outline application and supported by the LLFA. Subsequent to the previous LLFA response the applicant has provided the location of permeable paving within parking areas.

Leicestershire County Council as Lead Local Flood Authority (LLFA) advises the Local Planning Authority (LPA) that the application documents as submitted are sufficient for the LLFA to support the approval of the reserved matters.

Note: Reserved matters applications are reviewed by the LLFA in relation to details such as 'access', 'appearance', 'landscaping', 'layout' and 'scale' only, in line with article 2 of the Town and Country Planning Order 2015. This response does not consider any surface water specific conditions which must be consulted on separately once the reserved matters are approved by the LPA.

Standing Advice to the Local Planning Authority

1. Standing Advice – National Planning Policy Framework

When determining planning applications, the local planning authority should ensure flood risk is not increased elsewhere and only consider development appropriate in areas at risk of flooding

where informed by a site-specific Flood Risk Assessment (FRA) confirming it will not put the users of the development at risk. Where an FRA is applicable this should be undertaken in accordance with the requirements of the National Planning Policy Framework and accompanying Planning Practice Guidance.

2. Standing Advice – Consent

Where there are any works proposed as part of an application which are likely to affect flows in an ordinary watercourse or ditch, the applicant will require consent under Section 23 of the Land Drainage Act 1991. This is in addition to any planning permission that may be granted.

Guidance on this process and a sample application form can be found via the following website:
<http://www.leicestershire.gov.uk/flood-risk-management>

Applicants are advised to refer to Leicestershire County Council's culverting policy contained within the Local Flood Risk Management Strategy Appendix document, available at the above link. No development should take place within 5 metres of any watercourse or ditch without first contacting the County Council for advice.

3. Standing Advice – Maintenance

Note that it is the responsibility of the Local Planning Authority under the DEFRA/DCLG legislation (April 2015) to ensure that a system to facilitate the future maintenance of SuDS features can be managed and maintained in perpetuity before commencement of the works.

Additional information and guidance is available here:

<https://www.leicestershire.gov.uk/environment-and-planning/flooding-and-drainage/>

Note: Response provided by the Lead Local Flood Authority under the delegated authority of the Director of Environment and Transport.