

25/00289/DISCON

Supporting Information to Condition 9 CTMP

Please see attached amended docs for condition 9 these address the below comments as follows:

- The LHA advises it is unclear if this would be the existing farm access to the site, or a new access.
- o The previously submitted proposed a new access however, the attached propose the use of the existing access
- The LHA requests that the Applicant widens the construction access to allow for two-way traffic
- o Width of construction access widened to 5.5m to ensure two-way traffic and reduce risk of conflict at access.
- It would be beneficial for the Applicant to provide the full route(s) which construction traffic would use to access the site
- o See attached Construction Routing Plan