
From: public.access@hinckley-bosworth.gov.uk
Sent: 12 April 2024 12:29
To: Planning Application Comments
Subject: Consultee Comments for Planning Application 24/00083/HYB

Consultee comments

Dear Sir/Madam,

A consultee has commented on a Planning Application. A summary of the comments is provided below.

Comments were submitted at 12/04/2024 12:28 PM from Mr Giles Rawdon (giles.rawdon@hinckley-bosworth.gov.uk) on behalf of HBBC ES Pollution 2.

Application Summary

Reference:	24/00083/HYB
Address:	Land At Burbage Fields Farm Bullfurlong Lane Burbage Leicestershire
Proposal:	Hybrid planning application for 422 dwellings, public open space, associated infrastructure and the demolition of 65 and 65a Coventry Road, and Burbage Fields Farm and outline planning application for a residential care home and up to 11no. self-build plots (all matters reserved except for access)
Case Officer:	Alex Jelley

[Click for further information](#)

Comments Details

Noise

With regard to the updated Noise Impact Assessment I have the following comments:

Comments: The criteria in the report is satisfactory and the mitigation in the form of upgraded double glazing and the acoustic barriers is welcomed. The ventilation strategy for those plots affected by noise from the M69 should be reconsidered. The use of trickle ventilators may provide 'Whole dwelling ventilation' but is generally insufficient to provide ventilation to combat overheating unless the initial ventilation strategy is provided through mechanical ventilation with summer by-pass options.

It is reasonable to expect that occupants would wish to regulate temperature by opening windows particularly during warmer months. Should occupants of the proposed dwellings wish to open windows to regulate temperature during the summer months they could experience higher than desirable levels of noise intrusion- if they were solely reliant on the ability to open windows to assist with the thermal control of their properties.

The requirement for mechanical ventilation has been conditioned on many permissions from HBBC when residential have been positioned adjacent to noise

sources. It gives the occupier the opportunity to make the choice about how they ventilate their rooms especially bedrooms at night. Windows can be opened but if the noise is unacceptable to the occupier, they have the option to use their ventilation and still get fresh air.

I therefore recommended the requirement for mechanical ventilation in the affected plots.

Noise may be conditioned.

Air Quality

The Air Quality Impact Assessment predicts a negligible impact from the operational phase.

The report recommends mitigation measures for the construction phase to form part of a Construction Environmental Management Plan (CEMP) for the site. A CEMP should be conditioned.

Land Contamination

The Phase I Risk Assessment recommends that further intrusive investigation should be carried out for both land contamination and ground gas. This may be conditioned.

CEMP

Due to the scale of the development I recommend that a CEMP is conditioned.

Recommended conditions:

Noise

C40. Noise Attenuation

- a) Development shall not begin until a scheme for protecting the proposed dwellings from noise from the road network has been submitted to and approved by the Local Planning Authority
- b) All works which form part of the scheme shall be completed before any of the permitted dwellings are first occupied.

Noise Attenuation (2)

- a) Development shall not begin until a scheme for protecting nearby dwellings from noise from the proposed development has been submitted to and approved by the Local Planning Authority
- b) All works which form part of the scheme shall be completed before the permitted development first comes into use.

CONTAMINATED LAND

C174. Land Contamination

- a) No development approved by this permission shall be commenced until a scheme for the investigation of any potential land contamination on the site has been submitted to and agreed in writing by the Local Planning Authority which shall include details of how any contamination shall be dealt with.
- b) The approved scheme shall be implemented in accordance with the agreed details and any remediation works so approved shall be carried out prior to the site first being occupied.

NTA 50 - Contaminated Land (1)

In relation to conditions X and X advice from Environmental Health should be sought via esadmin@hinckley-bosworth.gov.uk to ensure that any investigation of land contamination is in accordance with their policy.

C75. Land Contamination Found Later

- a) If during development, contamination not previously identified is found to be present at the site, no further development shall take place until an addendum to the scheme for the investigation of all potential land contamination is submitted to and approved in writing by the Local Planning Authority which shall include details of how the unsuspected contamination shall be dealt with.

b) Any remediation works so approved shall be carried out prior to the site first being occupied.

C77. Landfill Gas Scheme

a) No development approved by this permission shall be commenced until a scheme for the monitoring of landfill gas on the site has been submitted to and agreed in writing by the Local Planning Authority which shall include details of how any landfill gas shall be dealt with.

b) The approved scheme shall be implemented in accordance with the agreed details and any remediation works so approved shall be carried out prior to the site first being occupied.

CONSTRUCTION

a) Prior to commencement of development a Construction Environmental Management Plan shall be submitted to and agreed in writing by the LPA. The plan shall detail how, during the site preparation and construction phase of the development, the impact on existing and proposed residential premises and the environment shall be prevented or mitigated from dust, odour, noise, smoke, light and land contamination. The plan shall detail how such controls will be monitored. The plan will provide a procedure for the investigation of complaints.

b) The agreed details shall be implemented throughout the course of the development.

Site preparation and construction shall be limited to the following hours;

Monday – Friday 07:30 – 18:00

Saturday 08:00 – 13:00

No working on Sundays and Bank Holidays

Kind regards