
From: public.access@hinckley-bosworth.gov.uk
Sent: 08 April 2025 10:45
To: Planning Application Comments
Subject: Consultee Comments for Planning Application 25/00217/HOU

Follow Up Flag: Follow up
Flag Status: Flagged

Consultee comments

Dear Sir/Madam,

A consultee has commented on a Planning Application. A summary of the comments is provided below.

Comments were submitted at 08/04/2025 10:45 AM from Mr Peter Reid (peter.reid@hinckley-bosworth.gov.uk) on behalf of HBBC Drainage.

Application Summary

Reference:	25/00217/HOU
Address:	Woodside Little Lane Desford Leicester Leicestershire LE9 9GP
Proposal:	Single storey front, side and rear extensions, oak framed porch and hip to gable loft conversion with rear dormer and detached double oak framed garage.
Case Officer:	Sophie Iliffe

[Click for further information](#)

Comments Details

Note to Applicant:

Comments:	Rainwater from the detached garage roof should be positively drained into a suitable water butt, soakaway or domestic drainage system, and not be permitted to discharge directly onto the surface of the application site and neighbouring properties.
-----------	---

Kind regards