PLANNING APPLICATION COMMENT SHEET

09/00047/COU CTF

Bijou Stables Brascote Lane Cadeby
CHANGE OF USE OF BUILDINGS AND LAND TO USE OF A LIVERY AND ALTERATION OF ACCESS.
Applicant : Mr Andrew Sutton
Ward : Cadeby Carlton, M Bosworth & Shackerstone

ENVIRONMENTAL SERVICES COMMENTS.

Animal waste and surface water contaminated by animal waste must not be discharged to ditches, watercourses or soakaways. Slurry, contaminated runoff - including wash water - and leachate from stockpiled manure, must be collected in tanks (or lagoons) complying with the standards laid down in the 'Control of Pollution (Silage, Slurry and Agricultural Fuel Oil) Regulations 1991'. Clean roof water should be discharged to soakaways (subject to suitable ground strata), ditches or watercourses.

C Brown
Land drainage Engineer
Date: 06/02/09

SIGNATURE: DATE