PLANNING APPLICATION COMMENT SHEET

LFO	**09/00064/GDO**	Land Off Carlton Road Nailstone
28.01.2009	**CTF**	ERECTION OF A 4 BAY CALF REARING UNIT
DEL		Applicant : Mr David Ingham
		Ward : Cadeby Carlton, M Bosworth & Shackerstone

ENVIRONMENTAL SERVICES COMMENTS.

Animal waste and surface water contaminated by animal waste must not be discharged to ditches, watercourses or soakaways. Slurry, contaminated runoff - including wash water - and leachate from stockpiled manure, must be collected in tanks (or lagoons) complying with the standards laid down in the 'Control of Pollution (Silage, Slurry and Agricultural Fuel Oil) Regulations 1991'. Clean roof water should be discharged to soakaways (subject to suitable ground strata), ditches or watercourses.

C Brown
Land drainage Engineer
Date: 09/02/09

SIGNATURE: DATE