Lesley Keal

From: planning@hinckley-bosworth.gov.uk
Posted At: 04 June 2010 13:48
Conversation: ConsulteeAccess for Planning - Application Comments (10/00341/LBC)
Posted To: Planning Application Comments

Subject: ConsulteeAccess for Planning - Application Comments (10/00341/LBC)

ConsulteeAccess for Planning - Application Comments (10/00341/LBC)

"Chris Brown" has used the ConsulteeAccess for Planning website to submit their comments on a Planning Application. You have received this message because you are the Case Officer for this application or because this is a designated mailbox for ConsulteeAccess comments submissions.

ConsulteeAccess for Planning - Application Comments for 10/00341/LBC "Chris Brown" you have been sent this email because you or somebody else has submitted a comment on a Planning Application to the planning department using your email address.
A summary of your comments is provided below.
Comments were submitted at 04/06/2010 13:48:14 from chris.brown@hinckley-bosworth.gov.uk
Application Summary

Application Number: 10/00341/LBC
Address:
West Hall
Barr Lane
Higham On The Hill
Nuneaton
Leicestershire
CV13 6AN
Proposal:
EXTENSIONS AND ALTERATIONS TO DWELLING INCLUDING PART DEMOLITION Case Officer:
James Hicks
Customer Details

Name:
Chris Brown
Address:
empty
Comments:
If not already constructed, access drives, parking and turning areas should be constructed in a permeable paving system, with or without attenuation storage, depending on ground strata permeability. On low-permeability sites surface water dispersal may be augmented by piped land drains, installed in the foundations of the paving, discharging to an approved outlet. Disregard this comment if the paving works are merely the re-surfacing of an existing tarmacked area.
ConsulteeAccess for Planning. (c) CAPS Solutions Ltd.

ConsulteeAccess for Planning. (c) CAPS Solutions Ltd.