
From: Sian Williams <siwilliams@davidsonsgroup.co.uk>
Sent: 21 September 2023 16:14
To: Lesley Keal; Melissa Balk
Subject: RE: 23/00872/DISCON CEMP Response
Attachments: PJSG21-58-DR-200B_Detailed Foundation Design.pdf

Follow Up Flag: Follow up
Flag Status: Flagged

Hi Lesley,

Yes we will be using piling on site – see attached the foundation key plan highlighting which plots are to be piled. They will not be working outside of the permitted working times. I'm assuming as they will not be working outside of the permitted working times that I don't need to add any details including noise data? We don't know this information at the moment as we are yet to appoint a contractor, so we have no details on the rig being used etc. Is it just some notes regarding vibration that you need adding for this section?

I will also ensure your other comments are included i.e. detailing the proposed site noise limit of 65dB Laeq(t) and no burning of materials will commence on the development.

Thanks.

Siân Williams

Assistant Technical Technician – South Midlands



M. 07554119038
T. 01604 953 200
siwilliams@davidsonsgroup.co.uk

Davidsons Developments Ltd,
South Midlands Office,
Rickyard Barn, Blisworth Hill Farm,
Stoke Road, Blisworth, Northants.
NN73DB
www.davidsonsgroup.co.uk



From: Lesley Keal <Lesley.Keal@hinckley-bosworth.gov.uk>
Sent: Tuesday, September 19, 2023 12:00 PM
To: Melissa Balk <mbalk@davidsonsgroup.co.uk>
Cc: Sian Williams <siwilliams@davidsonsgroup.co.uk>
Subject: 23/00872/DISCON CEMP Response

CAUTION: This email originated from outside of the organisation. Do not click links or open attachments unless you recognize the sender and know the content is safe.

Good Morning

I have received the following response relating to condition 25 CEMP as follows

Condition 25

Will piling be used on site?- if so vibration needs to be considered.

will any plant be operated outside the stated operational hours (e.g. generators/dryers etc) if so please provide details including noise data and the location of the plant. if no plant is to be used this should be expressed in the CEMP.

In the noise control section it is stated that "Where measured levels exceed the specified limit level, measures will, where practicable, be implemented to reduce levels to within the limit level" there is no detail of a proposed site limit (this should be 65dB Laeq(t) using the ABC method in BS5228).

There should be no burning of any materials on the site- this should be expressed in the CEMP.

A complaints procedure should be included.

I await a response from Highways and they have upto 3 October to submit. In the meantime if you can address the points raised above I would be grateful

Many thanks

Kind Regards

Lesley Keal (Her/She)

Compliance & Monitoring Officer

Tel: 01455 255905

Email: Lesley.keal@hinckley-bosworth.gov.uk

Web: www.hinckley-bosworth.gov.uk

Hinckley Hub, Rugby Road, Hinckley, Leics LE10 0FR

**Hinckley & Bosworth
Borough Council**

**Hinckley & Bosworth
Borough Council**

Sign up for our email updates: www.hinckley-bosworth.gov.uk/emailupdates



@Hinckandbos_bc



Hinckandbosbc



@Hinckandbosbc

This email and any files sent with it are confidential.

If this email isn't intended for you, please notify the sender immediately and then permanently delete it.

You must not read, print, store, disclose, copy or take any other action in respect of this email.

We routinely monitor incoming and outgoing email messages to ensure they comply with Hinckley & Bosworth Borough Council's policy on the use of electronic communications.

The contents of emails may have to be disclosed to a request under the Data Protection Act 2018, Freedom of Information Act 2000 and/or the Environmental Information Regulations 2004.

The views expressed by the author may not necessarily reflect the views or policies of Hinckley & Bosworth Borough Council.

Attachments to email messages may contain viruses that may damage your system.

Whilst Hinckley & Bosworth Borough Council has taken every reasonable precaution to minimise this risk, we cannot accept any liability for any damage you suffer as a result.

You are advised to carry out your own virus checks before opening any attachment.

Save paper - only print this email if necessary.

Visit us online: https://linklock.titanhq.com/analyse?url=http%3A%2F%2Fwww.hinckley-bosworth.gov.uk&data=eJx1jUeLwiAYhn-N3pLlxO3ilYiN6hREd6c2RTeH3zbp32f3gvfywMvzKMFryjjila64GbAWWu5OQ5xhTHFbilpk83gSjezt43Lr783zikEsaQdUn4-ccqraV9sUCAaCeRNvZECssm5WvvBhiJBjWiOZ4_51JQEuuxCcnKD8fvY2Ydd1QfUJ0a4s50z--T6HN0Lg

Main office: Hinckley Hub, Rugby Road, Hinckley, Leics LE10 0FR. Main switchboard: 01455 238141

