Steve Atkinson MA(Oxon) MBA MioD FRSA
Chief Executive

Please Ask For: Louise Forman
Direct Dial/Ext: 01455 255682
Direct Fax: 01455 619897
Email: planning@hinckley-bosworth.gov.uk
Your Ref: WP10-04-11
Our Ref: 10/00248/FUL
Date: 16 April 2010

Hinckley & Bosworth Borough Council

A Borough to be proud of

Central Networks
Herald Way
Pegasus Business Park
East Midlands Airport
Castle Donington
DE74 2TU

Dear Sir

DESCRIPTION : **ERECTION OF ONE DWELLING**
LOCATION : **Land Rear Of 3 Hall Drive Stoke Golding Leicestershire**
GRID REF : **E : 440211** **N : 297138**

A planning application has been received for the above proposal. If you have any comments to make would you please enter them via the Consultee Access website (https://cx.hinckley-bosworth.gov.uk/ConsulteeAccess/authentication/consultee_login.aspx) within 21 days of the date of this correspondence.

Yours faithfully

INFRASTRUCTURE SERVICES
16 APR 2010
REPLY BY
22 APR 2010
PEGASUS

SIMON WOOD
HEAD OF PLANNING

Unable to add comments online. - Website Error.

e·on | Central Networks

19 APR 2010

Our Ref: **WP10-0411 MB**
Your Ref: 10/00248/FUL

Mr Simon Wood
Hinckley & Bosworth Borough Council
Council Offices
Argents Mead
Hinckley
Leicestershire
LE10 1BZ

DEVELOPMENT SERVICES
19 APR 2010
RECEIVED

Central Networks
Pegasus Business Park
Castle Donington
Derbyshire
United Kingdom
DE74 2TU
central-networks.co.uk

Central Support Team
T 02476 185846
F 0115 8767429
centralsupportteam
@central-networks.co.uk

16 April 2010

Dear Mr Wood,

Re: Erection of one dwelling – land rear of 3 Hall Drive, Stoke Golding, Leicestershire

Thank you for allowing me to comment on the above development.

In this instance we do not object to the development as proposed.

However, we must emphasize the following;

Central Networks has Network within close proximity to the proposed site. ☐

Central Networks has Network within the proposed site. ☑

Central Networks requires 24 hour access to this network. ☑

Please contact **Aim Bureau Services** at **Toll End Road, Tipton, DY4 0HH** to obtain copies of our mains records. There may be a charge levied for this service. ☑

For new developments, diversions and ground works you can contact Central Networks **CAT Team** at **Toll End Road, Tipton, DY4 0HH**. ☑

P.T.O

For information regarding the safety of working around our networks, please contact our **Cablesafe Team** on **0800 0150 927** or on http://www.eon-uk.com/distribution/1701.aspx

There is an electricity substation within close proximity of the development.

A substation is a potential source of noise, therefore the developer should adopt measures to ensure that acceptable noise levels are maintained for future residents.

We must emphasise that any alteration, building or ground works proposed in the vicinity of our cables that may or may not directly affect our cables, must be notified in detail to Central Networks.

For further information please contact me at **Central Networks, Pegasus Business Park, Castle Donington, Derbyshire DE74 2TU** or email centralsupportteam@central-networks.co.uk

Yours sincerely

H Band

Central Support Team
Infrastructure Services

Website Error - unable to add comments online.