

24/01006/DISCON

Summary of details submitted to satisfy Condition 27 following the LLFA and Drainage Officer Comments :

- Hydraulic calculations
 - o E279 SW Calculations V05 - 1yr, 30yr, 30yr +35% CC & 100yr +40% CC Storm Events +10% UC
- Clear evidence that a point of discharge to the existing watercourse is not viable. - – Will follow up with this within the new year
- Construction details (cross-sectional) of the proposed flow-control chamber and the attenuation basin. Please ensure these are site-specific rather than typical details.
 - o E279-20-11A BASIN SECTIONS & PLAN - SHEET 1 OF 1-A1
 - o E279-40-05B CONTROL CHAMBER S110 DETAIL-A1
- Private drainage / external levels details.
 - o E279-90-01 EXTERNAL WORKS AND PRIVATE DRAINAGE A1
 - o E279-90-02 EXTERNAL WORKS AND PRIVATE DRAINAGE A1
- Details of who will take on the maintenance of the flow control chamber and attenuation basin (C29).
 - o Icosa water the adopting body of the S104 network will adopt the control chamber and Stonewater the housing association and landowner will include the maintenance of the attenuation basin within their maintenance regime of the development.