
From: public.access@hinckley-bosworth.gov.uk
Sent: 07 September 2023 13:59
To: Planning Application Comments
Subject: Consultee Comments for Planning Application 23/00866/DISCON

Categories: Rudi

Consultee comments

Dear Sir/Madam,

A consultee has commented on a Planning Application. A summary of the comments is provided below.

Comments were submitted at 07/09/2023 1:59 PM from Mr Giles Rawdon (giles.rawdon@hinckley-bosworth.gov.uk) on behalf of HBBC ES Pollution 2.

Application Summary

Reference:	23/00866/DISCON
Address:	FP McCann Brascote Lane Cadeby Nuneaton Leicestershire CV13 0BB
Proposal:	Application to discharge conditions 6 (External Lighting), 14 (Surface Water Drainage and Long Term Maintenance), 15 (Surface Water Drainage during Construction), 16 (Landscape Management Plan), 17 (Materials) attached to planning permission 22/00420/FUL
Case Officer:	Lesley Keal

[Click for further information](#)

Comments Details

Comments:	Condition 6 Details should be submitted to demonstrate that the lighting on site will comply with the Institution of Lighting Professionals Guidance Note 1 for the reduction of obtrusive light 2021. An Environmental Zone E2 should be used. a vertical plane at an appropriate height for surrounding dwellings should be used.
-----------	--

Kind regards