

From: public.access@hinckley-bosworth.gov.uk
Sent: 03 January 2025 14:38
To: Planning Application Comments
Subject: Consultee Comments for Planning Application 24/01116/HOU

Consultee comments

Dear Sir/Madam,

A consultee has commented on a Planning Application. A summary of the comments is provided below.

Comments were submitted at 03/01/2025 2:37 PM from Mr Peter Reid (peter.reid@hinckley-bosworth.gov.uk) on behalf of HBBC Drainage.

Application Summary

Reference:	24/01116/HOU
Address:	1 Quarrymans Court Markfield Leicester Leicestershire LE67 9XQ
Proposal:	Garden outbuilding
Case Officer:	Richard Wright

[Click for further information](#)

Comments Details

Note to Applicant:

Comments:	Rainwater from the outbuilding roof should be positively drained into a suitable water butt, soakaway or domestic drainage system, and not be permitted to discharge directly onto the surface of the application site and neighbouring properties.
-----------	---

Kind regards