Louise Forman

From: Nicola Allatt [Nicola.Allatt@intmail.mouchelparkman.com]
Sent: 05 October 2007 16:28
To: James Howe
Subject: Tesco Hinckley drawings

Hi James,

Please find attached my amended detailed design drawings for the above scheme which address the comments received from Leicestershire County Council on 10/09/07. These drawings now require approval by the council.

Concerning the issue raised by LCC of the new BT chamber being within the tactile paving, I can confirm that tactile paving can be laid in the chamber lid but that LCC will be responsible for the future maintenance of it. I spoke to Ian Harrison of BT and he said that there were two options for the blocks - either normal sized ones laid within a pre-sunk lid, or thinner blocks stuck onto a regular lid. He said that he hadn't experienced any problems with either type. He also stressed that he'd be happy to discuss the matter with the council to get the best option for them, ideally by positioning the chamber away from the tactile paving if possible.

Regards

Nicola Allatt

Assistant Engineer

tel 0161 838 6006