
From: public.access@hinckley-bosworth.gov.uk
Sent: 26 March 2025 11:53
To: Planning Application Comments
Subject: Consultee Comments for Planning Application 25/00203/DISCON

Consultee comments

Dear Sir/Madam,

A consultee has commented on a Planning Application. A summary of the comments is provided below.

Comments were submitted at 26/03/2025 11:53 AM from Mr Peter Reid (peter.reid@hinckley-bosworth.gov.uk) on behalf of HBBC Drainage.

Application Summary

Reference:	25/00203/DISCON
Address:	Hinckley And District General Hospital Mount Road Hinckley Leicestershire LE10 1AE
Proposal:	Application to discharge C15 (Long Term Maintenance of SuDS) C17 (Intergrated Swift Boxes) C22 (Car Park Management Agreement) attached to planning permission 23/00851/OUT
Case Officer:	Emma Baumber

[Click for further information](#)

Comments Details

Comments:	C15 - the submitted SuDS O&M Manual should also include for the long-term maintenance of the permeable paving
-----------	---

Kind regards