Lesley Keal

From: planning@hinckley-bosworth.gov.uk
Posted At: 06 October 2010 17:07
Conversation: ConsulteeAccess for Planning - Application Comments (10/00681/FUL)
Posted To: Planning Application Comments

Subject: ConsulteeAccess for Planning - Application Comments (10/00681/FUL)

ConsulteeAccess for Planning - Application Comments (10/00681/FUL)

"Chris Brown" has used the ConsulteeAccess for Planning website to submit their comments on a Planning Application. You have received this message because you are the Case Officer for this application or because this is a designated mailbox for ConsulteeAccess comments submissions.

ConsulteeAccess for Planning - Application Comments for 10/00681/FUL "Chris Brown" you have been sent this email because you or somebody else has submitted a comment on a Planning Application to the planning department using your email address.
A summary of your comments is provided below.
Comments were submitted at 06/10/2010 17:06:38 from chris.brown@hinckley-bosworth.gov.uk
Application Summary

Application Number: 10/00681/FUL
Address:
Narrows House
The Narrows
Hinckley
Leicestershire
LE10 1EH

Proposal:
PROPOSED 3 NO. NEW TOWN HOUSES
Case Officer:
Sarah Fryer
Customer Details

Name:
Chris Brown
Address:
empty
Comments:
Surface water should be discharged to a soakaway, subject to the presence of satisfactorily permeable ground strata. In ground of borderline permeability a high level overflow should be provided to transfer excess water to the combined sewer.
ConsulteeAccess for Planning. (c) CAPS Solutions Ltd.

ConsulteeAccess for Planning. (c) CAPS Solutions Ltd.