Lesley Keal

From: planning@hinckley-bosworth.gov.uk
Posted At: 06 October 2010 17:19
Conversation: ConsulteeAccess for Planning - Application Comments (10/00558/FUL)
Posted To: Planning Application Comments

Subject: ConsulteeAccess for Planning - Application Comments (10/00558/FUL)

ConsulteeAccess for Planning - Application Comments (10/00558/FUL)

"Chris Brown" has used the ConsulteeAccess for Planning website to submit their comments on a Planning Application. You have received this message because you are the Case Officer for this application or because this is a designated mailbox for ConsulteeAccess comments submissions.

ConsulteeAccess for Planning - Application Comments for 10/00558/FUL "Chris Brown" you have been sent this email because you or somebody else has submitted a comment on a Planning Application to the planning department using your email address.
A summary of your comments is provided below.
Comments were submitted at 06/10/2010 17:18:57 from chris.brown@hinckley-bosworth.gov.uk
Application Summary

Application Number: 10/00558/FUL
Address:
122 Wolvey Road
Burbage
Hinckley
Leicestershire
LE10 2JJ
Proposal:
EXTENSIONS AND ALTERATIONS TO DWELLING.
Case Officer:
Kevin Roeton
Customer Details

Name:
Chris Brown
Address:
empty
Comments:
Access drives, parking and turning areas should be constructed in a permeable paving system, with or without attenuation storage, depending on ground strata permeability. On low-permeability sites surface water dispersal may be augmented by piped land drains, installed in the foundations of the paving, discharging to an approved outlet. (See Environment Agency guidance on the permeable surfacing of front gardens)
ConsulteeAccess for Planning. (c) CAPS Solutions Ltd.

ConsulteeAccess for Planning. (c) CAPS Solutions Ltd.