

Application address Ashfield Farm Kirkby Road Desford Leicester Leicestershire	Planning ref. 24/00709/REM
	Our ref. 2024/0709/04/F
Description Application for approval (relating to Appearance, Landscaping, Layout and Scale for the erection of 120 dwellings and associated works.) attached to planning permission 22/01227/OUT	Consultation date 17/09/2024
	Response date 08/10/2024
Planning officer Alex Jelley	Reviewing officer Andrew Smallwood
Application type Reserved Matters	Extension requested ☐
No concerns ☒	Further consultation required ☐

Lead Local Flood Authority Key Observations

Leicestershire County Council as Lead Local Flood Authority (LLFA) notes that the 5.35 ha greenfield site is located within Flood Zone 1 being at low risk of fluvial flooding and a very low to low risk of surface water flooding. The proposals seek to discharge at 23.5 l/s via pervious paving and a dry detention basin an existing Severn Trent Water (STW) surface water sewer to the north-east of the site with two options.

The proposed site layout has altered significantly from the layout that was approved in 22/01227/OUT. These changes make minimal impact on the drainage strategy as presented in that application. The LLFA however notes that no detail has been provided on location and specifications of SuDS features, the layout as proposed doesn't limit or preclude their inclusion.

Note: Reserved matters applications are reviewed by the LLFA in relation to details such as 'access', 'appearance', 'landscaping', 'layout' and 'scale' only, in line with article 2 of the Town and Country Planning Order 2015

Leicestershire County Council as Lead Local Flood Authority (LLFA) advises the Local Planning Authority (LPA) that the application documents as submitted are sufficient for the LLFA to support the approval of the reserved matters.

Standing Advice to the Local Planning Authority

1. Standing Advice – National Planning Policy Framework

When determining planning applications, the local planning authority should ensure flood risk is not increased elsewhere and only consider development appropriate in areas at risk of flooding where informed by a site-specific Flood Risk Assessment (FRA) confirming it will not put the users of the development at risk. Where an FRA is applicable this should be undertaken in

accordance with the requirements of the National Planning Policy Framework and accompanying Planning Practice Guidance.

2. Standing Advice – Consent

Where there are any works proposed as part of an application which are likely to affect flows in an ordinary watercourse or ditch, the applicant will require consent under Section 23 of the Land Drainage Act 1991. This is in addition to any planning permission that may be granted.

Guidance on this process and a sample application form can be found via the following website:

<http://www.leicestershire.gov.uk/flood-risk-management>

Applicants are advised to refer to Leicestershire County Council's culverting policy contained within the Local Flood Risk Management Strategy Appendix document, available at the above link. No development should take place within 5 metres of any watercourse or ditch without first contacting the County Council for advice.

3. Standing Advice – Maintenance

Note that it is the responsibility of the Local Planning Authority under the DEFRA/DCLG legislation (April 2015) to ensure that a system to facilitate the future maintenance of SuDS features can be managed and maintained in perpetuity before commencement of the works.

Additional information and guidance is available here:

<https://www.leicestershire.gov.uk/environment-and-planning/flooding-and-drainage/>

Note: Response provided by the Lead Local Flood Authority under the delegated authority of the Director of Environment and Transport.