Lisa Clarke

From: planning@hinckley-bosworth.gov.uk
Posted At: 21 July 2010 14:24
Conversation: ConsulteeAccess for Planning - Application Comments (10/00530/FUL)
Posted To: Planning Application Comments

Subject: ConsulteeAccess for Planning - Application Comments (10/00530/FUL)

ConsulteeAccess for Planning - Application Comments (10/00530/FUL)

"L.C.C. Highways" has used the ConsulteeAccess for Planning website to submit their comments on a Planning Application. You have received this message because you are the Case Officer for this application or because this is a designated mailbox for ConsulteeAccess comments submissions.

ConsulteeAccess for Planning - Application Comments for 10/00530/FUL "L.C.C. Highways" you have been sent this email because you or somebody else has submitted a comment on a Planning Application to the planning department using your email address. A summary of your comments is provided below.
Comments were submitted at 21/07/2010 14:23:41 from Application Summary
---
Application Number: 10/00530/FUL
Address:
72 Fletcher Road
Burbage
Hinckley
Leicestershire
LE10 2PS
Proposal:
ERECTION OF ONE DWELLING.
Case Officer:
Sarah Fryer
Customer Details

Name:
L.C.C. Highways
Address:
empty
Comments:
Could you please consider the Highway Authority response through the 'Standing advice' procedure with the following comments?:
Consider parking within the curtilage of the new and existing dwellings.
Consider nothing at the highway boundary at the site frontage should be erected or allowed to grow above 0.6 metres above level of footway.
Consider surfacing of accesses.
Consider drainage of accesses.
Consider gradient?
Note- All works within the highway. Area Manager etc.
ConsulteeAccess for Planning. (c) CAPS Solutions Ltd.

ConsulteeAccess for Planning. (c) CAPS Solutions Ltd.