

24/00605/DISCON

C10 Plan Noise Assessment email received 3 July 2024

Condition No.10 – Plant Noise Assessment:

With regards to the specifications of the remediation measures recommended:

GFT can confirm that we shall be advancing in accordance with the recommendations described within Apex's Plant Noise Impact Assessment.

An 16dB Kit acoustic enclosure will be provided for 1no.ASHP and an 18dB acoustic enclosure for 2no. VRV condensers as below:

- ☐ ASHP – QAHV-N560YA
- ☐ CU01 – REYA16A
- ☐ CU02 – REYA16A

Enclosures to be free standing full acoustic enclosures.

Galvanised finish as per the typical image below.

These units are to sit on an external slab.