

24/00327/DISCON

Email received 5 July 2024 re Piling C18 CEMP

Piling contractor and they will struggle to meet the limit of 1mm/s. They have advised they will implement measures to reduce vibrations to ensure we are no more than 3mm/s – which was the limit we agreed with yourself at our Burgess Factory site. I hope this is acceptable.

No plant will be operated outside the stated site operating hours