
From: public.access@hinckley-bosworth.gov.uk
Sent: 23 October 2024 16:55
To: Planning Application Comments
Subject: Consultee Comments for Planning Application 24/00914/OUT

Categories: Tidd

Consultee comments

Dear Sir/Madam,

A consultee has commented on a Planning Application. A summary of the comments is provided below.

Comments were submitted at 23/10/2024 4:55 PM from Mr Peter Reid (peter.reid@hinckley-bosworth.gov.uk) on behalf of HBBC Drainage.

Application Summary

| | |
|---------------|--|
| Reference: | 24/00914/OUT |
| Address: | Burroughs Road Recreation Ground Burroughs Road Ratby Leicester Leicestershire LE6 0XZ |
| Proposal: | Outline planning application (with all four matters reserved apart from access) for a phased mixed-use development comprising about 470 dwellings (Use Class C3) or, in the alternative, about 450 dwellings and care home/extra care facility (Use Class C2/C3). Provision of a community hub (Use Class F2); 1FE primary school (Use Class F1); and associated operations and infrastructure including but not limited to site re-profiling works, sustainable urban drainage system, public open space, landscaping, habitat creation, internal roads/routes, and upgrades to the public highway. |
| Case Officer: | Alex Jolley |

[Click for further information](#)

Comments Details

No objection subject to the following conditions:

Development shall not begin until a scheme to provide a sustainable surface water drainage system in accordance with the Sustainable Drainage Statement (Revision P03) dated September 2024 has been submitted to and approved by the Local Planning Authority, and the scheme shall subsequently be implemented in accordance with the approved details before the development is completed.

| | |
|-----------|---|
| Comments: | Prior to commencement of development details in relation to the management of surface water on site during construction of the development shall be submitted to, and approved in writing by, the Local Planning Authority. Details should demonstrate how surface water will be managed on site to prevent an increase in flood risk during the various construction stages of development from initial site works through to completion. This shall include temporary attenuation, additional treatment, controls, maintenance and protection. Details regarding the protection of any proposed infiltration areas should also be provided. |
|-----------|---|

Prior to commencement of development details in relation to the long term maintenance of the sustainable surface water drainage system on the development shall be submitted to and approved in writing by the Local Planning Authority. Details of the SuDS Maintenance Plan should include responsibilities and schedules for routine maintenance, remedial actions and monitoring of the separate elements of the system and should also include procedures that must be implemented in the event of pollution incidents within the development site.

Kind regards