
From: public.access@hinckley-bosworth.gov.uk
Sent: 23 October 2024 17:05
To: Planning Application Comments
Subject: Consultee Comments for Planning Application 24/00959/HOU

Categories: Tidd

Consultee comments

Dear Sir/Madam,

A consultee has commented on a Planning Application. A summary of the comments is provided below.

Comments were submitted at 23/10/2024 5:04 PM from Mr Peter Reid (peter.reid@hinckley-bosworth.gov.uk) on behalf of HBBC Drainage.

Application Summary

Reference:	24/00959/HOU
Address:	2 The Manor Wood Lane Norton Juxta Twycross Nuneaton Leicestershire CV9 3QB
Proposal:	Double garage
Case Officer:	Richard Wright

[Click for further information](#)

Comments Details

Note to Applicant:

Comments: Rainwater from the garage roof should be positively drained into a suitable water butt, soakaway or domestic drainage system, and not be permitted to discharge directly onto the surface of the application site and neighbouring properties.

Kind regards