Lesley Keal

From: planning@hinckley-bosworth.gov.uk
Posted At: 04 May 2010 16:52
Conversation: ConsulteeAccess for Planning - Application Comments (10/00234/FUL)
Posted To: Planning Application Comments

Subject: ConsulteeAccess for Planning - Application Comments (10/00234/FUL)

ConsulteeAccess for Planning - Application Comments (10/00234/FUL)

"Chris Brown" has used the ConsulteeAccess for Planning website to submit their comments on a Planning Application. You have received this message because you are the Case Officer for this application or because this is a designated mailbox for ConsulteeAccess comments submissions.

ConsulteeAccess for Planning - Application Comments for 10/00234/FUL "Chris Brown" you have been sent this email because you or somebody else has submitted a comment on a Planning Application to the planning department using your email address.
A summary of your comments is provided below.
Comments were submitted at 04/05/2010 16:52:12 from chris.brown@hinckley-bosworth.gov.uk
Application Summary

Application Number: 10/00234/FUL
Address:
Barn Adjacent
Leicester Lane
Desford
Leicestershire

Proposal:
ERECTION OF AN AGRICULTURAL BUILDING.
Case Officer:
Sarah Humphries
Customer Details

Name:
Chris Brown
Address:
empty
Comments:
The suitability of the ground strata for soakaway drainage should be ascertained by means of the test described in BRE Digest 365, and the results approved by the Building Control Surveyor before development is commenced. The soakaway must be constructed either as a brick or concrete-lined perforated chamber with access for maintenance or, alternatively, assembled from units of one of the newer, modular systems, comprising cellular tanks and incorporating silt traps. Design and construction of all types of soakaway will be subject to the approval of the Building Control Surveyor.

Animal waste and surface water contaminated by animal waste must not be discharged to ditches, watercourses or soakaways. Slurry, contaminated runoff - including wash water - and leachate from stockpiled manure, must be collected in tanks (or lagoons) complying with the standards laid down in the 'Control of Pollution (Silage, Slurry and Agricultural Fuel Oil) Regulations 1991'. Clean roof water should be discharged to soakaways (subject to suitable ground strata), ditches or watercourses.
ConsulteeAccess for Planning. (c) CAPS Solutions Ltd.

ConsulteeAccess for Planning. (c) CAPS Solutions Ltd.