
From: public.access@hinckley-bosworth.gov.uk
Sent: 20 September 2024 12:09
To: Planning Application Comments
Subject: Consultee Comments for Planning Application 24/00846/OUT
Categories: Rudi

Consultee comments

Dear Sir/Madam,

A consultee has commented on a Planning Application. A summary of the comments is provided below.

Comments were submitted at 20/09/2024 12:08 PM from Mr Peter Reid (peter.reid@hinckley-bosworth.gov.uk) on behalf of HBBC Drainage.

Application Summary

Reference:	24/00846/OUT
Address:	106 Station Road Earl Shilton Leicester Leicestershire LE9 7GB
Proposal:	Outline planning permission for the demolition of existing garage service station and car wash and erection of 5 residential dwellings (all matters reserved)
Case Officer:	Emma Baumber

[Click for further information](#)

Comments Details

No objection subject to the following condition:

Comments:	Development shall not begin until surface water drainage details, incorporating sustainable drainage principles (SuDS) have been submitted to and approved by the Local Planning Authority, and the scheme shall subsequently be implemented in accordance with the approved details before the development is completed.
-----------	---

Kind regards