

Application address The Fulford, Bosworth Road, Osbaston, CV13 0HT.	Planning ref.	24/00416/FUL
	Our ref.	2024/0416/04/F
Description Construction of a new self-build dwelling.	Consultation date	09/05/2024
	Response date	30/05/2024
Planning officer Satbir Jandu	Reviewing officer	Harvey Speed
Application type Full	Extension requested	☐

LLFA Key Observations and Advice

Leicestershire County Council as Lead Local Flood Authority (LLFA) notes that the 0.1547ha developed site is located within Flood Zone 1 being at low risk of fluvial flooding and a very low risk of surface water flooding.

This application is for the replacement of an existing dwelling with a self-build 4 bedroom dwelling. The proposals are therefore not considered to be major development as defined by Article 2 of The Town and Country Planning (Development Management Procedure) (England) Order 2015.

The LLFA is not a statutory consultee for this application and offers **no comment**. Please refer to the enclosed standing advice.

Advice to the Local Planning Authority

1. Standing Advice – National Planning Policy Framework

When determining planning applications, the local planning authority should ensure flood risk is not increased elsewhere and only consider development appropriate in areas at risk of flooding where informed by a site-specific Flood Risk Assessment (FRA) confirming it will not put the users of the development at risk. Where an FRA is applicable this should be undertaken in accordance with the requirements of the National Planning Policy Framework and accompanying Planning Practice Guidance.

2. Standing Advice – Consent

Where there are any works proposed as part of an application which are likely to affect flows in an ordinary watercourse or ditch, the applicant will require consent under Section 23 of the Land Drainage Act 1991. This is in addition to any planning permission that may be granted. Guidance on this process and a sample application form can be found via the following website: <http://www.leicestershire.gov.uk/flood-risk-management>

Applicants are advised to refer to Leicestershire County Council's culverting policy contained within the Local Flood Risk Management Strategy Appendix document, available at the above link. No development should take place within 5 metres of any watercourse or ditch without first contacting the County Council for advice.

This consent does not consider local watercourse bylaws. It is the responsibility of the applicant to check if the local borough or district council has their own bylaws which the proposals will also need to consider.

3. Standing Advice – Maintenance

Note that it is the responsibility of the Local Planning Authority under the DEFRA/DCLG legislation (April 2015) to ensure that a system to facilitate the future maintenance of SuDS features can be managed and maintained in perpetuity before commencement of the works.

Additional information and guidance is available here:

<https://www.leicestershire.gov.uk/environment-and-planning/flooding-and-drainage/>

Note: Response provided by the Lead Local Flood Authority under the delegated authority of the Director of Environment and Transport.