

JMS (Midlands) Ltd		Page 1
Victoria Count Tennant St Nuneaton Warwickshire CV11 4LZ	CO22/293/07 Kennel Lane, Atherstone Plots 1 - 5 (Rev A)	
Date 04/07/2023 File MICRODRAINAGE NETWORK 0...	Designed by PG Checked by PG	
XP Solutions	Network 2018.1	

STORM SEWER DESIGN by the Modified Rational Method

Design Criteria for Storm

Pipe Sizes STANDARD Manhole Sizes STANDARD

FSR Rainfall Model - England and Wales

Return Period (years)	2	PIMP (%)	100
M5-60 (mm)	20.000	Add Flow / Climate Change (%)	0
Ratio R	0.400	Minimum Backdrop Height (m)	0.200
Maximum Rainfall (mm/hr)	50	Maximum Backdrop Height (m)	1.500
Maximum Time of Concentration (mins)	30	Min Design Depth for Optimisation (m)	1.200
Foul Sewage (l/s/ha)	0.000	Min Vel for Auto Design only (m/s)	1.00
Volumetric Runoff Coeff.	0.750	Min Slope for Optimisation (1:X)	500

Designed with Level Soffits

Time Area Diagram for Storm

Time (mins)	Area (ha)	Time (mins)	Area (ha)
0-4	0.068	4-8	0.022

Total Area Contributing (ha) = 0.090

Total Pipe Volume (m³) = 1.929

Network Design Table for Storm

PN	Length (m)	Fall (m)	Slope (1:X)	I.Area (ha)	T.E. (mins)	Base Flow (l/s)	k (mm)	HYD SECT	DIA (mm)	Section Type	Auto Design
1.000	11.100	0.110	100.9	0.018	5.00	0.0	0.600	o	150	Pipe/Conduit	
1.001	8.710	0.090	96.8	0.004	0.00	0.0	0.600	o	150	Pipe/Conduit	
2.000	11.052	0.110	100.5	0.018	5.00	0.0	0.600	o	150	Pipe/Conduit	
2.001	9.807	0.100	98.1	0.010	0.00	0.0	0.600	o	150	Pipe/Conduit	
1.002	11.510	0.120	95.9	0.010	0.00	0.0	0.600	o	150	Pipe/Conduit	

Network Results Table

PN	Rain (mm/hr)	T.C. (mins)	US/IL (m)	Σ I.Area (ha)	Σ Base Flow (l/s)	Foul (l/s)	Add Flow (l/s)	Vel (m/s)	Cap (l/s)	Flow (l/s)
1.000	50.00	5.18	71.940	0.018	0.0	0.0	0.0	1.00	17.7	2.4
1.001	50.00	5.33	71.830	0.022	0.0	0.0	0.0	1.02	18.1	3.0
2.000	50.00	5.18	71.950	0.018	0.0	0.0	0.0	1.00	17.7	2.4
2.001	50.00	5.34	71.840	0.028	0.0	0.0	0.0	1.01	17.9	3.8
1.002	50.00	5.53	71.740	0.060	0.0	0.0	0.0	1.03	18.1	8.1

JMS (Midlands) Ltd		Page 2
Victoria Count	CO22/293/07	
Tennant St Nuneaton	Kennel Lane, Atherstone	
Warwickshire CV11 4LZ	Plots 1 - 5 (Rev A)	
Date 04/07/2023	Designed by PG	
File MICRODRAINAGE NETWORK 0...	Checked by PG	
XP Solutions	Network 2018.1	

Network Design Table for Storm

PN	Length (m)	Fall (m)	Slope (1:X)	I.Area (ha)	T.E. (mins)	Base Flow (l/s)	k (mm)	HYD SECT	DIA (mm)	Section Type	Auto Design
3.000	19.890	0.135	147.3	0.010	5.00	0.0	0.600	o	150	Pipe/Conduit	
3.001	24.560	0.165	148.8	0.010	0.00	0.0	0.600	o	150	Pipe/Conduit	
1.003	9.875	0.100	98.8	0.005	0.00	0.0	0.600	o	150	Pipe/Conduit	
1.004	2.645	0.025	105.8	0.005	0.00	0.0	0.600	o	150	Pipe/Conduit	

Network Results Table

PN	Rain (mm/hr)	T.C. (mins)	US/IL (m)	Σ I.Area (ha)	Σ Base Flow (l/s)	Foul (l/s)	Add Flow (l/s)	Vel (m/s)	Cap (l/s)	Flow (l/s)
3.000	50.00	5.40	71.920	0.010	0.0	0.0	0.0	0.83	14.6	1.4
3.001	50.00	5.90	71.785	0.020	0.0	0.0	0.0	0.82	14.5	2.7
1.003	50.00	6.06	71.620	0.085	0.0	0.0	0.0	1.01	17.9	11.5
1.004	50.00	6.11	71.520	0.090	0.0	0.0	0.0	0.98	17.3	12.2

JMS (Midlands) Ltd		Page 3
Victoria Count	CO22/293/07	
Tennant St Nuneaton	Kennel Lane, Atherstone	
Warwickshire CV11 4LZ	Plots 1 - 5 (Rev A)	
Date 04/07/2023	Designed by PG	
File MICRODRAINAGE NETWORK 0...	Checked by PG	
XP Solutions	Network 2018.1	

Manhole Schedules for Storm

MH Name	MH CL (m)	MH Depth (m)	MH Connection	MH Diam., L*W (mm)	PN	Pipe Out Invert Level (m)	Diameter (mm)	PN	Pipes In Invert Level (m)	Diameter (mm)	Backdrop (mm)
1	72.850	0.910	Open Manhole	1200	1.000	71.940	150				
2	72.800	0.970	Open Manhole	1200	1.001	71.830	150	1.000	71.830	150	
3	72.850	0.900	Open Manhole	1200	2.000	71.950	150				
3	72.800	0.960	Open Manhole	1200	2.001	71.840	150	2.000	71.840	150	
3	72.880	1.140	Open Manhole	1200	1.002	71.740	150	1.001	71.740	150	
								2.001	71.740	150	
6	72.750	0.830	Open Manhole	1200	3.000	71.920	150				
6	72.850	1.065	Open Manhole	1200	3.001	71.785	150	3.000	71.785	150	
4	73.000	1.380	Open Manhole	1200	1.003	71.620	150	1.002	71.620	150	
								3.001	71.620	150	
8	73.100	1.580	Open Manhole	1200	1.004	71.520	150	1.003	71.520	150	
	71.800	0.305	Open Manhole	0		OUTFALL		1.004	71.495	150	

JMS (Midlands) Ltd	Page 4
Victoria Count Tennant St Nuneaton Warwickshire CV11 4LZ	CO22/293/07 Kennel Lane, Atherstone Plots 1 - 5 (Rev A)
Date 04/07/2023 File MICRODRAINAGE NETWORK 0...	Designed by PG Checked by PG
XP Solutions	Network 2018.1



PIPELINE SCHEDULES for Storm

Upstream Manhole

PN	Hyd Sect	Diam (mm)	MH Name	C.Level (m)	I.Level (m)	D.Depth (m)	MH Connection	MH DIAM., L*W (mm)
1.000	o	150	1	72.850	71.940	0.760	Open Manhole	1200
1.001	o	150	2	72.800	71.830	0.820	Open Manhole	1200
2.000	o	150	3	72.850	71.950	0.750	Open Manhole	1200
2.001	o	150	3	72.800	71.840	0.810	Open Manhole	1200
1.002	o	150	3	72.880	71.740	0.990	Open Manhole	1200
3.000	o	150	6	72.750	71.920	0.680	Open Manhole	1200
3.001	o	150	6	72.850	71.785	0.915	Open Manhole	1200
1.003	o	150	4	73.000	71.620	1.230	Open Manhole	1200
1.004	o	150	8	73.100	71.520	1.430	Open Manhole	1200

Downstream Manhole

PN	Length (m)	Slope (1:X)	MH Name	C.Level (m)	I.Level (m)	D.Depth (m)	MH Connection	MH DIAM., L*W (mm)
1.000	11.100	100.9	2	72.800	71.830	0.820	Open Manhole	1200
1.001	8.710	96.8	3	72.880	71.740	0.990	Open Manhole	1200
2.000	11.052	100.5	3	72.800	71.840	0.810	Open Manhole	1200
2.001	9.807	98.1	3	72.880	71.740	0.990	Open Manhole	1200
1.002	11.510	95.9	4	73.000	71.620	1.230	Open Manhole	1200
3.000	19.890	147.3	6	72.850	71.785	0.915	Open Manhole	1200
3.001	24.560	148.8	4	73.000	71.620	1.230	Open Manhole	1200
1.003	9.875	98.8	8	73.100	71.520	1.430	Open Manhole	1200
1.004	2.645	105.8		71.800	71.495	0.155	Open Manhole	0

Free Flowing Outfall Details for Storm

Outfall Pipe Number	Outfall Name	C. Level (m)	I. Level (m)	Min I. Level (m)	D,L (mm)	W (mm)
1.004		71.800	71.495	0.000	0	0

JMS (Midlands) Ltd		Page 5
Victoria Count	CO22/293/07	
Tennant St Nuneaton	Kennel Lane, Atherstone	
Warwickshire CV11 4LZ	Plots 1 - 5 (Rev A)	
Date 04/07/2023	Designed by PG	
File MICRODRAINAGE NETWORK 0...	Checked by PG	
XP Solutions	Network 2018.1	

Simulation Criteria for Storm

Volumetric Runoff Coeff	0.750	Additional Flow - % of Total Flow	0.000
Areal Reduction Factor	1.000	MADD Factor * 10m ³ /ha Storage	2.000
Hot Start (mins)	0	Inlet Coefficient	0.800
Hot Start Level (mm)	0	Flow per Person per Day (l/per/day)	0.000
Manhole Headloss Coeff (Global)	0.500	Run Time (mins)	60
Foul Sewage per hectare (l/s)	0.000	Output Interval (mins)	1
Number of Input Hydrographs	0	Number of Storage Structures	7
Number of Online Controls	1	Number of Time/Area Diagrams	0
Number of Offline Controls	0	Number of Real Time Controls	0

Synthetic Rainfall Details

Rainfall Model	FSR	Profile Type	Summer
Return Period (years)	2	Cv (Summer)	0.750
Region	England and Wales	Cv (Winter)	0.840
M5-60 (mm)	20.000	Storm Duration (mins)	30
Ratio R	0.400		

JMS (Midlands) Ltd		Page 6
Victoria Count	CO22/293/07	
Tennant St Nuneaton	Kennel Lane, Atherstone	
Warwickshire CV11 4LZ	Plots 1 - 5 (Rev A)	
Date 04/07/2023	Designed by PG	
File MICRODRAINAGE NETWORK 0...	Checked by PG	
XP Solutions	Network 2018.1	
<u>Online Controls for Storm</u> <u>Orifice Manhole: 8, DS/PN: 1.004, Volume (m³): 1.9</u> Diameter (m) 0.030 Discharge Coefficient 0.600 Invert Level (m) 71.520		
©1982-2018 Innovyze		

JMS (Midlands) Ltd		Page 7
Victoria Count Tennant St Nuneaton Warwickshire CV11 4LZ	CO22/293/07 Kennel Lane, Atherstone Plots 1 - 5 (Rev A)	
Date 04/07/2023 File MICRODRAINAGE NETWORK 0...	Designed by PG Checked by PG	
XP Solutions	Network 2018.1	

Storage Structures for Storm

Porous Car Park Manhole: 1, DS/PN: 1.000

Infiltration Coefficient Base (m/hr)	0.00000	Width (m)	8.0
Membrane Percolation (mm/hr)	1000	Length (m)	10.0
Max Percolation (l/s)	22.2	Slope (1:X)	0.0
Safety Factor	2.0	Depression Storage (mm)	5
Porosity	0.30	Evaporation (mm/day)	3
Invert Level (m)	72.395	Cap Volume Depth (m)	0.375

Porous Car Park Manhole: 2, DS/PN: 1.001

Infiltration Coefficient Base (m/hr)	0.00000	Width (m)	5.0
Membrane Percolation (mm/hr)	1000	Length (m)	8.0
Max Percolation (l/s)	11.1	Slope (1:X)	0.0
Safety Factor	2.0	Depression Storage (mm)	5
Porosity	0.30	Evaporation (mm/day)	3
Invert Level (m)	72.345	Cap Volume Depth (m)	0.375

Porous Car Park Manhole: 3, DS/PN: 2.000

Infiltration Coefficient Base (m/hr)	0.00000	Width (m)	8.0
Membrane Percolation (mm/hr)	1000	Length (m)	10.0
Max Percolation (l/s)	22.2	Slope (1:X)	0.0
Safety Factor	2.0	Depression Storage (mm)	5
Porosity	0.30	Evaporation (mm/day)	3
Invert Level (m)	72.395	Cap Volume Depth (m)	0.375

Porous Car Park Manhole: 3, DS/PN: 2.001

Infiltration Coefficient Base (m/hr)	0.00000	Width (m)	3.0
Membrane Percolation (mm/hr)	1000	Length (m)	10.0
Max Percolation (l/s)	8.3	Slope (1:X)	0.0
Safety Factor	2.0	Depression Storage (mm)	5
Porosity	0.30	Evaporation (mm/day)	3
Invert Level (m)	72.345	Cap Volume Depth (m)	0.375

Porous Car Park Manhole: 3, DS/PN: 1.002

Infiltration Coefficient Base (m/hr)	0.00000	Width (m)	5.0
Membrane Percolation (mm/hr)	1000	Length (m)	14.0
Max Percolation (l/s)	19.4	Slope (1:X)	0.0
Safety Factor	2.0	Depression Storage (mm)	5
Porosity	0.30	Evaporation (mm/day)	3
Invert Level (m)	72.425	Cap Volume Depth (m)	0.375

Porous Car Park Manhole: 6, DS/PN: 3.001

Infiltration Coefficient Base (m/hr)	0.00000	Max Percolation (l/s)	21.7
Membrane Percolation (mm/hr)	1000	Safety Factor	2.0

JMS (Midlands) Ltd		Page 8
Victoria Count	CO22/293/07	
Tennant St Nuneaton	Kennel Lane, Atherstone	
Warwickshire CV11 4LZ	Plots 1 - 5 (Rev A)	
Date 04/07/2023	Designed by PG	
File MICRODRAINAGE NETWORK 0...	Checked by PG	
XP Solutions	Network 2018.1	

Porous Car Park Manhole: 6, DS/PN: 3.001

Porosity	0.30	Slope (1:X)	0.0
Invert Level (m)	72.395	Depression Storage (mm)	5
Width (m)	6.0	Evaporation (mm/day)	3
Length (m)	13.0	Cap Volume Depth (m)	0.375

Porous Car Park Manhole: 4, DS/PN: 1.003

Infiltration Coefficient Base (m/hr)	0.00000	Width (m)	5.0
Membrane Percolation (mm/hr)	1000	Length (m)	10.0
Max Percolation (l/s)	13.9	Slope (1:X)	0.0
Safety Factor	2.0	Depression Storage (mm)	5
Porosity	0.30	Evaporation (mm/day)	3
Invert Level (m)	72.545	Cap Volume Depth (m)	0.375

JMS (Midlands) Ltd		Page 9
Victoria Count	CO22/293/07	
Tennant St Nuneaton	Kennel Lane, Atherstone	
Warwickshire CV11 4LZ	Plots 1 - 5 (Rev A)	
Date 04/07/2023	Designed by PG	
File MICRODRAINAGE NETWORK 0...	Checked by PG	
XP Solutions	Network 2018.1	

1 year Return Period Summary of Critical Results by Maximum Level (Rank 1)
for Storm

Simulation Criteria

Areal Reduction Factor 1.000 Additional Flow - % of Total Flow 0.000
 Hot Start (mins) 0 MADD Factor * 10m³/ha Storage 2.000
 Hot Start Level (mm) 0 Inlet Coefficient 0.800
 Manhole Headloss Coeff (Global) 0.500 Flow per Person per Day (l/per/day) 0.000
 Foul Sewage per hectare (l/s) 0.000

Number of Input Hydrographs 0 Number of Storage Structures 7
 Number of Online Controls 1 Number of Time/Area Diagrams 0
 Number of Offline Controls 0 Number of Real Time Controls 0

Synthetic Rainfall Details

Rainfall Model FSR Ratio R 0.400
 Region England and Wales Cv (Summer) 0.750
 M5-60 (mm) 20.000 Cv (Winter) 0.840

Margin for Flood Risk Warning (mm) 300.0
 Analysis Timestep 2.5 Second Increment (Extended)
 DTS Status OFF
 DVD Status ON
 Inertia Status ON

Profile(s) Summer and Winter
 Duration(s) (mins) 15, 30, 60, 120, 240, 360, 480, 960, 1440
 Return Period(s) (years) 1, 30, 100
 Climate Change (%) 0, 0, 40

									Water
	US/MH			Return	Climate	First (X)	First (Y)	First (Z)	Overflow
PN	Name	Storm	Period	Change	Surcharge	Flood	Overflow	Act.	Level
1.000	1	120 Winter	1	+0%	30/15 Summer				72.081
1.001	2	120 Winter	1	+0%	1/30 Winter				72.080
2.000	3	120 Winter	1	+0%	30/15 Summer				72.082
2.001	3	120 Winter	1	+0%	1/30 Winter				72.081
1.002	3	120 Winter	1	+0%	1/15 Summer				72.079
3.000	6	120 Winter	1	+0%	1/120 Winter				72.078
3.001	6	120 Winter	1	+0%	1/15 Winter				72.078
1.003	4	120 Winter	1	+0%	1/15 Summer				72.076
1.004	8	120 Winter	1	+0%	1/15 Summer				72.071

US/MH		Depth	Volume	Flow /	Overflow	Pipe	Level
PN	Name	(m)	(m ³)	Cap.	(l/s)	Flow	Exceeded
1.000	1	-0.009	0.000	0.05		0.8	OK
1.001	2	0.100	0.000	0.05		0.8	SURCHARGED
2.000	3	-0.018	0.000	0.05		0.8	OK
2.001	3	0.091	0.000	0.07		1.2	SURCHARGED

JMS (Midlands) Ltd		Page 10
Victoria Count Tennant St Nuneaton Warwickshire CV11 4LZ	CO22/293/07 Kennel Lane, Atherstone Plots 1 - 5 (Rev A)	
Date 04/07/2023 File MICRODRAINAGE NETWORK 0...	Designed by PG Checked by PG	
XP Solutions	Network 2018.1	

1 year Return Period Summary of Critical Results by Maximum Level (Rank 1)
for Storm

PN	US/MH Name	Surcharged Flooded		Pipe		Status	Level Exceeded
		Depth (m)	Volume (m ³)	Flow / Overflow Cap. (l/s)	Flow (l/s)		
1.002	3	0.189	0.000	0.12	2.0	SURCHARGED	
3.000	6	0.008	0.000	0.03	0.5	SURCHARGED	
3.001	6	0.143	0.000	0.05	0.7	SURCHARGED	
1.003	4	0.306	0.000	0.08	1.3	SURCHARGED	
1.004	8	0.401	0.000	0.13	1.4	SURCHARGED	

JMS (Midlands) Ltd

Page 11

Victoria Count

Tennant St Nuneaton

Warwickshire CV11 4LZ

CO22/293/07

Kennel Lane, Atherstone

Plots 1 - 5 (Rev A)

Date 04/07/2023

File MICRODRAINAGE NETWORK 0...

Designed by PG

Checked by PG

XP Solutions

Network 2018.1

30 year Return Period Summary of Critical Results by Maximum Level (Rank 1)

for Storm

Simulation Criteria

Areal Reduction Factor 1.000

Additional Flow - % of Total Flow 0.000

Hot Start (mins) 0

MADD Factor * 10m³/ha Storage 2.000

Hot Start Level (mm) 0

Inlet Coefficient 0.800

Manhole Headloss Coeff (Global) 0.500

Flow per Person per Day (l/per/day) 0.000

Foul Sewage per hectare (l/s) 0.000

Number of Input Hydrographs 0

Number of Storage Structures 7

Number of Online Controls 1

Number of Time/Area Diagrams 0

Number of Offline Controls 0

Number of Real Time Controls 0

Synthetic Rainfall Details

Rainfall Model FSR

Ratio R 0.400

Region England and Wales Cv (Summer) 0.750

M5-60 (mm) 20.000

Cv (Winter) 0.840

Margin for Flood Risk Warning (mm) 300.0

Analysis Timestep 2.5 Second

Increment (Extended) DTS Status OFF

DVD Status ON

Inertia Status ON

Profile(s) Summer and Winter

Duration(s) (mins) 15, 30, 60, 120, 240, 360, 480, 960, 1440

Return Period(s) (years) 1, 30, 100

Climate Change (%) 0, 0, 40

PN

US/MH Name

Storm

Return Period

Climate Change

First (X) Surge

First (Y) Flood

First (Z) Overflow

Overflow Act.

Water Level (m)

1.000

1 120 Winter

30

+0%

30/15 Summer

72.460

1.001

2 120 Winter

30

+0%

1/30 Winter

72.459

2.000

3 120 Winter

30

+0%

30/15 Summer

72.461

2.001

3 120 Winter

30

+0%

1/30 Winter

72.460

1.002

3 120 Winter

30

+0%

1/15 Summer

72.458

3.000

6 120 Winter

30

+0%

1/120 Winter

72.457

3.001

6 120 Winter

30

+0%

1/15 Winter

72.455

1.003

4 120 Winter

30

+0%

1/15 Summer

72.453

1.004

8 120 Winter

30

+0%

1/15 Summer

72.447

PN

US/MH Name

Depth (m)

Volume (m³)

Flow / Cap.

Overflow (l/s)

Pipe Flow (l/s)

Status

Level Exceeded

Surcharged

Flooded

1.000

1

0.370

0.000

0.10

1.6

SURCHARGED

1.001

2

0.479

0.000

0.06

0.9

SURCHARGED

2.000

3

0.361

0.000

0.10

1.6

SURCHARGED

2.001

3

0.470

0.000

0.08

1.3

SURCHARGED

©1982-2018 Innovyze

JMS (Midlands) Ltd		Page 12
Victoria Count Tennant St Nuneaton Warwickshire CV11 4LZ	CO22/293/07 Kennel Lane, Atherstone Plots 1 - 5 (Rev A)	
Date 04/07/2023 File MICRODRAINAGE NETWORK 0...	Designed by PG Checked by PG	
XP Solutions	Network 2018.1	

30 year Return Period Summary of Critical Results by Maximum Level (Rank 1)
for Storm

PN	US/MH Name	Surcharged Flooded		Pipe		Status	Level Exceeded
		Depth (m)	Volume (m ³)	Flow / Overflow Cap. (l/s)	Flow (l/s)		
1.002	3	0.568	0.000	0.12	1.9	SURCHARGED	
3.000	6	0.387	0.000	0.07	1.0	FLOOD RISK	
3.001	6	0.520	0.000	0.10	1.3	SURCHARGED	
1.003	4	0.683	0.000	0.12	1.9	SURCHARGED	
1.004	8	0.777	0.000	0.17	1.8	SURCHARGED	

JMS (Midlands) Ltd		Page 14
Victoria Count Tennant St Nuneaton Warwickshire CV11 4LZ	CO22/293/07 Kennel Lane, Atherstone Plots 1 - 5 (Rev A)	
Date 04/07/2023 File MICRODRAINAGE NETWORK 0...	Designed by PG Checked by PG	
XP Solutions	Network 2018.1	

100 year Return Period Summary of Critical Results by Maximum Level (Rank 1) for Storm

PN	US/MH Name	Surcharged		Flooded		Pipe		Status	Level Exceeded
		Depth (m)	Volume (m ³)	Flow / Cap.	Overflow (l/s)	Flow (l/s)			
1.002	3	0.732	0.000	0.12		2.0	FLOOD RISK		
3.000	6	0.551	0.000	0.13		1.8	FLOOD RISK		
3.001	6	0.685	0.000	0.10		1.4	FLOOD RISK		
1.003	4	0.847	0.000	0.12		2.0	SURCHARGED		
1.004	8	0.941	0.000	0.18		1.9	SURCHARGED		