

Schedule						
Symbol	Label	QTY	Manufacturer	Catalog	Description	Lamp Output Input Power
	2FW9	3	HOLOPHANE EUROPE LIMITED	FTS.3.LA094.FW	2FW9 on 6m stepped column	8383 132
	FW9+BLS	6	HOLOPHANE EUROPE LIMITED	FTS.3.LA094.FW+BLS	FW9+BLS on 6m stepped column	8383 66
	H	4	OTHERS	JEE.5312.157.37	Flux LED 1x34,5W LED nw VETRO SABBIAIO	3986 34.5
	K	6	OTHERS	MTA.5407.157AS.37	Apollo LED 25,8W LED nw	2220 25.8



Statistics				
Description	Symbol	Avg	Min	Min/Avg
Service Ramp	+	52 lux	14 lux	0.27
Spill Light	+	0 lux	0 lux	N/A
Under Canopy	+	132 lux	67 lux	0.51
Car Park (20 Ave 5 Min)	+	20 lux	3 lux	0.15



Note
HoloPhane Europe Ltd offer a Lighting Design Service in good faith and without charge, every effort is made to ensure we interpret the design specifications accurately. All illuminance values shown are the result of theoretical computer calculations, summated by luminaires positioned in a fixed relationship to each other and the site's layout. In practice the values may vary due to tolerances in column installation, luminaire orientation, surface reflectance and fluctuations in power supply (voltage). Results provided within this design are derived from product specific phenomena, the substitution of alternative luminaires will not produce comparable results.